



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

June 25, 2012

Paul Craver
Craver Parcel Initial Fill Activities
963 W Orange Rd
Delaware, OH 43065

Re: Storm Water Inspection at Paul Craver Fill Tract Permit #: 4GCO00067*AG

Dear Mr. Craver:

This letter is written in follow-up to a construction storm water inspection by Elizabeth Pleta, Brittany Turner, Jacqueline Sexton, and Alicia Rector of the Ohio EPA, at Craver Parcel Initial Fill Activities located at 963 West Orange Road on June 20, 2012. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

Sediment and Erosion Controls

- It was observed that the orange silt fence on the west side of the site is improperly entrenched (See Photo 1). However, it was noted that the black slit fence further down slope was installed in accordance with the General Storm Water Permit.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Paul Carver Fill Tract Delaware Cnty 6-20-2012

Central District Office
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 728 3778
614 | 728 3898 (fax)
www.epa.ohio.gov