



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

June 28, 2012

Mr. Gary Buck
Plant Manager/Chemist
Jackson Lea/Osborn
3440 Symmes Road
Hamilton, OH 45015

RE: Industrial Site Storm Water Inspection; NPDES permit 1GR00981*EG

Dear Mr. Buck:

On Wednesday, June 20, 2012, I inspected the Jackson Lea facility in Hamilton, Ohio, to determine compliance with its Industrial Storm Water Discharge permit. You represented the facility during this inspection.

Based on my observations, the site appeared to be in substantial compliance with the terms of this permit. From a review of the site's Storm Water Pollution Prevention Plan (SWP3), it appeared a more thorough explanation could be provided regarding the process workers follow to ensure that rainwater collected in containment structures can be released to the storm sewers that ultimately drain to the site. These changes should be made and incorporated in the revised SWP3 as soon as possible.

If you have questions about this information, please contact me at 937.285.6442, or via email at chris.cotton@epa.state.oh.us.

Sincerely,

Chris Cotton
Environmental Specialist II
Division of Surface Water

cc: Ohio EPA/SWDO/DSW Files

CC/ca