



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

June 29, 2012

Sam Van Land
Jaeger Commerce Park
3016 Maryland Ave
Columbus, Oh 43209

**Re: Construction Storm Water Inspection at Jaeger Commerce Park
Permit Number 4GC03201*AG**

Dear Mr. Van Land:

This letter is written regarding the storm water inspection conducted by Jacqueline Sexton, Alicia Rector, Brittany Turner and Elizabeth Pleta of the Ohio EPA at Jaeger Development Corporation on Nationwide Blvd on June 20, 2012. The Agency understands these construction activities are currently covered under Ohio's EPA General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items must be addressed:

Sediment and Erosion Control:

- During the inspection, I noted final reclamation of the site. Please continue all efforts to establish a successful vegetative cover measured by a minimum density of 70%.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. A follow-up inspection will be conducted to ensure the conditions of the General Permit are met.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

HK/hsm 3016 Jaeger Commerce Park June 20, 2012