



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

June 29, 2012

Paul Craver  
Craver Parcel Initial Fill Activities  
963 W Orange Rd  
Delaware, OH 43065

**Re: Storm Water Inspection at Paul Craver Fill Tract  
Permit Number: 4GCO00067\*AG**

Dear Mr. Craver:

This letter is written in follow-up to a construction storm water inspection by Elizabeth Pleta, Brittany Turner, Jacqueline Sexton, and Alicia Rector of the Ohio EPA, at Craver Parcel Initial Fill Activities located at 963 West Orange Road on June 20, 2012. The purpose of the inspection was to evaluate compliance with Ohio EPA's General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

#### **Sediment and Erosion Controls**

- It was observed that the orange silt fence on the west side of the site is improperly entrenched (See Photo 1). However, the black slit fence further down slope was installed in accordance with the General Storm Water Permit.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

HK/nsm Paul Craver Fill Tract Delaware County 6-20-2012

Central District Office  
50 West Town Street, Suite 700  
P.O. Box 1049  
Columbus, OH 43216-1049

614 | 728 3778  
614 | 728 3898 (fax)  
www.epa.ohio.gov



**Figure 1 Orange silt fence improperly entrenched.**