



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

July 2, 2012

Ms. Mary Gerbus  
The Pines Park, Inc.  
11779 Stone Mill Road  
Cincinnati, Ohio 45251

**RE: Butler County, The Pines MHP, NPDES Permit Violations**

Dear Ms. Gerbus:

We have reviewed your Discharge Monitoring Reports (DMRs) covering the months of February through May 2012 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit (NPDES Permit # OH0127329; OEPA Permit # 1PV00107\*CD). The specific instances of noncompliance and deficiencies were as follows:

**Effluent Limit Violations for February through May 2012**

Reporting Period	Parameter	Limit Type	Units	Permit Limit	Reported Value
May 2012	E. coli	Monthly	#/100ml	284	370
May 2012	E. coli	Weekly	#/100ml	126	370


Please be advised that failure to comply with the effluent limitations, or to satisfy the reporting requirements of your NPDES permit, may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, by July 13, 2012 as to the reasons for the above-referenced violations, as well as a description of the actions, taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions. Future violations must be reported as required by the NPDES permit as detailed in Part III.12 titled "Noncompliance Notification."

Ms. Mary Gerbus  
The Pines Park, Inc.  
July 2, 2012  
Page 2

If you have any questions regarding the above, please contact me at (937) 285-6096.

Sincerely,



Ned Sarle  
Environmental Specialist  
Division of Surface Water  
Permit Section

ec: Eric Gibson, Winelco, Inc.

NS/ca