



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Lucas County
Wynn Road Sanitary Sewer
Improvements
Construction
Storm Water

July 2, 2012

Mr. Dick Moses
Moses Schlachter Group
2780 Centennial Road
Toledo, Ohio 43617

Dear Mr. Moses:

On June 19, 2012, I inspected Wynn Road Sanitary Sewer Improvements located on the east side of Wynn Road, south of Seaman Road, Oregon. The purpose of the visit was to evaluate compliance of the site with the National Pollutant Discharge Elimination System (NPDES) general permit for storm water discharges associated with construction activity, Facility ID No. 2GC01295. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111.

The sanitary sewer line, which serves Eden Park Subdivision, is complete. A Notice of Termination (NOT) must be filed to relieve you of the obligation to comply with this general permit. An NOT may be filed if one or more of the following conditions have been met:


- Final stabilization has been established on all areas of the site for which the permittee is responsible. Final stabilization means that either:
 1. All soil disturbing activities at the site are complete and a uniform perennial vegetative cover of at least 70% density has been established over the entire site. All temporary erosion and sediment control measures have been removed, properly disposed of, and all trapped sediment has been permanently stabilized; or,
 2. For construction projects on land used for agricultural purposes, final stabilization may be accomplished by returning the disturbed land to its pre-construction agricultural use. If not returned to its pre-construction agricultural use, the land must meet the final stabilization criteria above.
- Another operator(s) has assumed control over all areas of the site that have not been fully stabilized.

Mr. Dick Moses
July 2, 2012
Page Two

If your site meets the above criteria, please file the NOT form. The NOT form and instructions can be found on our website: <http://www.epa.ohio.gov/dsw/storm/stormform.aspx>. Completed NOT forms must be mailed to Ohio EPA's Central Office within 45 days of when the above criteria are met.

If there are any questions, please contact me at (419) 373-3009.

Sincerely,



Lynette Hablitzel, P.E.
Division of Surface Water
Storm Water Program

/jlm

cc: Paul Roman, P.E., Director of Public Service, City of Oregon
Tracking