



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

Re: Lucas County  
Luther Home of Mercy  
Community Activity Center  
Construction  
Storm Water

July 2, 2012

Mr. Kurt Dotson  
Dotson Company Inc.  
P.O. Box 2429  
Whitehouse, Ohio 43571

Dear Mr. Dotson:

On June 19, 2012, I inspected Luther Home of Mercy Community Activity Center located on the southeast corner of Corduroy and Stadium Roads, Oregon. The purpose of the visit was to evaluate compliance of the site with the National Pollutant Discharge Elimination System (NPDES) general permit for storm water discharges associated with construction activity, Facility ID No. 2GC02129. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111.

It appears that construction activities at Luther Home of Mercy Community Activity Center are complete. A finished building and paved parking areas were present. It appears that a small extended detention basin has been installed on the west side of the project to meet post construction storm water management requirements. A Notice of Termination (NOT) must be filed to relieve you of the obligation to comply with this general permit. An NOT may be filed if one or more of the following conditions have been met:

- Final stabilization has been established on all areas of the site for which the permittee is responsible. Final stabilization means that either:
  1. All soil disturbing activities at the site are complete and a uniform perennial vegetative cover of at least 70% density has been established over the entire site. All temporary erosion and sediment control measures have been removed, properly disposed of, and all trapped sediment has been permanently stabilized; or,
  2. For construction projects on land used for agricultural purposes, final stabilization may be accomplished by returning the disturbed land to its pre-construction agricultural use. If not returned to its pre-construction agricultural use, the land must meet the final stabilization criteria above.


Mr. Kurt Dotson  
July 2, 2012  
Page Two

- Another operator(s) has assumed control over all areas of the site that have not been fully stabilized.

If your site meets the above criteria, please file the NOT form. The NOT form and instructions can be found on our website: <http://www.epa.ohio.gov/dsw/storm/stormform.aspx>. Completed NOT forms must be mailed to Ohio EPA's Central Office within 45 days of when the above criteria are met.

If there are any questions, please contact me at (419) 373-3009.

Sincerely,



Lynette Hablitzel, P.E.  
Division of Surface Water  
Storm Water Program

/jlm

ec: Paul Roman, P.E., Director of Public Service, City of Oregon  
Tracking