



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: **Notice of Violation**
Lucas County
Nationwide Auto
Construction
Storm Water

July 3, 2012

Mr. Al Tawil
Nationwide Auto
2121 Woodville Road
Oregon, Ohio 43616

Dear Mr. Tawil:

On June 4, 2012, Lynette Hablitzel, Jessica Heitman, and I inspected the Nationwide Auto at 2121 Woodville Road, Oregon. The purpose of our visit was to evaluate compliance of the site with the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity, Facility ID No. 2GC03138. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. Our records indicate that there are no co-permittees on this project.

As a result of the inspection, I have the following comments:

1. At the time of inspection, machinery was demolishing a structure. It appeared that water from the fire hydrant was being used to minimize dust from the site. There was no evidence of a discharge from the site.
2. There was no sediment settling pond onsite. A catch basin was located down gradient on the south side of the site. Inlet protection had not been installed.

Permits Requires: Practices shall minimize sediment laden water entering active storm drain systems unless they drain to a sediment settling pond. *This is a violation of Part III.G.2.d.iv. of the permit.* I recommend that proper inlet protection be installed.

3. The grass by the hydrant was torn up. If this area is to be used as a vehicle/equipment access point, it must be stabilized with stone. *Please see Part III.G.2.g.ii. of the permit.*

Within 10 days of the date on this letter, please submit to this office a **written response** to the above comments. Your reply should describe the actions taken or proposed to prevent any future violations, including dates for the completion of the actions. Please describe how the post construction storm water management requirements will be met for this project. Your reply should include the type(s) of practices you are implementing and the basis for their design.

If there are any questions, please contact me at 419-373-3011.

Sincerely,

Bernard E. Weik
Division of Surface Water
Storm Water Program

/jlm

cc: Paul Roman, P.E., Director of Public Service, City of Oregon
Tracking

Northwest District Office
347 North Dunbridge Road
Bowling Green, OH 43402-9398

419 | 352 8461
419 | 352 8468 (fax)
www.epa.ohio.gov