



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

June 29, 2012

Mark Fullen
Newark City High School
314 Grandville Street
Newark, OH 43055

Re: Storm Water Inspection at Newark City High School

Dear Mr. Fullen:

This letter is written in follow-up to a construction storm water inspection I conducted at Newark City High School located at 314 Grandville Street on May 25, 2012. The purpose of the inspection was to evaluate compliance with the current storm water regulations pursuant to 40 CFR 122.26. During the inspection, I noted the following:

Permitting Requirements:

- This construction site appears to be greater than one acre and will require coverage (under 40 CFR 122.26) under the General Storm Water Permit Associated with Construction Activities. Please fill out the enclosed Notice of Intent (NOI) form and submit it to the address stated in the filing instruction, once your Storm Water Pollution Prevention Plan is completed, the NOI form is found at: http://www.epa.ohio.gov/portals/35/documents/NOI_form2_fis.pdf. Instructions concerning the form can be found at http://www.epa.ohio.gov/dsw/permits/gpfact.aspx#draft_general_permits.

Storm Water Pollution Prevention Plan (SWPPP):

- A SWPPP must be developed specific for this site. The plan must address all phases of construction and identify the location and sizing of all sediment and erosion controls. Schedules for temporary and permanent seeding must also be addressed in the SWPPP. This plan must be maintained on site for the agency to review. Be Aware Ohio EPA reserves the right to require modifications to the SWPPP if the minimum conditions of the General Storm Water Permit are not met.

•

Sediment and Erosion Controls:

- This site appears to be void of any sediment controls. The General Permit states that all sediment controls must be implemented prior to initial grading of the site. Please implement these controls immediately to ensure compliance with the General Storm Water Permit.

Post Construction Requirements:

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. In addition, please provide a written response (**email preferred**) to the action items addressed above within ten days from receipt of this letter. A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office