



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

June 28, 2012

Steve Peck  
Dominion Homes  
4900 Tuttle Crossing Boulevard  
Dublin, OH 43016

**Re: 4<sup>th</sup> Notice of Violation  
Big Run Ridge, Sec. 2, Franklin County  
Construction Storm Water Permit 4GC03526\*AG**

Dear Mr. Peck:

This letter is written in follow-up to a construction storm water inspection that I conducted on June 27, 2012, at Big Run Ridge, Sec. 2, located at 3974 Big Run Road South, in Grove City, Ohio. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. Please consider this your fourth formal notice of violation. If issues in this letter are not addressed, I will have no other option than to proceed with an enforcement referral. During the inspection, I noted the following issues associated with construction activities at this site:

**Sediment and Erosion Control:**

- I noted four new home construction sites and several barren lots. I noted sediment discharging to the streets. The active sites and barren lots did not have erosion controls.
- Please install and maintain silt fence around the perimeter of the active construction sites and barren lots. Please see attached pictures of a few of the sites.
- Please be aware that the General Permit states that all barren areas including soil stockpiles which remain idle in excess of 21 days must be protected from erosion within seven (7) days of the last earth disturbing activities.
- The general permit states that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. The weekly inspection log did not appear to be adequate at the site.

Steve Peck  
Dominion Homes  
Page 2

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3851 or email at [greg.sanders@epa.state.oh.us](mailto:greg.sanders@epa.state.oh.us).

Sincerely,

A handwritten signature in black ink, appearing to read 'G. Sanders', written in a cursive style.

Gregory L. Sanders  
Environmental Specialist  
Division of Surface Water  
Central District Office

Enclosure

cc: Gregory L. Sanders, DSW/CDO

GS/nsm Big Run Ridge, Sec. 2, June 27, 2012

