



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

June 29, 2012

Numan Babieh
ODOT District 5
9600 Jacksontown Road
Southeast Jacksontown, OH 43030

**Re: Storm Water Inspection at Kirkersville
Permit #: 4GC03667*AG**

Dear Mr. Babieh:

This letter is written in follow up to a construction storm water inspection I conducted at LIC-158-0.58 (PID 84700) PID – 84700 located at IR 70 & SR 158 Interchange in Kirkersville, Ohio on June 4 and 26, 2012. The purpose of the inspection was to evaluate compliance with Ohio EPA's General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following:

Sediment and Erosion Controls

- Perimeter controls were effectively implemented for this site in accordance with Ohio EPA's General Storm Water Permit.
- Reinforced inlet protection was noted for all drop catch basin storm water inlets.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.
- All areas requiring temporary and/or permanent stabilization were addresses concurrent with my June 26, 2012 inspection.

Post Construction Requirements:

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

Numan Babieh
ODOT District 5
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met. Ohio EPA appreciates the attention to detail regarding Effective Sediment and Erosion Control Implementation for this site.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office