



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

June 29, 2012

Daniel Peloquin
Maverick Companies
4975 Centre Pointe Drive #300
North Charleston, SC 29418

**Re: Storm Water Inspection at Dollar Tree- Newark – Licking County
Permit # 4GC03815*AG**

Dear Mr. Peloquin:

This letter is written in follow-up to a construction storm water inspection by Brittany Turner, and Abigail Tamkin of the Ohio EPA, at Dollar Tree-Newark located at 1003-1009 Mount Vernon Road, West side SR 13 (MT Vernon Road) North of English Ave on June 22, 2012. The purpose of the inspection was to evaluate compliance with Ohio EPA's General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

Sediment and Erosion Controls:

- The sediment and erosion controls at this site are currently functioning properly. Please continue to monitor and ensure continued compliance with the General Storm Water Permit Associated with Construction Activities.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

Post Construction Requirements:

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at:
<http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

Daniel Peloquin
Maverick Companies
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,

A handwritten signature in black ink, appearing to read "Harry Kallipolitis". The signature is written in a cursive style with a large initial "H".

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

HK/nsm Dollar Tree-Newark Licking County 6-28-2012