



July 2, 2012

Mr. Robert Leventry
Butler County Environmental Services
130 High Street
Hamilton, Ohio 45069

RE: Butler County, Upper Mill Creek WWTP, NPDES Permit Violations

Dear Mr. Leventry:

We have received your Discharge Monitoring Reports covering the month of May 2012 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit (NPDES Permit # OH0072087; OEPA Permit # 1PK00016*LD). The specific instances of noncompliance are as follows:

Effluent Limit Violations for May 2012

Reporting Period	Parameter	Limit Type	Units	Permit Limit	Reported Value
May 2012	Phosphorus	Monthly	mg/l	1.0	1.1
May 2012	Phosphorus	Weekly	mg/l	1.5	2.2
May 2012	TSS	Weekly	mg/l	18	25
May 2012	TSS	Weekly	mg/l	1090.1	2022.5
May 2012	E. coli	Weekly	#/100ml	362	"AK"

Please be advised that failure to comply with the effluent limitations of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code Chapter 6111.

We have reviewed your report addressing the reasons for the above violations and the actions being taken to prevent further occurrences. No additional information is requested at this time. Future violations must continue to be reported as required by the NPDES permit as detailed in Part III.12 titled "Noncompliance Notification."

Mr. Robert Leventry
July 2, 2012
Page 2

If you have any questions regarding the above, please contact me at (937) 285-6096.

Sincerely,

A handwritten signature in cursive script, appearing to read "Ned Sarle".

Ned Sarle
Environmental Specialist
Division of Surface Water
Permit Section

NS/tf

cc: Brian Custer, Butler County Water and Sewer Department