



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

July 9, 2012

Lisa Dobberstein
DiYanni Homes
1537 Brice Road
Reynoldsburg, OH 43068

**Re: Rolling Acres / Fairfield County
General Storm Water Construction Permit #4GC00344**

Dear Ms. Dobberstein:

This letter is written regarding the storm water inspection that I conducted at Rolling Acres, located along Elder Road, in the Village of Lithopolis, Ohio, on July 5, 2012. I understand that these construction activities are covered under the General Storm Water Permit Associated with Construction Activities. Based on my site inspection and the General Storm Water Permit, the following items must be addressed:

Sediment and Erosion Controls:

There is one active home site under construction located at 699 Rolling Acres Drive. Erosion controls were installed on the west and south boundary of the site, however, they also need to be installed on the eastern boundary as well. Please install erosion controls such as silt fence or straw wattles along the eastern boundary of the active construction site.

Please maintain erosions controls at the site including the concrete wash-out pit.

Please be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.


There was a barren lot located on the north side of the development that will need to be re-seeded.

If any of the lots were sold to another developer, it is the responsibility of the permit holder to insure that the new owner of the lot applies for a lot notice of intent.

Lisa Dobberstein
DiYanni Homes
Page 2

If you have any questions regarding this letter or my inspection, please do not hesitate to call me at our Central District Office at (614) 728-3851.

Sincerely,

A handwritten signature in black ink, appearing to read 'G. Sanders', written in a cursive style.

Gregory L. Sanders
Storm Water Unit
Division of Surface Water
Central District Office

ec: Greg Sanders, DSW/CDO

GS/nsm Rolling Acres, July 5, 2012