



**Environmental
Protection Agency**

John R. Kasich, Governor

Mary Taylor, Lt. Governor

Scott J. Nally, Director

July 5, 2012

RE: CUYAHOGA COUNTY
CITY OF CLEVELAND
HOGSBACK LANE SLOPE STABILIZATION
CONSTRUCTION STORM WATER
PERMIT NO: 3GC05918

Mr. Richard J. Kerber
Cleveland Metroparks
4101 Fulton Parkway
Cleveland, OH 44144

Mr. Richard J. Switalski
City of Cleveland Division of Engineering & Construction
601 Lakeside Avenue, Room 518
Cleveland, OH 44114

Dear Mr. Kerber and Mr. Switalski:

On June 20, 2012, I performed a compliance inspection for storm water best management practices (BMPs) at the above referenced site. Our records indicate that the Cleveland Metroparks has obtained coverage under the Ohio EPA General Storm Water National Pollutant Discharge Elimination System (NPDES) Permit for Construction Activities #3GC05918*AG on April 12, 2012.

It appears that construction activities are complete and the site has been stabilized. Please be aware that NPDES permit coverage must be terminated within 45 days of when the site reaches final stabilization. Final stabilization means that either:

1. All soil disturbing activities at the site are complete and a uniform perennial vegetative cover (i.e., evenly distributed, without large bare areas) has reached a growth density of 70% or greater on all unpaved areas and areas not covered by permanent structures. Equivalent stabilization measures such as the use of landscape mulches, rip-rap or gabions may be employed, where appropriate, in lieu of vegetation. In addition, all temporary erosion and sediment control practices must be removed and disposed and all sediment trapped by these practices must be permanently stabilized; or
2. For individual lots in residential construction by either:
 - a. The homebuilder completing final stabilization as specified above; or
 - b. The homebuilder establishing temporary stabilization, including perimeter controls, for an individual lot prior to occupation of the home by the homeowner and informing the homeowner of the need for and benefits of final stabilization.

Please review your site to determine if it has reached final stabilization and ensure that post-construction BMPs have been installed. If you determine that your site has reached final stabilization, you must submit a Notice of Termination (NOT) to Ohio EPA to terminate NPDES permit coverage. The form and instructions are available on our website at

HOGSBACK LANE SLOPE STABILIZATION
JULY 5, 2012
PAGE 2 OF 2

www.epa.ohio.gov/dsw/storm/stormform.aspx. If you determine that your site does not yet qualify for an NOT, please provide me with a letter of explanation indicating why NPDES permit coverage cannot yet be terminated. Please submit the NOT or letter of explanation no later than July 19, 2012.

If you have any questions, please contact me at (330) 963-1125 or by e-mail at Katie.Bowman@epa.state.oh.us

Sincerely,



Katie Bowman
Assistant to the District Engineer
Division of Surface Water

KB/cs

cc: Shannon Millins, Cuyahoga SWCD
Frank G. Jackson, Mayor, City of Cleveland