



**Environmental
Protection Agency**

John R. Kasich, Governor

Mary Taylor, Lt. Governor

Scott J. Nally, Director

July 9, 2012

RE: SUMMIT COUNTY
CITY OF CUYAHOGA FALLS
WAYSIDE FARM NURSING HOME
4557 QUICK ROAD
COMPLIANCE EVALUATION INSPECTION/
NOTICE OF VIOLATION
OHIO EPA PERMIT NO. 3PR00530

Wayside Farm Nursing Home
c/o Judith Loving Tr
Attn: Ms. Rebecca Pool
4557 Quick Road
Peninsula, OH 44264

Dear Ms. Pool:

On June 29, 2012, this office conducted a Compliance Evaluation Inspection at the wastewater treatment plant (WWTP) serving Wayside Farm Nursing Home. The inspection was prompted by a "failed" inspection report from the Summit County Health Department. At the health department's June 27, 2012 inspection, the WWTP was found to be shut off and discharging raw sewage.

According to our files, the existing wastewater treatment system consists of a 3500-gallon trash trap and a 15,000-gpd extended aeration treatment plant. The plant discharges to an unnamed tributary of Dickerson Run via an on-site pond overflow. This office is in the process of reviewing the permit-to-install (PTI) for the proposed WWTP upgrade. According to the compliance schedule in your NPDES permit, construction of the upgrade shall be completed by September 2012.

During this office's recent inspection, it was learned that the blower motor had broken down. A new blower motor had been installed the day before my inspection. The treatment plant was extremely septic and odorous, but should improve within a few days.

Review of the electronic Discharge Monitoring Reports (eDMRs) reported for your facility from March 1, 2011 through June 2012, revealed the following effluent violations:

Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
August 2011	Total Suspended Solids	30D Qty	0.85	.94474	8/1/2011
August 2011	Dissolved Oxygen	1D Conc	6.0	5.9	8/17/2011
December 2011	Total Suspended Solids	30D Conc	30	90.	12/1/2011
December 2011	Total Suspended Solids	7D Conc	45	90.	12/1/2011
December 2011	Total Suspended Solids	30D Qly	0.85	2.65707	12/1/2011
December 2011	Total Suspended Solids	7D Qty	1.3	2.65707	12/1/2011
December 2011	CBOD 5 day	30D Conc	25	77.	12/1/2011
December 2011	CBOD 5 day	7D Conc	37.5	77.	12/1/2011

WAYSIDE FARM NURSING HOME
JULY 9, 2012
PAGE 2 OF 2

December 2011	CBOD 5 day	30D Qty	0.71	2.27327	12/1/2011
December 2011	CBOD 5 day	7D Qty	1.07	2.27327	12/1/2011
March 2012	Total Suspended Solids	30D Conc	30	323.	3/1/2012
March 2012	Total Suspended Solids	30D Qty	0.85	7.62874	3/1/2012
March 2012	CBOD 5 day	30D Conc	25	86.	3/1/2012
March 2012	CBOD 5 day	30D Qty	0.71	2.03118	3/1/2012
March 2012	Total Suspended Solids	7D Conc	45	323.	3/8/2012
March 2012	Total Suspended Solids	7D Qty	1.3	7.62874	3/8/2012
March 2012	CBOD 5 day	7D Conc	37.5	86.	3/8/2012
March 2012	CBOD 5 day	7D Qty	1.07	2.03118	3/8/2012
March 2012	Dissolved Oxygen	1D Conc	6.0	4.	3/14/2012

Please be advised such instances of non-compliance are subject to enforcement pursuant to Ohio Revised Code (ORC) 6111. It is assumed that all effluent violations will cease with the completion of the treatment plant upgrade.

If you have any questions, please contact this office at (330) 963-1151.

Sincerely,



Jennifer S. Bennage
Environmental Engineer
Division of Surface Water

JSB/cs

ec: Tom LaPlante, Summit County Health Department