



**Environmental  
Protection Agency**

**John R. Kasich, Governor**

**Mary Taylor, Lt. Governor**

**Scott J. Nally, Director**

July 12, 2012

RE: SUMMIT  
CITY OF TWINSBURG  
SHEETZ  
CONSTRUCTION STORM WATER  
PERMIT NO: 3GC00993

Mr. Errin Hensley  
GPD Group  
520 South Main Street  
Akron, OH 44311

Dear Mr. Hensley:

On July 10, 2012, I performed an inspection at the above-referenced site to determine compliance with the Ohio EPA General Storm Water National Pollutant Discharge Elimination System (NPDES) Permit for Construction Activities #3GC00993\*AG. Our records indicate that the GPD Group was granted coverage under the NPDES permit on July 27, 2004.

It appears that construction activities are complete and the site has been stabilized. Please be aware that NPDES permit coverage must be terminated within 45 days of when the site reaches final stabilization. Final stabilization means that all soil disturbing activities at the site are complete and a uniform perennial vegetative cover (i.e., evenly distributed, without large bare areas) has reached a growth density of 70% or greater on all unpaved areas and areas not covered by permanent structures. Equivalent stabilization measures such as the use of landscape mulches, rip-rap or gabions may be employed, where appropriate, in lieu of vegetation. In addition, all temporary erosion and sediment control practices must be removed and disposed and all sediment trapped by these practices must be permanently stabilized

In addition, before NPDES permit coverage can be terminated, post-construction water quality best management practices (post-construction BMPs) must be installed and a long-term maintenance plan must be provided to the party that will be responsible for long-term maintenance of those practices, e.g., homeowners' association. Post-construction BMPs are permanent site features that will remain in perpetuity to improve the quality of storm water runoff from the development site. Examples of post-construction BMPs include, but are not limited to, extended detention basins, bioretention cells (or "rain gardens"), sand filters, permeable pavement and enhanced swales. In some cases, post-construction BMPs include non-structural preservation areas such as riparian setbacks and conservation easements.

Please review your site to determine if it has reached final stabilization and ensure that post-construction BMPs have been installed. If you determine that your site has reached final stabilization, you must submit a Notice of Termination (NOT) to Ohio EPA to terminate NPDES permit coverage. The form and instructions are available on our website at [www.epa.ohio.gov/dsw/storm/stormform.aspx](http://www.epa.ohio.gov/dsw/storm/stormform.aspx). If you determine that your site does not yet qualify for an NOT, please provide me with a letter of explanation indicating why NPDES permit

SHEETZ  
JULY 12, 2012  
PAGE 2 OF 2

coverage cannot yet be terminated. Please submit the NOT or letter of explanation **no later than July 26, 2012.**

If you have any questions, please contact me at (330) 963-1145 or by e-mail at [Katie.Bowman@epa.state.oh.us](mailto:Katie.Bowman@epa.state.oh.us).

Sincerely,



Katie Bowman  
Assistant to the District Engineer  
Division of Surface Water

KB/cs

Cc: Amy L. Mohr, Engineer, City of Twinsburg  
Katherine Procop, Mayor, City of Twinsburg  
Brian Prunty, Summit SWCD