



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

July 12, 2012

Fischer Homes
570 Polaris Parkway
Suite 125
Westerville, OH 43082

Re: Alum Creek Village, Franklin County

To Whom it May Concern:

This letter is written in response to my storm water inspection on July 9, 2012, of the construction activities associated with Alum Creek Village, located along Alum Creek Drive, in Franklin County. Based on my site observations of the site and the conditions of the Storm Water Permit, the following items were noted.

Sediment and Erosion Controls:

1. There were approximately four barren lots and no active construction. There were no erosion controls around the perimeter of the barren lots. Please install erosion controls around the perimeter of the barren lots and stabilize the barren areas. Please see attached pictures.
2. I noted that there was a concrete wash-out pit at the site. However, it needed to be maintained. Please inspect erosion controls weekly and after significant rain events.

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844.

Sincerely,

Gregory L. Sanders
Storm Water Unit
Division of Surface Water
Central District Office

Enclosure

ec: Greg Sanders, DSW/CDO

GS/nsm Alum Creek Village, July 9, 2012

