



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

July 12, 2012

Denny Taylor
800 Martinsburg Road
Mount Vernon, OH 43050

**Re: Storm Water Inspection at Mount Vernon Nazarene University Athletic Center
Permit Number: 4GC03812AG**

Dear Mr. Taylor:

This letter is written in follow up to a construction storm water inspection by Alicia Rector and Abigail Tamkin of the Ohio EPA, at Mount Vernon Nazarene University Athletic Center located at Mount Vernon, Ohio on June 28, 2012. The purpose of the inspection was to evaluate compliance with Ohio EPA's General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

Sediment and Erosion Controls:

- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days. This specifically applies to the areas noted in figure 1.
- Our staff noted the site was void of sediment and erosion controls as noted in figure 2. Sediment controls for this project must be implemented in accordance with the General Storm Water Permit. Silt fencing must be implemented along the contour and control areas where sheet flow is present. The silt fence must be trenched in otherwise proper reinstallation will be required. Sediment traps must be utilized for areas of concentrated flow and must be sized with a required sediment storage volume per the General Permit). These sediment impoundments will require cleaning once they have exceeded 50 percent of their capacity.


Post Construction Requirements:

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

Denny Taylor
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,

A handwritten signature in black ink, appearing to read 'Harry Kallipolitis', written over a faint, illegible printed name.

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office



Figure 1: Barren areas in need of erosion protection



Figure 2: Appears to be void of silt fence