



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

July 11, 2012

William Buescher  
Columbus Metro Parks  
1069 W. Main Street  
Westerville, Ohio 43081

**Re: Storm Water Inspection at Heritage Trail Park-Dog Park- Franklin County  
Permit # 4GC03825\*AG**

Dear Mr. Buescher,

This letter is written in follow up to a construction storm water inspection by Brittany Turner, and Alicia Rector of the Ohio EPA, at Heritage Trail Park-Dog Park located at Hayden Run Road West of Cosgray Road on July 2, 2012. The purpose of the inspection was to evaluate compliance with Ohio EPA General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

**Sediment and Erosion Controls:**

- This site appears to be void of any sediment controls. The General Permit states that all sediment controls must be implemented prior to initial grading of the site. Please implement these controls immediately to ensure compliance with the General Storm Water Permit (Figure 1).
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days (Figure 2).

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Clyde "Butch" Seidle, P.E

HK/nsm Heritage Trail Park -- Dog Park Franklin county 7-5-2012




Figure 1: Void of any Sediment Controls




Figure 2: Barren Areas