



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

July 11, 2012

Aaron Stanford, PE
City of Dublin
5800 Shier-Rings Road
Dublin, Ohio 43016

**Re: Notice of Termination Inspection at - Fishel Drive at Cosgary Road
Permit # 4GC03854*AG**

Dear Mr. Stanford:

This letter is written in follow-up to a construction storm water inspection by Brittany Turner, and Alicia Rector of the Ohio EPA, we conducted at Fishel Drive 8-Inch Water Main Extension located at Fishel Drive at Cosgray Road on July 2, 2012. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

It appeared during the inspection that construction activity has been completed for this site. A Notice of Termination will be required provided the following measures are addressed:

- A Notice of Termination (NOT) must be submitted once vegetation is established to control erosion measured by a minimum density of 70 percent. The NOT form and filing instructions can be found at:
- <http://www.epa.state.oh.us/dsw/storm/stormform.aspx>.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844.

Sincerely

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

HK/nsm Fishel Drive 8in.water main extension Franklin county 7-2-2012

Central District Office
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 728 3778
614 | 728 3898 (fax)
www.epa.ohio.gov