Ohio | Environmental Protection Agency
John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

July 13, 2012

Re: Coshocton County
Coshocton Readiness Center
Storm Water Construction Activity
0GC00076*AG

Mr. Vince Hartzler
Bogner Construction Company
P.O. Box 887
Wooster, Ohio 44691

Dear Mr. Hartzler:

On July 9, 2012, I visited the Coshocton Readiness Center in Coshocton, Ohio. The purpose of the inspection was to determine the compliance of this site with the National Pollutant Discharge Elimination System (NPDES) permit for discharges of storm water associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statues, Ohio Revised Code (ORC) Chapter 6111.

At the time of the inspection, the site was inactive and it appeared that construction activities had been completed. In accordance with the NPDES permit, a Notice of Termination (NOT) must be submitted to the Ohio Environmental Protection Agency (Ohio EPA) to release you from the terms and conditions of this permit.

An NOT may be submitted to Ohio EPA if the following requirements have been fulfilled:

1. A perennial vegetative cover (or equivalent means of stabilization) has been established over 100% of the surface area disturbed during construction. The vegetative growth must be at a growth density of 70%.

2. All temporary sediment and erosion controls have been removed and properly disposed.

3. All sediment has been permanently stabilized to prevent further erosion.

4. Construction activity at the site has ceased.

Southeast District Office
2195 Front Street
Logan, OH 43138-8637

740 | 385 8501
740 | 385 6490 (fax)
www.epa.ohio.gov

It appears that your site meets the above criteria. If you agree, please submit an NOT within 45 days of the completion of construction activities. Failure to submit an NOT is a violation of the permit requirements and may affect your ability to obtain a NPDES permit in the future.

Please send the completed NOT to the following address:

Ohio Environmental Protection Agency
Division of Surface Water
Storm Water Section
P.O. Box 1049
Columbus, Ohio 43216-1049

If there are any questions, please contact me at (740) 380-5447 or Aaron Wolfe at (740) 380-5277.

Sincerely,

Sara J Peters

Sara Peters
Storm Water Section
Division of Surface Water

SP/dh

Enclosure: Notice of Termination