



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

July 16, 2012

**Re:** Noble County  
Caldwell WWTP  
Notice of Significant Non-Compliance  
OPB00005; OH0127728  
Correspondence (PWW)

Mayor and Council  
Village of Caldwell  
Railroad Street  
Caldwell, Ohio 43724

Dear Mayor and Council:

We have reviewed your self-monitoring reports covering the months of October 2011 through March 2012 for the Caldwell wastewater treatment facility. The facility was in significant non-compliance (SNC) with its total suspended solids limits (see attachment). Attached is a document explaining significant non-compliance.

A notice of violation letter for the exceedances was sent dated May 4, 2012. In a phone conversation on May 8, 2012 with Superintendent Arthur Schockling indicated that they will be having the flow meter recalibrated and will review lab procedures in response to the exceedances.

Within thirty (30) days of receipt of this letter please provide a response as to the progress of recalibrating the flow meter and reviewing the lab procedures. Please be advised that failure to take action to return to compliance will be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111.

If there are any questions, please contact me at (740) 380-5418.

Sincerely,

Tim Fulks  
District Representative  
Division of Surface Water

TF/dh

c: Mr. Arthur Schockling, Superintendent, Village of Caldwell

Facility	Report Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
Caldwell WWTP	Nov 2011	001	00300	Dissolved Oxygen	1D Conc	5.5	.52	11/18/2011
Caldwell WWTP	Oct 2011	001	00530	Total Suspended Sol	30D Qty	42.4	56.9183	10/1/2011
Caldwell WWTP	Oct 2011	001	00530	Total Suspended Sol	7D Qty	63.6	75.4539	10/15/2011
Caldwell WWTP	Oct 2011	001	00530	Total Suspended Sol	7D Qty	63.6	74.9146	10/22/2011
Caldwell WWTP	Nov 2011	001	00530	Total Suspended Sol	30D Qty	42.4	59.7192	11/1/2011
Caldwell WWTP	Nov 2011	001	00530	Total Suspended Sol	7D Conc	21	24.	11/22/2011
Caldwell WWTP	Nov 2011	001	00530	Total Suspended Sol	7D Qty	63.6	165.219	11/22/2011
Caldwell WWTP	Dec 2011	001	00530	Total Suspended Sol	30D Qty	42.4	47.9857	12/1/2011
Caldwell WWTP	Dec 2011	001	00530	Total Suspended Sol	7D Qty	63.6	66.3321	12/22/2011
Caldwell WWTP	Jan 2012	001	00530	Total Suspended Sol	30D Qty	42.4	51.7527	1/1/2012
Caldwell WWTP	Jan 2012	001	00530	Total Suspended Sol	7D Conc	21	31.	1/1/2012
Caldwell WWTP	Jan 2012	001	00530	Total Suspended Sol	30D Conc	14	16.5	1/1/2012
Caldwell WWTP	Jan 2012	001	00530	Total Suspended Sol	7D Qty	63.6	71.5308	1/1/2012