



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

July 17, 2012

**Re:** Guernsey County  
ODOT Rest Area 5-30  
Notice of Significant Non-Compliance  
OPP00058; OH0076929  
Correspondence (PWW)

Mr. Terry Gregg, Operator  
ODOT, District 5  
P.O. Box 306  
Jacksontown, Ohio 43030

Dear Mr. Gregg:

We have reviewed your self-monitoring reports covering the months of October 2011 through March 2012 for the ODOT Rest Area #5-30. The facility was in significant non-compliance (SNC) with its nitrogen ammonia limits during the months of January and February 2012 (see attachment). Attached is a document explaining significant non-compliance.

In a notice of violation letter dated May 4, 2012, you were notified of the violations and a response for the reasons for the violations was requested within ten (10) days of receipt of the letter. To date, this office has yet to receive a response. Please submit in writing the reasons for the violations, actions taken to correct the issues and what will be done to prevent future violations within ten (10) days of receipt of this letter. I will be contacting you in the near future to set up a compliance enforcement inspection at the facility.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at (740) 380-5418.

Sincerely,

Tim Fulks  
District Representative  
Division of Surface Water

TF/dh

Enclosure

Report Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
Jan 2012	001	00610	Nitrogen, Ammonia	30D Conc	4.0	5.8415	1/1/2012
Jan 2012	001	00610	Nitrogen, Ammonia	7D Conc	6.0	11.4	1/1/2012
Feb 2012	001	00610	Nitrogen, Ammonia	30D Conc	4.0	14.44	2/1/2012
Feb 2012	001	00610	Nitrogen, Ammonia	7D Conc	6.0	7.4	2/1/2012
Feb 2012	001	00610	Nitrogen, Ammonia	7D Conc	6.0	6.32	2/8/2012
Feb 2012	001	00610	Nitrogen, Ammonia	7D Conc	6.0	29.6	2/22/2012