



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Mercer County
Lake Campus Development LLC
Construction
Storm Water

July 12, 2012

Mr. Gary Niekamp
HA Dorsten Inc.
220 West Livingston Street Room A201
Celina, Ohio 45822

Mr. Kyle Vantiburg
VTF Excavation LLC
8398 Celina-Mendon Road
Celina, Ohio 45822

Dear Messrs. Niekamp and Vantiburg:

On June 21, 2012, Jessica Heitman and I inspected Lake Campus Development LLC located at 576000 State Route 703, Celina. The purpose of our visit was to evaluate compliance of the site with the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity, Facility ID No. 2GC02841. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111.

It appears that construction activities at the Lake Campus Development LLC are complete. A finished building, paved drives, and paved parking areas were present.

A Notice of Termination (NOT) must be filed to relieve you of the obligation to comply with this general permit. An NOT may be filed if one or more of the following conditions have been met:

- Final stabilization has been established on all areas of the site for which the permittee is responsible. Final stabilization means that all soil disturbing activities at the site are complete and a uniform perennial vegetative cover of at least 70% density has been established over the entire site. All temporary erosion and sediment control measures have been removed, properly disposed of, and all trapped sediment has been permanently stabilized; or
- Another operator(s) has assumed control over all areas of the site that have not been fully stabilized.

Messrs. Niekamp and Vantiburg
July 12, 2012
Page Two

Your site does not yet appear to meet all of the conditions mentioned above. Once a 70% density of perennial vegetation has been reached on all disturbed ground, you may remove temporary sediment controls and file the NOT form. The NOT form and instructions can be found on our website: <http://www.epa.ohio.gov/dsw/storm/stormform.aspx>. NOTs must be mailed to Ohio EPA's Central Office within 45 days of when the above criteria are met.

Within 10 days of the date on this letter, please submit to this office **written notification** as to the actions taken or proposed to prevent any future violations. Your response should include the dates, either actual or proposed, for the completion of the actions.

If there are any questions, please contact me at (419) 373-3011.

Sincerely,



Bernard Weik
Division of Surface Water
Storm Water Program

/jlm

ec: Kent Bryan, Celina Engineer
Tracking