



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Hardin County
Liberty Baptist Church
Construction
Stormwater

July 12, 2012

Mr. Dave Drake, Treasurer
Liberty Baptist Church
2955 County Road 20
Ada, Ohio 45810

Dear Mr. Drake:

On June 5, 2012, Jessica Heitman and I inspected Liberty Baptist Church located at 2955 County Road 20, Liberty Township, Hardin County. The purpose of our visit was to evaluate compliance of the site with the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity, Facility ID No. 2GC02935. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. No one was present at the time of the inspection to provide information on the project, and our records show that there are no co-permittees.

It appears that construction activities at the Liberty Baptist Church are complete.

A Notice of Termination (NOT) must be filed to relieve you of the obligation to comply with this general permit. An NOT may be filed if one or more of the following conditions have been met:

- Final stabilization has been established on all areas of the site for which the permittee is responsible. Final stabilization means that all soil disturbing activities at the site are complete and a uniform perennial vegetative cover of at least 70% density has been established over the entire site. All temporary erosion and sediment control measures have been removed, properly disposed of, and all trapped sediment has been permanently stabilized; or
- Another operator(s) has assumed control over all areas of the site that have not been fully stabilized.

Your site does not yet appear to meet all of the conditions mentioned above. The site, although seeded and mulched, has not yet reached 70% density of perennial vegetation. Once a 70% density of perennial vegetation has been reached on all disturbed ground, you may remove temporary sediment controls. Once all permit conditions have been met and post construction storm water management facilities have been installed, please file the NOT form. The NOT form and instructions can be found at <http://www.epa.ohio.gov/dsw/storm/stormform.aspx>. NOTs must be mailed to Ohio EPA's Central Office within 45 days of when the above criteria are met.

If there are any questions, please contact me at 419-373-3011.

Sincerely,

Bernard E. Weik
Division of Surface Water
Storm Water Program

/jlm

ec: Mark Seger, Hardin County Conservation Engineer
Tracking

Northwest District Office
347 North Dunbridge Road
Bowling Green, OH 43402-9398

419 | 352 8461
419 | 352 8468 (fax)
www.epa.ohio.gov