



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

July 19, 2012

**RE: CUYAHOGA COUNTY
MAYFIELD VILLAGE
CUYAHOGA CO PUBLIC LIBRARY
MAYFIELD BRANCH
CONSTRUCTION STORM WATER
PERMIT NO: 3GC05882**

Mr. William Rubin
Cuyahoga County Public Library
2111 Snow Road
Parma, OH 44134

Dear Mr. Rubin:

On July 3, 2012, I performed a compliance inspection for storm water best management practices (BMPs) at the above referenced site. I was accompanied by Tom Cappelo, Engineer with Stephen Hovancsek & Associates. While on site we met the following representatives of Infinity Construction: Justin Thenn, Project Engineer and Mark Vega, Project Manager. Our records indicate that the Cuyahoga County Public Library has obtained coverage under the Ohio EPA General Storm Water National Pollutant Discharge Elimination System (NPDES) Permit for Construction Activities #3GC05882*AG.

After review of the site and the Storm Water Pollution Prevention Plan (SWP3), I noted that a temporary sediment pond with a skimmer device will be installed, as well as silt fencing, two rock construction entrances, and a concrete washout pit. One construction entrance, the concrete washout pit, and perimeter and stock pile silt fencing are currently in place and in good condition. I was informed by Mark Vega that the site is in its initial stage of construction. However, as per the NPDES permit for Construction Activities "Sediment basins and perimeter sediment barriers shall be implemented prior to grading and within seven days from the start of grubbing." The sediment basin should be installed immediately, not during the intermediate phase as shown in the SWP3.

You are directed to provide me with a letter of response indicating the actions that you have taken or will take to address the deficiencies noted above. Include any amendments to the SWP3 with your response. Your response must be received **no later than August 1, 2012**. Failure to comply with the NPDES permit is a violation of Ohio Revised Code 6111.04 and 6111.07 and is punishable by fines.

If you have any questions, please contact me at (330) 963-1125 or by e-mail at Katie.Bowman@epa.state.oh.us.

Sincerely,

Katie Bowman
Assistant to the District Engineer
Division of Surface Water

KB/cl

cc: Tom Cappelo, Engineer, Stephen Hovancsek & Associates
Todd Houser, Cuyahoga SWCD
Bruce G. Rinker, Mayor, Mayfield Village