



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

July 19, 2012

**RE: CUYAHOGA COUNTY  
CITY OF SOUTH EUCLID  
ARGONNE ROAD PHASE 2  
INFRASTRUCTURE IMPV PROJ  
CONSTRUCTION STORM WATER  
PERMIT NO: 3GC05907**

Mr. Andrew K. Blackley  
City of South Euclid  
1349 South Green Road  
South Euclid, OH 44121

Dear Mr. Blackley:

On July 3, 2012, I performed a compliance inspection for storm water best management practices (BMPs) at the above referenced site. While on site I met Randall Butler, Superintendent with Trax. Our records indicate that the City of South Euclid has obtained coverage under the Ohio EPA General Storm Water National Pollutant Discharge Elimination System (NPDES) Permit for Construction Activities #3GC05907\*AG.

After review of the site, I noted that catch basin inlet protection had been installed and was ponding water well. Since it was raining while I conducted this inspection, I would expect the catch basins' inlet protection need to be cleaned out. Continue your weekly inspections to ensure proper functioning of the inlet protection.

If you have any questions, please contact me at (330) 963-1125 or by e-mail at [Katie.Bowman@epa.state.oh.us](mailto:Katie.Bowman@epa.state.oh.us).

Sincerely,

Katie Bowman  
Assistant to the District Engineer  
Division of Surface Water

KB/cl

cc: Todd Houser, Cuyahoga SWCD  
Georgine Welo, Mayor, City of South Euclid