



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

July 20, 2012

**Re:** Perry County  
ODOT PID 23544  
Storm Water Construction Activity  
0GC00216\*AG

Ms. Margaret Hatem  
ODOT District 5  
9600 Jacksontown Road SE  
Jacksontown, Ohio 43030

Dear Ms. Hatem:

On July 9, 2012, I visited PID 23544 in Crooksville Ohio. The purpose of the inspection was to determine the compliance of this site with the National Pollutant Discharge Elimination System (NPDES) permit for discharges of storm water associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statues, Ohio Revised Code (ORC) Chapter 6111.

At the time of the inspection, the site was inactive and it appeared that construction activities had been completed. In accordance with the NPDES permit, a Notice of Termination (NOT) must be submitted to the Ohio Environmental Protection Agency (Ohio EPA) to release you from the terms and conditions of this permit.

An NOT may be submitted to Ohio EPA if the following requirements have been fulfilled:

1. A perennial vegetative cover (or equivalent means of stabilization) has been established over 100% of the surface area disturbed during construction. The vegetative growth must be at a growth density of 70%.
2. All temporary sediment and erosion controls have been removed and properly disposed.
3. All sediment has been permanently stabilized to prevent further erosion.
4. Construction activity at the site has ceased.

It appears that your site meets the above criteria. If you agree, please submit an NOT within 45 days of the completion of construction activities. Failure to submit an NOT is a violation of the permit requirements and may affect your ability to obtain a NPDES permit in the future.

Please send the completed NOT to the following address:

Ohio Environmental Protection Agency  
Division of Surface Water  
Storm Water Section  
P.O. Box 1049  
Columbus, Ohio 43216-1049

If there are any questions, please contact me at (740) 380-5447 or Aaron Wolfe at (740) 380-5277.

Sincerely,

A handwritten signature in cursive script that reads "Sara Peters".

Sara Peters  
Storm Water Section  
Division of Surface Water

SP/dh

Enclosure: Notice of Termination