

Ohio EPA DSW Storm Water Section, Construction Site Visit Information Form

Inspector initials: EWG

Visit date: 7/18/14 Permit # 16C04159

Site Name: WPAFB Taxiway B North End (Hiway Paving Inc)

Site Address: WPAFB 45437

People contacted on site (attach business cards): Zack Olds

Their phone and e-mail: 257-9009

1. Did you see the following on site?

ITEM	Yes/No	Not requested	Comments
NOI	Yes		
Coverage letter	Y		
SWP3	Y		
Inspection records	Y		
Contractor & Subs signature document	Y		

2. Acreage disturbed (circle): < 1 acre >1 but <5 acres >5 but <10 acres >10 acres ³² ??

3. Site status,; Clearing/grubbing Rough grading Storm sewers in Streets in
 Utilities installed Final grade Final stabilization

4. Are BMPs needed on site? Yes Concrete Washout Silt Fence
Inlet Covers

5. Are BMPs on site effective? All Some None No BMPS

Explain: Some Areas have Double Protection Silt + Inlet

6. What post construction controls are shown on the SWP3? None

7. Were photos taken and saved? Yes

8. Was an NOV issued? No

Notes:

- Batch Plant for Taxi-Ways
- 3 phase washout Area

Taxi area Complete Silt fence to be removed