



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

July 18, 2012

Shane Clark  
Del-Co Water Company, Inc.  
6658 Olentangy River Road  
Delaware, OH 43015

**Re: Lackey Old State Road Water Transmission Line, Delaware County**

Dear Mr. Clark:

This letter is written in follow-up to a construction storm water inspection that I conducted on July 16, 2012, of the Lackey Old State Road Water Transmission Line project located along Lackey Old State Road from Cheshire Road to US 36, in Delaware, Ohio. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following:

**Sediment Controls and Maintenance:**

- There was active construction at the site during my inspection.
- There were no erosion controls installed at the site. The contractor stated he was not aware of the erosion controls that were proposed to be installed in the storm water pollution prevention plan (SWP3). The SWP3 was not located at the site.
- Please provide me an electronic copy of the SWP3 to the following e-mail address; [greg.sanders@epa.state.oh.us](mailto:greg.sanders@epa.state.oh.us). Also, please provide me with the inspection log.
- Please make the contractor aware of the erosion controls that need to be installed per the SWP3. Please insure that the erosion controls are installed per the SWP3. It was noted that the contractor is listed as a co-permittee on the construction permit.
- Please be aware the General Permit mandates specific permanent and temporary stabilization requirements. All disturbed areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. All areas of final grade must be protected within seven days.

Shane Clark  
Del-Co Water Company, Inc.  
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3851.

Sincerely,

A handwritten signature in black ink, appearing to read 'G.L. Sanders', written in a cursive style.

Gregory L. Sanders  
Environmental Specialist  
Division of Surface Water  
Central District Office

c: Don Starn, Ray Starn & Son

ec: Greg Sanders, DSW/CDO

GS/nsm Lackey Old State Road Water Transmission Line, July 16, 2012