



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

July 25, 2012

Re: Meigs County
Rutland WWTP
Self-Monitoring Report Violations
Ohio EPA Permit OPA00052
NPDES Permit OH0050130
Correspondence (PWW)

Mayor and Council
Village of Rutland WWTP
P.O. Box 420
Rutland, Ohio 45775

Dear Mayor and Council:

We have received your self-monitoring reports covering the months of January through May 2012 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Outfall	Date	Parameter	Reported	Units	Limit
001	1/1/2012	Nitrogen, Ammonia (NH3)	3.9	mg/l	3.0
001	2/1/2012	Nitrogen, Ammonia (NH3)	11.045	mg/l	3.0
001	2/1/2012	Nitrogen, Ammonia (NH3)	1.24038	mg/l	0.59
001	2/15/2012	Nitrogen, Ammonia (NH3)	12.3	mg/l	4.5
001	2/15/2012	Nitrogen, Ammonia (NH3)	1.44322	mg/l	0.89
001	2/22/2012	Nitrogen, Ammonia (NH3)	9.79	mg/l	4.5
001	2/22/2012	Nitrogen, Ammonia (NH3)	1.03754	mg/l	0.89

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have reviewed your report addressing the reasons for the above violations and the actions being taken to prevent further occurrences. Hopefully, these actions will prevent any recurrence so that enforcement action will not be required. No additional information is requested at this time.

If there are any questions, please contact me at (740) 380-5266.

Sincerely,

Cynthia Yandrich
District Representative
Division of Surface Water

CY/dh