



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

July 25, 2012

Re: Meigs County
Middleport WWTP
Self-Monitoring Report Violations
Ohio EPA Permit OPB00025
NPDES Permit OH0026514
Correspondence (PWW)

Mr. Faymon Roberts
Village of Middleport
237 Race Street
Middleport, Ohio 45760

Dear Mr. Roberts:

We have received your self-monitoring report covering the month of October 2011 through May 2012 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Outfall	Date	Parameter	Reported	Units	Permit Limit
001	12/1/2011	CBOD 5 day	33.1872	mg/l	28.4
001	12/8/2011	CBOD 5 day	116.885	mg/l	45.4
001	1/1/2012	Total Suspended Solids	53.0035	mg/l	34.1
001	1/15/2012	Total Suspended Solids	61.1148	mg/l	51.1
001	1/22/2012	Total Suspended Solids	135.177	mg/l	51.1
001	2/1/2012	Total Suspended Solids	36.2982	mg/l	34.1
001	2/1/2012	Total Suspended Solids	70.2261	mg/l	51.1
001	3/1/2012	Total Suspended Solids	51.3064	mg/l	51.1
001	3/1/2012	CBOD 5 day	36.6754	mg/l	28.4
001	3/1/2012	CBOD 5 day	68.4085	mg/l	45.4
001	3/15/2012	CBOD 5 day	45.7455	mg/l	45.4


Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

The violations were CBOD₅ and total suspended solids monthly and weekly loadings. These violations occur when flows are over the design flow of the plant. The Village is currently under construction to eliminate the majority of storm water from the system

while increasing the capacity of the lagoons to handle more water from the combined system. I encourage the Village to remove as much storm water that is feasible from the system as quickly as possible.

No response is needed at this time. If there are any questions, please contact me at (740) 380-5266.

Sincerely,

A handwritten signature in black ink, appearing to read 'Cynthia Yandrich', written in a cursive style.

Cynthia Yandrich
District Representative
Division of Surface Water

CY/dh