



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

July 25, 2012

Re: Guernsey County
Buckeye Trail School
Notice of Violation
0GS00067; OHGS00123
Correspondence (PWW)

Mr. Lonnie E. Caudill, Principal
Buckeye Trail High School
65553 Wintergreen Road
Lore City, Ohio 43755

Dear Mr. Caudill:

We have received your self-monitoring report covering the months of March through June 2012 for the Buckeye Trail High School wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Numeric Violations:

Station	Reporting Code	Parameter	Violation Date	Limit Type*	Limit	Reported Value
001	00610	Nitrogen, Ammonia	3/1/2012	30D Conc	3.0	4.22667
001	00610	Nitrogen, Ammonia	3/1/2012	7D Conc	4.5	5.48
001	00530	Total Suspended Solids	3/1/2012	30D Conc	12	13.3333
001	00530	Total Suspended Solids	3/1/2012	7D Conc	18	22.
001	00300	Dissolved Oxygen	3/5/2012	1D Conc	6.0	5.35
001	00300	Dissolved Oxygen	3/14/2012	1D Conc	6.0	4.7
001	00300	Dissolved Oxygen	3/26/2012	1D Conc	6.0	5.

* 1D Conc is equal to maximum daily concentration limit.
30D Conc is equal to average monthly concentration limit.

A prior explanation of these violations has been sent and no further action is required.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at (740) 380-5418.

Sincerely,

A handwritten signature in cursive script, appearing to read "Tim Fulks".

Tim Fulks
District Representative
Division of Surface Water

TF/dh