



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

July 25, 2012

Re: Guernsey County
Rolling Hills Subdivision WWTP
Notice of Violations
OPW00007; OH0075809
Correspondence (PWW)

Mr. Dennis Daugherty
Guernsey County Water and Sewer District
11272 E. Pike
Cambridge, Ohio 43728

Dear Mr. Daugherty:

We have received your self-monitoring reports covering the months of April through June 2012 for the Rolling Hills Subdivision's wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Numeric Violations:

Station	Reporting Code	Parameter	Violation Date	Limit Type*	Limit	Reported Value
001	31616	Fecal Coliform	6/15/2012	7D Conc	2000	5100.

* 1D Conc is equal to a maximum daily concentration limit.
1D QTY is equal to the maximum daily loading limit
7D Conc is equal to a weekly average concentration limit.
7D Qty is equal to the weekly average loading limit.

A prior explanation of these violations has been sent. No further action is required.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at (740) 380-5418.

Sincerely,

Tim Fulks
District Representative
Division of Surface Water

TF/dh