



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

Re: Allen County  
All-Former District Office Demolition  
Construction  
Storm Water

July 31, 2012

Mr. Luke Johansen  
ODOT District 1  
1885 North McCullough Street  
Lima, Ohio 45801

Ms. Trish Pohl  
J&J Schlaegel, Inc.  
518 Miami Street  
Urbana, Ohio 43078

Dear Mr. Johansen and Ms. Pohl:

On July 17, 2012, I inspected All-Former District Office Demolition located at 2100 North West Street, Lima (photos taken). The purpose of the visit was to evaluate compliance of the site with the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity, Facility ID No. 2GC01950\*AG. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. No one was present onsite at the time of my visit.

It appeared that construction at the site was complete and the majority of the site had been seeded and had a grass cover. A Notice of Termination (NOT) must be filed to relieve you of the obligation to comply with this general permit. An NOT may be filed if one or more of the following conditions have been met:

- Final stabilization has been established on all areas of the site for which the permittee is responsible. Final stabilization means that all soil disturbing activities at the site are complete and a uniform perennial vegetative cover of at least 70% density has been established over the entire site. All temporary erosion and sediment control measures have been removed, properly disposed of, and all trapped sediment has been permanently stabilized; or
- Another operator(s) has assumed control over all areas of the site that have not been fully stabilized.

Your site appears to meet all of the conditions mentioned above; therefore, you may remove any temporary sediment controls and file the NOT form. The NOT form and instructions can be found on our website: <http://www.epa.ohio.gov/dsw/storm/stormform.aspx>. NOTs must be mailed to Ohio EPA's Central Office within 45 days of when the above criteria are met.

If there are any questions, please contact me at (419) 373-3025.

Sincerely,

Jessica Heitman  
Division of Storm Water  
Storm Water Program

/jlm  
pc NWDO file  
ec: Tracking