



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Fulton County
Pike Delta York Local Schools Bus Fueling Station
Construction
Storm Water

July 27, 2012

Mr. Robin Rayfield
Pike Delta York Local Schools
504 Fernwood Street
Delta, Ohio 43515

Dear Mr. Rayfield:

On June 27, 2012, Jessica Heitman and I inspected Pike Delta York Local Schools Bus Fueling Station on the west side of County Road 6-2, Delta. The purpose of our visit was to evaluate compliance of the site with the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity, Facility ID No. 2GC02799. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. Our records indicate that there are no co-permittees on this project.

It appears that construction activities at Pike Delta York Local Schools Bus Fueling Station are complete.

A Notice of Termination (NOT) must be filed to relieve you of the obligation to comply with this general permit. An NOT may be filed if one or more of the following conditions have been met:

- Final stabilization has been established on all areas of the site for which the permittee is responsible. Final stabilization means that all soil disturbing activities at the site are complete and a uniform perennial vegetative cover of at least 70% density has been established over the entire site. All temporary erosion and sediment control measures have been removed, properly disposed of, and all trapped sediment has been permanently stabilized; or
- Another operator(s) has assumed control over all areas of the site that have not been fully stabilized.

The NOT form and instructions can be found on our website: <http://www.epa.ohio.gov/dsw/storm/stormform.aspx>. NOTs must be mailed to Ohio EPA's Central Office within 45 days of when the above criteria are met.

Within 10 days of the date on this letter, please submit to this office **written notification** as to whether or not an NOT has been submitted to Columbus.

If there are any questions, please contact me at 419-373-3011.

Sincerely,

Bernard E. Weik
Division of Surface Water
Storm Water Program

/jlm

ec: Pete Carr, District Technician III
Tracking

Northwest District Office
347 North Dunbridge Road
Bowling Green, OH 43402-9398

419 | 352 8461
419 | 352 8468 (fax)
www.epa.ohio.gov