



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Allen County
Elida High School and Sports Complex
Construction
Storm Water

July 27, 2012

Mr. Don Diglia
Superintendent
Elida Local Schools
4380 Sunnydale Drive
Elida, Ohio 45087

Mr. Mark Miller
Elida High School and Sports Complex
101 East North Street
Elida, Ohio 45807

Dear Messrs. Diglia and Miller:

On July 2, 2012, Jessica Heitman and I inspected Elida High School and Sports Complex at 101 East North Street, Elida. The purpose of our visit was to evaluate compliance of the site with the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity, Facility ID No. 2GC02885. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111.

It appears that construction activities at Elida High School and Sports Complex are complete. The buildings and parking lot have been constructed. Seventy percent stabilization also appears to have been achieved.

A Notice of Termination (NOT) must be filed to relieve you of the obligation to comply with this general permit. An NOT may be filed if one or more of the following conditions have been met:

- Final stabilization has been established on all areas of the site for which the permittee is responsible. Final stabilization means that all soil disturbing activities at the site are complete and a uniform perennial vegetative cover of at least 70% density has been established over the entire site. All temporary erosion and sediment control measures have been removed, properly disposed of, and all trapped sediment has been permanently stabilized; or
- Another operator(s) has assumed control over all areas of the site that have not been fully stabilized.

Messrs. Diglia and Miller
July 27, 2012
Page Two

The NOT form and instructions can be found on our website:
<http://www.epa.ohio.gov/dsw/storm/stormform.aspx>. NOTs must be mailed to Ohio EPA's
Central Office within 45 days of when the above criteria are met.

Within 10 days of the date on this letter, please submit to this office written notification as to
whether or not an NOT has been submitted to our Central Office.

If there are any questions, please contact me at 419-373-3011.

Sincerely,



Bernard E. Weik
Division of Surface Water
Storm Water Program

/jlm

cc: Albert Suniga, District Technician
Tracking