



Environmental
Protection Agency

John R. Kasich, Governor

Mary Taylor, Lt. Governor

Scott J. Nally, Director

July 26, 2012

RE: SUMMIT COUNTY
VILLAGE OF REMINDERVILLE
LIBERTY LEDGES PHASE 1&2
CONSTRUCTION STORM WATER
PERMIT NO: 3GC03722

Mr. Mario Depadova
Liberty Ledges LLC
27800 Cedar Road
Beachwood, OH 44122

Dear Mr. Depadova:

On July 18, 2012 I performed a follow-up compliance inspection for storm water best management practices (BMPs) at the above referenced site. Our records indicate that the Liberty Ledges LLC has obtained coverage under the Ohio EPA General Storm Water National Pollutant Discharge Elimination System (NPDES) Permit for Construction Activities #3GC03722*AG.

After review of the site and Storm Water Pollution Prevention Plan (SWP3), I noted that hydroseeding has taken place around the perimeter of the site and that road catch basins with inlet protection have been installed. The silt fence along Liberty Road has been installed, but it needs to be extended inward toward the site on the side next to the construction entrance. Water is able to go around the silt fence at this time.

Please provide me with a letter of response indicating the actions that you have taken or will take to address the deficiencies noted above. Your response must be received **no later than August 9, 2012**. Failure to comply with the NPDES permit is a violation of Ohio Revised Code 6111.04 and 6111.07 and is punishable by fines.

If you have any questions, please contact me at (330) 963-1125 or by e-mail at Katie.Bowman@epa.state.oh.us

Sincerely,

Katie Bowman
Assistant to the District Engineer
Division of Surface Water

cc: Brian Prunty, SWCD, Summit County
Tony Riggi, Fabrizi Trucking
Sam Alonso, Mayor, Village of Reminderville

INSPECTION PHOTOS

Liberty Ledges Phase 1&2



Figure 1: Silt fence along Liberty Road. Needs to be extended toward the site