



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

July 27, 2012

**Re:** Muskingum County  
Kensington Village  
Storm Water Construction Activity  
Notice of Violation  
OGC00690\*AG

Mr. Larry Parr  
Mid-Ohio Development Corp.  
P.O. Box 32449  
Columbus, Ohio 43232

Dear Mr. Parr:

On June 26, 2012, I visited your site Kensington Village. The purpose of the inspection was to determine the compliance of this site with the National Pollutant Discharge Elimination System (NPDES) permit for discharges of stormwater associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. The following areas need to be addressed:

1. Part III.G.2.b.i. (Table 2) of the permit requires that any area that will lie dormant for more than 21 days, but less than a year be stabilized within 7 days of the most recent disturbance.

**We recommend that you do not cut the grass so short in the undeveloped areas. We understand that you will soon begin construction again. Please implement storm water controls as required.**

2. Part V. N. of the permit states that all facilities and systems of treatment and control must be properly operated and maintained at all times.

**The catch basin must be cleaned out and repaired immediately.**

Sediment and erosion controls for your site must meet the guidelines and design criteria set forth in the above mentioned *Rainwater and Land Development* manual. A copy of this manual may be obtained by contacting the Ohio Department of Natural Resources, Division of Soil and Water Conservation, at (614) 265-6610.

Within fourteen (14) days of receipt of this letter, please submit to me at this office a written notification as to actions taken or proposed to eliminate violations of the permit. Your response should include the dates, either actual or proposed, for the completion of the actions. If you have any questions, please contact Aaron Wolfe at (740) 380-5277.

Sincerely,

A handwritten signature in black ink, appearing to read 'AW', with a long horizontal stroke extending to the right.

Aaron Wolfe  
Storm Water Section  
Division of Surface Water

AW/dh