



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

July 27, 2012

Re: Noble County
Caldwell Slip Remediation
Storm Water Construction Activity
Notice of Violation
0GC01659*AG

Ms. Judith Box
East Ohio Gas Co.
320 Springside Drive
Suite 320
Akron, Ohio 44333

Dear Ms. Box:

On June 25, 2012, I visited your site on Caldwell Slip Remediation. The purpose of the inspection was to determine the compliance of this site with the National Pollutant Discharge Elimination System (NPDES) permit for discharges of stormwater associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. The following areas need to be addressed:

1. Part III.G.2.b.ii. of the permit states that operators shall stabilize channels and outfalls to prevent erosive flows. Techniques may include seeding, mulching, erosion control matting, sodding, rip rap, or rock check dams.

The channels need to have rip rap installed immediately.

2. Part III.G.2.d.iii of the permit requires silt fence to be installed on a level contour. Silt fence should be utilized in accordance with the specification of the *Rainwater and Land Development* manual.

The silt fences along the left side of the entrance must be replaced immediately.

Sediment and erosion controls for your site must meet the guidelines and design criteria set forth in the above mentioned *Rainwater and Land Development* manual. A copy of this manual may be obtained by contacting the Ohio Department of Natural Resources, Division of Soil and Water Conservation, at (614) 265-6610.

Within fourteen (14) days of receipt of this letter, please submit to me at this office a written notification as to actions taken or proposed to eliminate violations of the permit. Your response should include the dates, either actual or proposed, for the completion of the actions. If you have any questions, please contact Aaron Wolfe at (740) 380-5277.

Sincerely,

A handwritten signature in black ink, appearing to read 'Aaron Wolfe', with a stylized flourish extending to the right.

Aaron Wolfe
Storm Water Section
Division of Surface Water

AW/dh