



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

August 2, 2012

RE: CUYAHOGA COUNTY
OLMSTED TOWNSHIP
FITCH ROAD (CR170) GRADE
SEPARATION PROJECT W/NORF
CONSTRUCTION STORM WATER
PERMIT NO: 3GC05447 & 3GC04965

Mr. Michael Tworzydlo
Great Lakes Construction Company
2608 Great Lakes Way
Hinckley, OH 44233

Mr. Jamal Husani
Cuyahoga County Engineer
2100 Superior Viaduct
Cleveland, OH 44113

Dear Mr. Tworzydlo and Mr. Husani:

On August 2, 2012, I performed a compliance inspection for storm water best management practices (BMPs) at the above referenced site. While on site I met with Todd Zima, Project Engineer with Cuyahoga County and Grant Salzgeber, Project Superintendent with The Great Lakes Construction Company. Our records indicate that the Great Lakes Construction Company has obtained coverage under the Ohio EPA General Storm Water National Pollutant Discharge Elimination System (NPDES) Permit for Construction Activities #3GC05447*AG and Cuyahoga County has obtained coverage under the Ohio EPA General Storm Water National Pollutant Discharge Elimination System (NPDES) Permit for Construction Activities #3GC04965*AG

After review of the site and Storm Water Pollution Prevention Plan (SWP3), I noted the following deficiencies:

1. The filter sock had been moved because earth work was being done in that area. Please reestablish the filter fence along the railroad tracks.
2. There are several catch basins that do not have inlet protection, please install inlet protection per the plan.
3. There was an oil spill on the bridge; please clean this up and maintain equipment and proper spill procedures.
4. There is a 55-gallon drum in one of the sediment traps. Please dispose of this properly.

Please provide me with a letter of response indicating the actions that you have taken or will take to address the deficiencies noted above. Your response must be received no later than August 16, 2012.

FITCH ROAD (CR170) GRADE SEPARATION PROJECT W/ NORF
AUGUST 2, 2012
PAGE 2 OF 3

If you have any questions, please contact me at (330) 963-1125 or by e-mail at Katie.Bowman@epa.state.oh.us. If you have questions or if your response will be sent after August 15, please contact Dan Bogoevski at 330-963-1145 or by e-mail at Dan.Bogoevski@epa.state.oh.us.

Sincerely,

A handwritten signature in black ink, appearing to read "Katie", with a long horizontal flourish extending to the right.

Katie Bowman
Assistant to the District Engineer
Division of Surface Water

KB/cs

cc: Shannon Mullins, Environmental Specialist 2, Cuyahoga SWCD
Board of Trustees, Olmsted Township

Attachments: Photos

INSPECTION PHOTOS

Fitch Road (CR170) Grade Separation Project w/ NORF



Figures 1&2: Areas where the filter sock needs to be reestablished



Figures 3&4: Catch basins that do not have any inlet protection



Figure 5: Oil spilled on the bridge

Figure 6: 55 gallon drum in a sediment trap