



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

August 8, 2012

**Re:** Muskingum County  
Holiday Inn Express  
Storm Water Construction Activity  
Notice of Violation  
Permit OGC01092\*AG

Mr. Ben Caufield  
Zanesville Lodging, Inc.  
437 Winton Avenue  
Zanesville, Ohio 43701

Dear Mr. Caufield:

On July 9, 2012, I visited your site on Spring Street. The purpose of the inspection was to determine the compliance of this site with the National Pollutant Discharge Elimination System (NPDES) permit for discharges of stormwater associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. I have the following comments:

**Permit Coverage:**

1. Part III.G.2.b.i (Table 1) of the permit requires that permanent stabilization be applied to areas at final grade within 7 days of the last disturbance. Permanent stabilization is defined as the establishment of permanent vegetative cover, decorative landscape mulching, matting, sod, rip rap and landscaping techniques to provide permanent erosion control.

Part III.G.2.b.i. (Table 1) of the permit requires that permanent stabilization be applied within 7 days to any area that will lie dormant for more than one year. Permanent stabilization is defined as the establishment of permanent vegetative cover, decorative landscape mulching, matting, sod, rip rap and landscaping techniques to provide permanent erosion control.

**Table 1: Permanent Stabilization**

Area requiring permanent stabilization	Time frame to apply erosion controls
Any areas that will lie dormant for one year or more	Within seven days of the most recent disturbance
Any areas within 50 feet of a surface water of the State and at final grade	Within two days of reaching final grade
Any other areas at final grade	Within seven days of reaching final grade within that area


**At the time of inspection the lot south of the Holiday Inn parking lot did not appear to meet the requirements set forth in the General permit for final stabilization. Please apply seed and straw to the area.**

Sediment and erosion controls for your site must meet the guidelines and design criteria set forth in the above mentioned *Rainwater and Land Development* manual. A copy of this manual may be obtained by contacting the Ohio Department of Natural Resources, Division of Soil and Water Conservation, at (614) 265-6610.

Violators of ORC 6111 may be fined up to \$10,000 per day of violation. In addition, federal law allows for third party lawsuits for failure to comply with your NPDES permit.

Within fourteen (14) days of receipt of this letter, please submit to me at this office a written notification as to actions taken or proposed to eliminate violations of the permit. Your response should include the dates, either actual or proposed, for the completion of the actions. If you have any questions, please contact me at (740) 380-5277.

Sincerely,

A handwritten signature in black ink, appearing to read 'Joe Cook', with a stylized flourish at the end.

Joe Cook  
Storm Water Section  
Division of Surface Water

JDC/dh