



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Marion County
River Bend Campground
NPDES Permit

August 8, 2012

Ms. Anna Anderson, President
River Bend Campground
P. O. Box 401
Caledonia, Ohio 43314

Dear Ms. Anderson:

On July 27, 2012, an operation and maintenance inspection was made of the wastewater treatment plant (WWTP serving River Bend Campground. This facility is located at 1092 Whetstone River Road in Claridon Township, Marion County. This inspection was conducted to evaluate compliance with your facility's National Pollutant Discharge Elimination System (NPDES) permit No. 2PR00189.

At the time of the inspection, the treatment facilities (South & North WWTPs) were in operation and the contents of the aeration tanks were brown with good roll. There was no discharge from either plant during our visit.

Our review of your discharge monitoring reports (1/1/2011 to 7/1/2012) for this facility indicated two effluent violations. Please refer to the enclosed violation table. Our completed inspection form is enclosed for your review. If you have any questions or comments, please call me at (419) 373-3021.

Yours truly,

Jason Ko
Division of Surface Water

/jlm

Enclosures

ec: Tracking

**OHIO ENVIRONMENTAL PROTECTION AGENCY
OPERATION AND MAINTENANCE INSPECTION**

NPDES Permit No. 2PR00189

Facility Name: River Bend Campground Expiration Date: July 31, 2013

Facility Address: 1092 Whetstone River Road Date: 7/27/2012 Time: 9:30 am

City: Marion County: Marion Township: Claridon

Name and Address of Owner: River Bend Corporation, P O Box 401, Caledonia, OH 43314

Person Contacted: Mr. John Kincaid Phone: (740) 386-3768

Flow: Design: 5,000 GPD (South) & 7,500 GPD (North) Present 2,500 (S) & 1500 (N) GPD

Trib. Pop. 240 RVs Weather at time of inspection: Temp 82°F - cloudy

OEPA Personnel: Jason Ko District: NWDO

1. Plant Effluent - Mark Severity No.

No.	Severity Description	No.	Turbidity	No.	Odor	No.	Color
0	None		Clear		None		Colorless
1	Mild						
2	Moderate		Light Solids		Musty		Grey
3	Serious						
4	Extreme		Heavy Solids		Septic		Black

2. Effect of effluent on Receiving Stream Name: Olentangy River - Not Observed

No.	Severity Description	No.	Turbidity	No.	Odor	No.	Color
0	None		Clear		None		Colorless
1	Mild						
2	Moderate		Light Solids		Musty		Grey
3	Serious						
4	Extreme		Heavy Solids		Septic		Black

3. a. Plant has _____ excellent X good _____ fair _____ poor operation
 b. Plant has _____ excellent X good _____ fair _____ poor maintenance
 c. Sand filters have _____ excellent _____ good X fair _____ poor maintenance

d. Not operating at expected efficiency due to:

Disinfection: (Required May 1 thru Oct.31.)

- (1) _____ hydraulic overload
 (2) _____ organic/ solids overload
 (3) _____ personnel inefficiency
 (4) _____ equipment failure
 (5) _____ wastes
 (6) _____

IN	OUT	
<u>X</u>	_____	Chlorination
<u>X</u>	_____	Dechlorination
_____	_____	U.V

- | | | | | | |
|----------|-------|-----------------------------------|---------------------|---------------------|------------|
| Yes | No | | Yes | No | Parameters |
| <u>X</u> | _____ | Compliance with NPDES Permit | Periodic Violations | <u>X</u> | _____ |
| <u>X</u> | _____ | Adequate Plant Safety | Chronic Violation | _____ | _____ |
| <u>X</u> | _____ | Operation and Maintenance Service | Name: | <u>John Kincaid</u> | |

Frequency of Visits: 1/week

Facility Name: River Bend (South Plant)

Process	# Units	Unit	If Needed - Description and Comments
Preliminary	1	Trash Trap	Pumping Frequency: 1/year
		Grease Trap	Pumping Frequency:
		Bar Screen	
		Comminutor	
		Flow Equalization	
Aeration Equipment		Plant Timer <u>X</u> <u>Y</u> <u> </u> N	Cycle Time: 1/2 hr "ON" & 1/2 hr "OFF"
	2	Motor/ Blower Unit	
Secondary Treatment	1	Aeration Tank	Color : Brown Adequate Aeration: Y <u>X</u> N <u> </u>
Final Settling	1	Clarifier	2 hoppers with some scum
	2	Sludge Return	In <u>X</u> Out <u> </u> Returning solids
	1	Surface Skimmer	In <u>X</u> Out <u> </u> Returning clear
		Fixed Media Clarifier	
Tertiary Treatment	2	Surface Sand Filter	Remove weed
		Polishing Pond	
		Other	
Disinfection	IN	Chlorine	Feed Cl at Clarifier Weir
	IN	Dechlorination	
		Ultraviolet (UV)	
Flow Metering	IN	Elapsed Pump Time	Hour meter at influent pump station
		Other	
Pumps	2	Raw Wastewater (type)	
	2	Sand Filter Effluent Dosing	
Sludge Handling		Aerated Storage Tank	
		Sludge Drying Bed	
Sludge Disposal	IN	Municipal POTW	Haul to City of Marion
		Landfill	
		Land Application	
Advanced Treatment	IN	Post Aeration	
		Spray Irrigation	
		Other	

Facility Name: River Bend (North Plant)

Process	# Units	Unit	If Needed - Description and Comments
Preliminary	1	Trash Trap	Pumping Frequency: 1/year
		Grease Trap	Pumping Frequency:
		Bar Screen	
		Comminutor	
	1	Flow Equalization	5000 gal, aerated w/ 2 pumps
Aeration Equipment		Plant Timer <u>X</u> <u>Y</u> <u> </u> <u>N</u>	Cycle Time: 1/2 hr "ON" & 1/2 hr "OFF"
	2	Motor/ Blower Unit	
Secondary Treatment	2	Aeration Tank	Color : Brown Adequate Aeration: Y <u>X</u> N <u> </u>
Final Settling	1	Clarifier	2 hoppers with scum
	2	Sludge Return	In <u>X</u> Out <u> </u>
	1	Surface Skimmer	In <u>X</u> Out <u> </u>
		Fixed Media Clarifier	
Tertiary Treatment	2	Surface Sand Filter	Remove weed
		Polishing Pond	
		Other	
Disinfection	IN	Chlorine	Feed Cl at splitter box
	IN	Dechlorination	
		Ultraviolet (UV)	
Flow Metering	IN	Elapsed Pump Time	Hour meter at EQ pumps
		Other	
Pumps	2	Raw Wastewater (type)	One lift station in the park
	2	Sand Filter Effluent Dosing	
Sludge Handling		Aerated Storage Tank	
		Sludge Drying Bed	
Sludge Disposal	IN	Municipal POTW	Haul to City of Marion
		Landfill	
		Land Application	
Advanced Treatment	IN	Post Aeration	
		Spray Irrigation	
		Other	

Get New Data

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PR00189*BD	June 2011	002	00530	Total Suspended Solids	30D Conc	12	14.	6/1/2011
2PR00189*BD	June 2012	002	31616	Fecal Coliform	1D Conc	2000	2000.	6/11/2012