



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

August 9, 2012

Re: Jackson County
Village of Oak Hill WWTP
Notice of Violation
NPDES Permit 0PB00055*GD
OH0026859
Correspondence (PWW)

Mayor and Council
Village of Oak Hill
415 N. Front Street
Oak Hill, Ohio 45656

Dear Mayor and Council:

NOTICE OF VIOLATION - Significant Non-Compliance

We have received self-monitoring reports covering January through June 2012 for the referenced facility. Our review indicated the following violations of your NPDES permit.

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00530	Total Suspended Solids	30D Conc	20	28.6	1/1/2012
001	00530	Total Suspended Solids	30D Qty	22.7	48.6433	1/1/2012
001	00610	Nitrogen, Ammonia (NH3)	7D Conc	6.0	7.76	1/1/2012
001	00530	Total Suspended Solids	7D Conc	30	72.	1/15/2012
001	00530	Total Suspended Solids	7D Qty	34.1	147.575	1/15/2012
001	80082	CBOD 5 day	7D Qty	26.1	31.3360	1/15/2012
001	00530	Total Suspended Solids	30D Conc	12	20.575	5/1/2012
001	00530	Total Suspended Solids	7D Conc	18	71.5	5/1/2012
001	00530	Total Suspended Solids	30D Qty	13.6	45.8497	5/1/2012
001	00530	Total Suspended Solids	7D Qty	20.4	165.624	5/1/2012
001	31616	Fecal Coliform	7D Conc	2000	2900.	5/1/2012
001	80082	CBOD 5 day	7D Qty	17.0	23.3913	5/1/2012
001	31616	Fecal Coliform	7D Conc	2000	6000.	5/8/2012

The recently reported data places the facility on our Significant Non-Compliance list.

The Clarifier scum/rake drive(s) are being repaired limiting the hydraulic and solids return capacities. Mr. Carpenter is coordinating with various suppliers to correct the problem. The clarifier corrections need to be expedited. During wet weather, both clarifiers need to operate for plant compliance.

Please be advised that failure to comply with the effluent limitations of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

If you have any questions, please feel free to contact me at (740) 380-5272.

Sincerely,

A handwritten signature in black ink, appearing to read 'Aaron Pennington', written over a faint, illegible typed name.

Aaron Pennington
District Representative
Division of Surface Water

AMP/dh