



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Allen County
University of Northwestern Ohio
Construction
Storm Water

August 14, 2012

Mr. Don Ricker
University of Northwestern Ohio
1441 North Cable Road
Lima, Ohio 45805

Mr. Jay Ulm
Ulms Excavating, Inc.
825 West Skinner
Delphos, Ohio 45833

Dear Messrs. Ricker and Ulm:

On July 17, 2012, I inspected University of Northwestern Ohio at 1441 North Cable Road, Lima (photos taken). The purpose of the visit was to evaluate compliance of the site with the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity, Facility ID No. 2GC01442*AG. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. No one was present onsite at the time of my visit.

It appeared that construction at the site was complete and the majority of the site had been seeded and had a grass cover. A finished building and paved parking areas were present. The parking lot had curb cuts that appeared to drain into an infiltration trench to meet the post-construction storm water management requirements of the permit. A Notice of Termination (NOT) must be filed to relieve you of the obligation to comply with this general permit. An NOT may be filed if one or more of the following conditions have been met:

- Final stabilization has been established on all areas of the site for which the permittee is responsible. Final stabilization means that all soil disturbing activities at the site are complete and a uniform perennial vegetative cover of at least 70% density has been established over the entire site. All temporary erosion and sediment control measures have been removed, properly disposed of, and all trapped sediment has been permanently stabilized; or
- Another operator(s) has assumed control over all areas of the site that have not been fully stabilized.

Messrs. Ricker and Ulm
August 14, 2012
Page Two

Your site appears to meet all of the conditions mentioned above. If you believe this is accurate and you have installed the post-construction storm water management facilities required by the permit, please file the NOT form. The NOT form and instructions can be found on our website: <http://www.epa.ohio.gov/dsw/storm/stormform.aspx>. NOTs must be mailed to Ohio EPA's Central Office within 45 days of when the above criteria are met.

Within 10 days of the date on this letter, please submit a written description of how the post construction storm water management requirements have been met for this project. Your reply should include the type(s) of practices you are implementing and the basis for their design.

If there are any questions, please contact me at (419) 373-3025.

Sincerely,



Jessica Heitman
Division of Storm Water
Storm Water Program

/jlm

pc: NWDO file