Ohio | Environmental Protection Agency
John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

August 8, 2012

Re: Guernsey County
Seneca Lake Campground
Notice of Violation
0PX00002; OH0059102
Correspondence (PWW)
Certified Mail 7010 1060 0001 7896 4604

Mr. Boris Slogar, Chief Engineer
Muskingum Watershed Conservancy District
1319 3rd Street, NW, P.O. Box 349
New Philadelphia, Ohio 44663

Dear Mr. Slogar:

On August 2, 2012, I conducted a Compliance Evaluation Inspection (CEI) of the Muskingum Watershed Conservancy District's (MWCD) Seneca Lake Campground wastewater treatment plant. The purpose of the inspection was to determine the facility's compliance status with the terms and conditions of NPDES Permit Number 0PX00002*AD. Myself, Superintendent Gary Taylor, and operator Jeremiah Warner were present during the inspection.

As a result of the inspection, I have the following comments:

1. A review of the facility's discharge monitoring reports (DMRs) for the current permit cycle (April 2005 through June 2012) shows extensive permit violations (approximately 1400 permit limit violations - see attached data). The parameters most frequently violated are total residual chlorine, dissolved oxygen, phosphorus, and total suspended solids.

2. MWCD operates an aerated lagoon system with chlorine disinfection and chemical phosphorus removal.

3. The final effluent flow meter needs to be calibrated on annual basis. **Part III, Item 3 (A)** of your permit requires at all times the permittee maintain in good working order and operate as efficiently as possible all treatment or control facilities. Please have the flow meter calibrated and document the date of calibration.

4. **Part III, Item 3 (A)** of your permit indicates proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. MWCD utilizes Ream and Haager Laboratory to test all parameters in their permit except for water temperature, color, dissolved oxygen, odor, and turbidity. Please note that the maximum hold time for pH and chlorine is 15 minutes. These parameters should be analyzed on site.

5. A review of the operator's log book revealed several occasions where entries were made in pencil. All entries should be made in ink.

6. Your NPDES permit expired on March 31, 2010. We are currently in the process of renewing your permit. The facility should continue to sample in accordance with the expired permit until the renewal is issued.

To address the violations noted in Item #1, MWCD needs to submit an acceptable plan to the Ohio EPA within (30) days upon receipt of this application to come into compliance with its permit. The plan should specifically address how excessive violations for total residual chlorine, dissolved oxygen, phosphorus and TSS will be resolved. Ohio EPA encourages MWCD to look at options such as installation of UV disinfection, post aeration, and sand filters, removing sludge from the lagoons and adjusting chemical feed rates for phosphorus removal. The plan should include a timeline for any actions necessary to achieve compliance. **If an acceptable plan is not submitted, your facility will be referred for enforcement action.**

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets or U.S. EPA's "Facility Pollution Prevention Guide" (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614) 644-3469.

Attached is a copy of the inspection report. If you have any questions about my inspection, please feel free to contact me by phone at (740) 380-5418 or email at tim.fulks@epa.state.oh.us.

Sincerely,

Tim Fulks
District Representative
Division of Surface Water

TF/dh

Enclosure

c: Gary Taylor, Operator, MWCD

OhioEPA

State of Ohio Environmental Protection Agency
Southeast District Office

Municipal NPDES Compliance Inspection Report

Section A: National Data System Coding					
Permit #	**NPDES #**	**Month/Day/Year**	**Inspection Type**	**Inspector**	**Facility Type**
0PX00002*AD	OH0059102	August 2, 2012	C	S	1

Section B: Facility Data		
Name and Location of Facility Inspected	**Entry Time**	**Permit Effective Date**
Seneca Lake Camp Area WWTP State Route 313, Richland Township Senecaville, Ohio 43780	2:30 p.m.	April 1, 2005
	Exit Time	**Permit Expiration Date**
	3:30 p.m.	March 31, 2010
Name(s) and Title(s) of On-Site Representative(s)	**Phone Number(s)**	
Gary Taylor, Plant Superintendent Jeremiah Warner, Plant Operator	(330) 827-0406	
Name, Address, and Title of Responsible Official	**Phone Number**	
Mr. Boris Slogar, Chief Engineer Muskingum Watershed Conservancy District 1319 3rd Street, NW P.O. Box 349 New Philadelphia, Ohio 44663	(330) 343-6647	

Section C: Areas Evaluated During Inspection
(S = Satisfactory; M = Marginal; U = Unsatisfactory; N = Not Evaluated; N/A = Not Applicable)

S	Permit	U	Flow Measurement	N/A	Pretreatment
M	Records/Reports	S	Laboratory	U	Compliance Schedules
S	Operations & Maintenance	U	Effluent/Receiving Waters	U	Self-Monitoring Program
S	Facility Site Review	M	Sludge Storage/Disposal	N	Other
S	Collection System				

Section D: Summary of Findings (attach additional sheets if necessary)

Flow Measurment: The effluent flow meter needs to be calibrated annually
Records/Reports: All entries in Operator log book should be made in ink
Compliance Schedules: Permittee is not consistently meeting residual chlorine limitations
Effluent/Receiving Waters: Excessive violations for multiple parameters - see attached data
Self-Monitoring Program: Hold times for pH and chlorine require they be analyzed onsite
Sludge Storage/Disposal: Sludge should be periodically removed from the lagoon and disposed

Inspector	Reviewer
8/8/12	Jennifer M. Witte 8/8/12
Timothy A. Fulks Date Division of Surface Water Southeast District Office	**Jennifer M. Witte** Date Compliance & Enforcement Supervisor Division of Surface Water Southeast District Office

Sections E through K: Complete on all inspections as appropriate
Y = Yes; N = No; N/A = Not Applicable; N/E = Not Evaluated

Section E: Permit Verification

Inspection observations verify the permit

(a) Correct name and mailing address of permittee ..... Y
(b) Flows and loadings conform with NPDES permit ..... Y
(c) Treatment processes are as described in permit application ..... Y
(d) All discharges are permitted ..... Y
(e) Number and location of discharge points are as described in permit ..... Y
(f) Storm water discharges properly permitted ..... Y

Comments/Status:

Section F: Compliance

(a) Any significant violations since the last inspection ..... Y
(b) Appropriate Non-compliance notification of violations ..... Y
(c) Permittee is taking actions to resolve violations ..... N
(d) Permittee has a compliance schedule ..... Y
(e) Compliance schedule contained in ..... NPDES permit
(f) Permittee is in compliance with schedule ..... N
(g) Has biomonitoring shown toxicity in discharge since last inspection ..... N/E

Comments/Status:

Section G: Operation and Maintenance

Treatment Works:

Treatment facility properly operated and maintained

(a) Standby power available generator ☒ or dual feed ☐ ..... Y
i. What does the back-up power source operate
A portable generator is avaible to operater the entire plant
ii. How often is the generator tested under load
N/E

(b) Which components have an alarm system available for power or equipment failures

N/A

(c) All treatment units in service other than backup units ..... Y

(d) What method is used for scheduling routine and preventative maintenance (calendar, software, etc.)

None

(e) Any major equipment breakdown since last inspection ..... Y

(f) Operation and maintenance manual provided and maintained ..... N/E

(g) Any plant bypasses since last inspection ..... N

(h) Any plant upsets since last inspection ..... N

Comments/Status:

(e) One blower broke down in January 2011

Record Keeping/Operator of Record:

(a) Wastewater Treatment Works classification (OAC 3745-7) I

(b) Operator of Record holds unexpired license of class required by Permit ..... Y

(c) Copy of certificate of Operator of Record displayed on-site ..... Y

(d) Has the Operator of Record submitted an ORC Notification form ..... Y

(e) Minimum operator staffing requirements fulfilled (OAC 3745-7) ..... Y

(f) If a Staffing Reduction plan has been approved, are the stipulations of the plan being met ..... N/A

(g) Operator of Record log book provided ..... Y

(h) Format of log book (e.g. computer log, hard bound book)

Hard bound book

(i) Log book kept onsite (in an area protected from weather) ..... Y

(j) Log book contains the following:

I. Identification of treatment works ..... Y

II. Date/times of arrival/departure for Operator of Record and any other operator required by OAC 3745-7 ..... Y

III. Daily record of operator and maintenance activities (including preventative maintenance, repairs and request for repairs, process control test results, etc.) ..... Y

IV. Laboratory results (unless documented on bench sheets) ..... Y

V. Identification of person making entries ..... Y

(k) Has the Operator of Record submitted written notifications to the permittee, Ohio EPA and, if applicable, any local environmental agencies when a collection system overflow, treatment plant bypass or effluent limit violation has occurred ..... Y

Comments/Status:

Collection System:

(a)	Are there pump stations in the collection system	Y
	I. How many publicly-owned pump stations equipped with permanent standby power or equivalent	5
	II. How many pump stations have telemetered alarms	0
	III. How many pump stations have operable alarms	5
(b)	Any chronic collection system overflows since last inspection	N
(c)	Regulatory agency notified of all overflows	N/A
(d)	Are there CSOs in the collection system	N
	If so, what is the LTCP status	
	N/A	
(e)	How are CSOs monitored (chalk, block, level sensor, etc.)	
	N/A	
(f)	Portable pumps available for collection system maintenance	Y
(g)	RDII Program established and active	N/E
(h)	Any WIB complaint received since last inspection	N
(i)	Is there a WIB response plan	N/E
(j)	Is any portion of the collection system at or near dry weather capacity	N

Comments/Status:

Section H: Sludge Management

(a) Method of Sludge Disposal.....

- ☐ Land Application
- ☐ Haul to Another NPDES Permittee
- ☐ Haul to a Mixed Solid Waste Landfill

*if one of the selected methods is land application, complete applicable charts.

Class A – Exception Quality Sewage Sludge (monitoring station 584)

Pathogen Reduction Alternative	84370 Vector Attraction Reduction Options							
	Option 1 – 38% Volatile Solids Reduction	Option 2 – Anaerobic Bench Scale Analysis	Option 3 – Aerobic Bench Scale Analysis	Option 4 – Specific Oxygen Uptake Rate	Option 5 – Aerobic Time and Temperature	Option 6 – Alkali Addition	Option 7 - >75% Solids without Unstabilized Solids	Option 8 - >75% Solids with Unstabilized Solids
Alternative 1 – Time and Temperature Regime (84369)	☐	☐	☐	☐	☐	☐	☐	☐
Alternative 2 – High pH and High Temperature (84369)	☐	☐	☐	☐	☐	☐	☐	☐
Alternative 3 – Other Processes (84369)	☐	☐	☐	☐	☐	☐	☐	☐
Alternative 4 – Unknown Processes (84369)	☐	☐	☐	☐	☐	☐	☐	☐
Alternative 5 – Composting (84397)	☐	☐	☐	☐	☐	☐	☐	☐
Alternative 5 – Heat Drying (84397)	☐	☐	☐	☐	☐	☐	☐	☐
Alternative 5 – Heat Treatment (84397)	☐	☐	☐	☐	☐	☐	☐	☐
Alternative 5 – Thermophilic Aerobic Digestion (84397)	☐	☐	☐	☐	☐	☐	☐	☐
Alternative 5 – Beta Ray Irradiation (84397)	☐	☐	☐	☐	☐	☐	☐	☐
Alternative 5 – Gamma Ray Irradiation (84397)	☐	☐	☐	☐	☐	☐	☐	☐
Alternative 5 – Pasteurization (84397)	☐	☐	☐	☐	☐	☐	☐	☐
Alternative 6 – Approved Equivalent Process	☐	☐	☐	☐	☐	☐	☐	☐

Class B – Sewage Sludge (monitoring station 581)

Pathogen Reduction Alternative	84370 Vector Attraction Reduction Options									
	Option 1 – 38% Volatile Solids Reduction	Option 2 – Anaerobic Bench Scale Analysis	Option 3 – Aerobic Bench Scale Analysis	Option 4 – Specific Oxygen Uptake Rate	Option 5 – Aerobic Time and Temperature	Option 6 – Alkali Addition	Option 7 - >75% Solids without Unstabilized Solids	Option 8 - >75% Solids with Unstabilized Solids	Option 9 – Land Injection	Option 10 – Immediate Incorporation
Alternative 1 – Geometric Mean of Seven Fecal Samples (84369)	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐
Alternative 2 – Aerobic Digestion (46396)	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐
Alternative 2 – Air Drying (46396)	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐
Alternative 2 – Anaerobic Digestion (46396)	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐
Alternative 2 – Composting (46396)	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐
Alternative 2 – Lime Treatment (46396)	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐
Alternative 3 – Approved Equivalent Process	☐	☐	☐	☐	☐	☐	☐	☐	☐	☐

(b) Has amount of sludge generated changed significantly since the last inspection ..... N/E
(c) How much sludge storage is provided at the plant

(d) Records kept in accordance with State and Federal law (5 years according to OAC 3745-40-06) ..... N/E
(e) Any complaints received in last year regarding sludge ..... N
(f) 5/8" screen at headworks for facilities that land apply sludge ..... N/A
(g) Are sludge application sites inspected to verify compliance with NPDES permit ..... N/A
(h) Is a contractor used for sludge disposal ..... N/A
If so, what is the name of the contractor

Comments/Status:

Sludge has not been removed from lagoons according to operator

Section I: Self-Monitoring Program

Flow Measurement:

(a) Primary/Secondary flow measuring devices (e.g. weir with ultrasonic level sensor)
Weir with ultrasonice level sensor
(b) Flow meter calibrated annually ..... N
Date of last calibration
unknown
(c) 24-hour recording instruments operated and maintained ..... Y
(d) Flow measurement equipment adequate to handle full range of flows ..... Y
(e) All discharged flow is measured ..... Y

Comments/Status:

Sampling:

(a) Sampling location(s) are as specified by permit ..... Y
(b) Parameters and sampling frequency agree with permit ..... Y
(c) Permittee uses required sampling method (see GLC page) ..... N
(d) Monitoring records (i.e., flow, pH, DO) maintained for a minimum of three years including all original strip chart recordings (i.e., continuous monitoring instrumentation, calibration and maintenance records) ..... N/E

Comments/Status:

(c) Permittee is having pH and total residual chlorine analyzed by lab, however, hold time on these parameters is 15 minutes. These parameters should be analyzed on site.

Laboratory:

General

(a) Does the Quality Assurance Manual contain written Standard Operating Procedures (SOP's) for all analysis performed onsite ..... N/E

(b) Do SOP's include the following if applicable ..... N/E

- Title
- Scope and Application
- Summary
- Sample Handling & Preservation
- Interferences
- Apparatus and Materials
- Reagents
- Procedure
- Calculations
- Quality Control
- Maintenance
- Corrective Action
- Reference (Parent Method)

Note: Standard Methods 1020A establishes that "Quality assurance (QA) is the definitive program for laboratory operation that specifies the measure required to produce defensible data of know precision and accuracy. Standard operating procedures are to be used in the laboratory in sufficient detail that a competent analyst unfamiliar with the method can conduct a reliable review and/or obtain acceptable results." SOPs should be developed for each analytical procedure.

(c) EPA approved analytical testing procedures used (40 CFR 136.3) ..... Y

(d) If alternate analytical procedures are used, proper approval has been obtained ..... N/A

(e) Analyses being performed more frequently than required by permit ..... N

(f) If (e) is yes, are results in permittee's self-monitoring report ..... N/A

(g) Satisfactory calibration and maintenance of instruments/equipment (see score from GLC page) ..... N/E

(h) Commercial laboratory used ..... Y
Parameters analyzed by commercial lab: pH, TSS, NH3, P, Fecal Coliform, Chlorine
Lab name: Ream and Haager Laboratory

Discharge Monitoring Report Quality Assurance (DMRQA)

(a) Participation in latest USEPA quality assurance performance sampling ..... N/A
Date:

(b) Were any parameters "Unsatisfactory" ..... N/A

(c) Reasons for "Unsatisfactory" parameters

N/A

Comments/Status:

Section J: Effluent/Receiving Water Observations

Outfall #: 001
Outfall Description: Final Outfall

Receiving Stream: Lake Seneca
Receiving Stream Description: No observable affect from the discharge were noted

Comments/Status:

Section K: Multimedia Observations

(a)	Are there indications of sloppy housekeeping or poor maintenance in work & storage areas or laboratories	N
(b)	Do you notice staining or discoloration of soils, pavement or floors	N
(c)	Do you notice distressed (unhealthy, discolored, dead) vegetation	N
(d)	Do you see unidentified dark smoke or dust clouds coming from sources other than smokestacks	N
(e)	Do you notice any unusual odors or strong chemical smells	N
(f)	Do you see any open or unmarked drums, unsecured liquids, or damaged containment facilities	N

If any of the above are observed, ask the following questions:

(1) What is the cause of the condition?
(2) Is the observed condition or source a waste product?
(3) Where is the suspected contaminant normally disposed?
(4) Is this disposal permitted?
(5) How long has the condition existed and when did it begin?

Comments/Status:

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
0PX00002*AD	April 2005	001	80082	CBOD 5 day	30D Qty	1.40	1.45723	4/1/2005
0PX00002*AD	August 2005	001	80082	CBOD 5 day	1D Qty	2.1	10.1438	8/1/2005
0PX00002*AD	August 2005	001	80082	CBOD 5 day	30D Qty	1.40	17.3428	8/1/2005
0PX00002*AD	August 2005	001	80082	CBOD 5 day	1D Qty	2.1	11.0332	8/8/2005
0PX00002*AD	August 2005	001	80082	CBOD 5 day	1D Qty	2.1	32.1308	8/15/2005
0PX00002*AD	August 2005	001	80082	CBOD 5 day	1D Qty	2.1	19.1558	8/23/2005
0PX00002*AD	August 2005	001	80082	CBOD 5 day	1D Qty	2.1	14.2505	8/29/2005
0PX00002*AD	July 2006	001	80082	CBOD 5 day	30D Conc	10	15.25	7/1/2006
0PX00002*AD	July 2006	001	80082	CBOD 5 day	1D Conc	15	23.	7/17/2006
0PX00002*AD	August 2006	001	80082	CBOD 5 day	1D Conc	15	16.	8/8/2006
0PX00002*AD	May 2008	001	80082	CBOD 5 day	1D Conc	15	16.	5/12/2008
0PX00002*AD	February 2009	001	80082	CBOD 5 day	30D Conc	10	15.25	2/1/2009
0PX00002*AD	February 2009	001	80082	CBOD 5 day	1D Conc	15	28.	2/23/2009
0PX00002*AD	September 2009	001	80082	CBOD 5 day	1D Conc	15	111.	9/1/2009
0PX00002*AD	September 2009	001	80082	CBOD 5 day	30D Conc	10	37.	9/1/2009
0PX00002*AD	September 2009	001	80082	CBOD 5 day	1D Conc	15	16.	9/10/2009
0PX00002*AD	November 2009	001	80082	CBOD 5 day	30D Conc	10	15.75	11/1/2009
0PX00002*AD	November 2009	001	80082	CBOD 5 day	1D Conc	15	21.	11/9/2009
0PX00002*AD	November 2009	001	80082	CBOD 5 day	1D Conc	15	18.	11/16/2009
0PX00002*AD	November 2009	001	80082	CBOD 5 day	1D Conc	15	19.	11/27/2009
0PX00002*AD	April 2010	001	80082	CBOD 5 day	30D Conc	10	11.5	4/1/2010
0PX00002*AD	April 2010	001	80082	CBOD 5 day	1D Conc	15	27.	4/19/2010
0PX00002*AD	June 2010	001	80082	CBOD 5 day	30D Conc	10	12.5	6/1/2010
0PX00002*AD	June 2010	001	80082	CBOD 5 day	1D Conc	15	30.	6/15/2010
0PX00002*AD	July 2010	001	80082	CBOD 5 day	30D Conc	10	19.75	7/1/2010
0PX00002*AD	July 2010	001	80082	CBOD 5 day	30D Qty	1.40	1.59065	7/1/2010
0PX00002*AD	July 2010	001	80082	CBOD 5 day	1D Conc	15	19.	7/7/2010
0PX00002*AD	July 2010	001	80082	CBOD 5 day	1D Conc	15	28.	7/12/2010
0PX00002*AD	July 2010	001	80082	CBOD 5 day	1D Qty	2.1	2.96744	7/12/2010
0PX00002*AD	July 2010	001	80082	CBOD 5 day	1D Conc	15	19.	7/19/2010
0PX00002*AD	August 2010	001	80082	CBOD 5 day	30D Conc	10	12.	8/1/2010
0PX00002*AD	August 2010	001	80082	CBOD 5 day	1D Conc	15	24.	8/9/2010
0PX00002*AD	October 2010	001	80082	CBOD 5 day	30D Conc	10	11.5	10/1/2010
0PX00002*AD	October 2010	001	80082	CBOD 5 day	1D Conc	15	18.	10/11/2010
0PX00002*AD	January 2011	001	80082	CBOD 5 day	30D Conc	10	16.5	1/1/2011
0PX00002*AD	January 2011	001	80082	CBOD 5 day	1D Conc	15	37.	1/18/2011
0PX00002*AD	February 2011	001	80082	CBOD 5 day	30D Conc	10	12.4325	2/1/2011
0PX00002*AD	February 2011	001	80082	CBOD 5 day	1D Conc	15	32.	2/22/2011
0PX00002*AD	May 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	1.11	5/1/2005
0PX00002*AD	May 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	1.2	5/2/2005
0PX00002*AD	May 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	2.	5/3/2005
0PX00002*AD	May 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	1.18	5/4/2005
0PX00002*AD	May 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	1.14	5/5/2005
0PX00002*AD	May 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	1.25	5/6/2005
0PX00002*AD	May 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	1.3	5/7/2005
0PX00002*AD	May 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	1.14	5/8/2005
0PX00002*AD	May 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	1.27	5/9/2005
0PX00002*AD	May 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	1.57	5/10/2005
0PX00002*AD	May 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	1.32	5/11/2005
0PX00002*AD	May 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	.8	5/12/2005
0PX00002*AD	May 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	1.36	5/14/2005
0PX00002*AD	May 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	1.43	5/15/2005
0PX00002*AD	May 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	2.2	5/16/2005
0PX00002*AD	May 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	1.59	5/17/2005
0PX00002*AD	May 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	1.18	5/18/2005
0PX00002*AD	May 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	.92	5/19/2005
0PX00002*AD	May 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	.66	5/20/2005
0PX00002*AD	May 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	2.2	5/21/2005
0PX00002*AD	May 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	1.56	5/22/2005

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
0PX00002*AD	May 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	.79	5/23/2005
0PX00002*AD	May 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	1.88	5/24/2005
0PX00002*AD	May 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	1.59	5/25/2005
0PX00002*AD	May 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	1.43	5/26/2005
0PX00002*AD	May 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	1.31	5/27/2005
0PX00002*AD	May 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	1.46	5/28/2005
0PX00002*AD	May 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	1.76	5/29/2005
0PX00002*AD	May 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	2.2	5/30/2005
0PX00002*AD	May 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	1.68	5/31/2005
0PX00002*AD	June 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	2.2	6/1/2005
0PX00002*AD	June 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	.65	6/2/2005
0PX00002*AD	June 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	.7	6/4/2005
0PX00002*AD	June 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	1.33	6/5/2005
0PX00002*AD	June 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	.62	6/6/2005
0PX00002*AD	June 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	.61	6/7/2005
0PX00002*AD	June 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	.89	6/10/2005
0PX00002*AD	June 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	.72	6/11/2005
0PX00002*AD	June 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	.71	6/12/2005
0PX00002*AD	June 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	.7	6/26/2005
0PX00002*AD	July 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	.53	7/2/2005
0PX00002*AD	July 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	.57	7/3/2005
0PX00002*AD	July 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	.69	7/4/2005
0PX00002*AD	July 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	.68	7/7/2005
0PX00002*AD	July 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	.59	7/8/2005
0PX00002*AD	July 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	1.46	7/13/2005
0PX00002*AD	July 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	.63	7/14/2005
0PX00002*AD	July 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	1.22	7/15/2005
0PX00002*AD	July 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	.72	7/16/2005
0PX00002*AD	July 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	.92	7/17/2005
0PX00002*AD	July 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	1.06	7/18/2005
0PX00002*AD	July 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	.56	7/19/2005
0PX00002*AD	July 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	.54	7/20/2005
0PX00002*AD	July 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	.75	7/23/2005
0PX00002*AD	July 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	.75	7/24/2005
0PX00002*AD	July 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	.61	7/26/2005
0PX00002*AD	July 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	.66	7/27/2005
0PX00002*AD	July 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	.86	7/28/2005
0PX00002*AD	July 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	.59	7/29/2005
0PX00002*AD	July 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	.98	7/30/2005
0PX00002*AD	August 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	.86	8/1/2005
0PX00002*AD	August 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	.82	8/2/2005
0PX00002*AD	August 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	.68	8/3/2005
0PX00002*AD	August 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	.88	8/5/2005
0PX00002*AD	August 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	.72	8/6/2005
0PX00002*AD	August 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	.74	8/11/2005
0PX00002*AD	August 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	.72	8/19/2005
0PX00002*AD	August 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	.64	8/29/2005
0PX00002*AD	September 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	.7	9/8/2005
0PX00002*AD	September 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	.54	9/11/2005
0PX00002*AD	September 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	1.38	9/12/2005
0PX00002*AD	September 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	1.55	9/13/2005
0PX00002*AD	September 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	1.78	9/14/2005
0PX00002*AD	September 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	1.39	9/15/2005
0PX00002*AD	September 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	.65	9/20/2005
0PX00002*AD	September 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	.92	9/28/2005
0PX00002*AD	October 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	.58	10/7/2005
0PX00002*AD	October 2005	001	50060	Chlorine, Total Residu	1D Conc	0.50	1.14	10/21/2005
0PX00002*AD	May 2006	001	50060	Chlorine, Total Residu	1D Conc	0.50	.58	5/1/2006
0PX00002*AD	May 2006	001	50060	Chlorine, Total Residu	1D Conc	0.50	.74	5/6/2006

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
0PX00002*AD	May 2006	001	50060	Chlorine, Total Residu	1D Conc	0.50	.51	5/7/2006
0PX00002*AD	May 2006	001	50060	Chlorine, Total Residu	1D Conc	0.50	.54	5/9/2006
0PX00002*AD	May 2006	001	50060	Chlorine, Total Residu	1D Conc	0.50	.59	5/25/2006
0PX00002*AD	June 2006	001	50060	Chlorine, Total Residu	1D Conc	0.50	.8	6/1/2006
0PX00002*AD	June 2006	001	50060	Chlorine, Total Residu	1D Conc	0.50	.94	6/2/2006
0PX00002*AD	June 2006	001	50060	Chlorine, Total Residu	1D Conc	0.50	.62	6/3/2006
0PX00002*AD	June 2006	001	50060	Chlorine, Total Residu	1D Conc	0.50	.89	6/4/2006
0PX00002*AD	June 2006	001	50060	Chlorine, Total Residu	1D Conc	0.50	.65	6/5/2006
0PX00002*AD	June 2006	001	50060	Chlorine, Total Residu	1D Conc	0.50	.66	6/6/2006
0PX00002*AD	June 2006	001	50060	Chlorine, Total Residu	1D Conc	0.50	.51	6/8/2006
0PX00002*AD	June 2006	001	50060	Chlorine, Total Residu	1D Conc	0.50	.56	6/11/2006
0PX00002*AD	June 2006	001	50060	Chlorine, Total Residu	1D Conc	0.50	.63	6/12/2006
0PX00002*AD	June 2006	001	50060	Chlorine, Total Residu	1D Conc	0.50	1.21	6/18/2006
0PX00002*AD	June 2006	001	50060	Chlorine, Total Residu	1D Conc	0.50	.77	6/22/2006
0PX00002*AD	June 2006	001	50060	Chlorine, Total Residu	1D Conc	0.50	.72	6/23/2006
0PX00002*AD	June 2006	001	50060	Chlorine, Total Residu	1D Conc	0.50	1.26	6/26/2006
0PX00002*AD	June 2006	001	50060	Chlorine, Total Residu	1D Conc	0.50	.92	6/28/2006
0PX00002*AD	July 2006	001	50060	Chlorine, Total Residu	1D Conc	0.50	.66	7/3/2006
0PX00002*AD	July 2006	001	50060	Chlorine, Total Residu	1D Conc	0.50	.77	7/4/2006
0PX00002*AD	July 2006	001	50060	Chlorine, Total Residu	1D Conc	0.50	.81	7/7/2006
0PX00002*AD	July 2006	001	50060	Chlorine, Total Residu	1D Conc	0.50	1.03	7/9/2006
0PX00002*AD	July 2006	001	50060	Chlorine, Total Residu	1D Conc	0.50	1.	7/12/2006
0PX00002*AD	July 2006	001	50060	Chlorine, Total Residu	1D Conc	0.50	1.03	7/13/2006
0PX00002*AD	July 2006	001	50060	Chlorine, Total Residu	1D Conc	0.50	.94	7/17/2006
0PX00002*AD	July 2006	001	50060	Chlorine, Total Residu	1D Conc	0.50	.86	7/19/2006
0PX00002*AD	July 2006	001	50060	Chlorine, Total Residu	1D Conc	0.50	.93	7/20/2006
0PX00002*AD	July 2006	001	50060	Chlorine, Total Residu	1D Conc	0.50	1.03	7/24/2006
0PX00002*AD	July 2006	001	50060	Chlorine, Total Residu	1D Conc	0.50	.77	7/30/2006
0PX00002*AD	September 2006	001	50060	Chlorine, Total Residu	1D Conc	0.50	1.07	9/13/2006
0PX00002*AD	September 2006	001	50060	Chlorine, Total Residu	1D Conc	0.50	.92	9/23/2006
0PX00002*AD	September 2006	001	50060	Chlorine, Total Residu	1D Conc	0.50	.62	9/28/2006
0PX00002*AD	October 2006	001	50060	Chlorine, Total Residu	1D Conc	0.50	1.89	10/9/2006
0PX00002*AD	October 2006	001	50060	Chlorine, Total Residu	1D Conc	0.50	8.9	10/16/2006
0PX00002*AD	October 2006	001	50060	Chlorine, Total Residu	1D Conc	0.50	1.17	10/20/2006
0PX00002*AD	October 2006	001	50060	Chlorine, Total Residu	1D Conc	0.50	.53	10/21/2006
0PX00002*AD	October 2006	001	50060	Chlorine, Total Residu	1D Conc	0.50	.58	10/22/2006
0PX00002*AD	October 2006	001	50060	Chlorine, Total Residu	1D Conc	0.50	.73	10/28/2006
0PX00002*AD	May 2007	001	50060	Chlorine, Total Residu	1D Conc	0.50	.6	5/17/2007
0PX00002*AD	May 2007	001	50060	Chlorine, Total Residu	1D Conc	0.50	.55	5/18/2007
0PX00002*AD	May 2007	001	50060	Chlorine, Total Residu	1D Conc	0.50	.51	5/21/2007
0PX00002*AD	May 2007	001	50060	Chlorine, Total Residu	1D Conc	0.50	.53	5/28/2007
0PX00002*AD	May 2007	001	50060	Chlorine, Total Residu	1D Conc	0.50	1.45	5/29/2007
0PX00002*AD	May 2007	001	50060	Chlorine, Total Residu	1D Conc	0.50	.66	5/30/2007
0PX00002*AD	May 2007	001	50060	Chlorine, Total Residu	1D Conc	0.50	.66	5/31/2007
0PX00002*AD	June 2007	001	50060	Chlorine, Total Residu	1D Conc	0.50	.53	6/1/2007
0PX00002*AD	June 2007	001	50060	Chlorine, Total Residu	1D Conc	0.50	.62	6/2/2007
0PX00002*AD	June 2007	001	50060	Chlorine, Total Residu	1D Conc	0.50	.72	6/3/2007
0PX00002*AD	June 2007	001	50060	Chlorine, Total Residu	1D Conc	0.50	.79	6/4/2007
0PX00002*AD	June 2007	001	50060	Chlorine, Total Residu	1D Conc	0.50	.82	6/9/2007
0PX00002*AD	June 2007	001	50060	Chlorine, Total Residu	1D Conc	0.50	.91	6/10/2007
0PX00002*AD	June 2007	001	50060	Chlorine, Total Residu	1D Conc	0.50	.65	6/11/2007
0PX00002*AD	June 2007	001	50060	Chlorine, Total Residu	1D Conc	0.50	.64	6/12/2007
0PX00002*AD	June 2007	001	50060	Chlorine, Total Residu	1D Conc	0.50	.77	6/14/2007
0PX00002*AD	June 2007	001	50060	Chlorine, Total Residu	1D Conc	0.50	.56	6/18/2007
0PX00002*AD	June 2007	001	50060	Chlorine, Total Residu	1D Conc	0.50	.62	6/22/2007
0PX00002*AD	June 2007	001	50060	Chlorine, Total Residu	1D Conc	0.50	1.2	6/23/2007
0PX00002*AD	July 2007	001	50060	Chlorine, Total Residu	1D Conc	0.50	.78	7/13/2007
0PX00002*AD	July 2007	001	50060	Chlorine, Total Residu	1D Conc	0.50	1.03	7/15/2007
0PX00002*AD	July 2007	001	50060	Chlorine, Total Residu	1D Conc	0.50	1.29	7/16/2007

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
0PX00002*AD	July 2007	001	50060	Chlorine, Total Residu	1D Conc	0.50	.62	7/19/2007
0PX00002*AD	July 2007	001	50060	Chlorine, Total Residu	1D Conc	0.50	1.25	7/21/2007
0PX00002*AD	July 2007	001	50060	Chlorine, Total Residu	1D Conc	0.50	.54	7/25/2007
0PX00002*AD	July 2007	001	50060	Chlorine, Total Residu	1D Conc	0.50	.76	7/26/2007
0PX00002*AD	July 2007	001	50060	Chlorine, Total Residu	1D Conc	0.50	.89	7/30/2007
0PX00002*AD	July 2007	001	50060	Chlorine, Total Residu	1D Conc	0.50	.58	7/31/2007
0PX00002*AD	August 2007	001	50060	Chlorine, Total Residu	1D Conc	0.50	.77	8/3/2007
0PX00002*AD	August 2007	001	50060	Chlorine, Total Residu	1D Conc	0.50	.56	8/5/2007
0PX00002*AD	August 2007	001	50060	Chlorine, Total Residu	1D Conc	0.50	.71	8/8/2007
0PX00002*AD	August 2007	001	50060	Chlorine, Total Residu	1D Conc	0.50	1.89	8/11/2007
0PX00002*AD	August 2007	001	50060	Chlorine, Total Residu	1D Conc	0.50	1.27	8/13/2007
0PX00002*AD	August 2007	001	50060	Chlorine, Total Residu	1D Conc	0.50	1.74	8/14/2007
0PX00002*AD	August 2007	001	50060	Chlorine, Total Residu	1D Conc	0.50	.94	8/28/2007
0PX00002*AD	September 2007	001	50060	Chlorine, Total Residu	1D Conc	0.50	.54	9/4/2007
0PX00002*AD	September 2007	001	50060	Chlorine, Total Residu	1D Conc	0.50	.7	9/6/2007
0PX00002*AD	May 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.11	5/1/2008
0PX00002*AD	May 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.14	5/2/2008
0PX00002*AD	May 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.11	5/3/2008
0PX00002*AD	May 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.09	5/4/2008
0PX00002*AD	May 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.1	5/5/2008
0PX00002*AD	May 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.12	5/6/2008
0PX00002*AD	May 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.57	5/7/2008
0PX00002*AD	May 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.44	5/8/2008
0PX00002*AD	May 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.29	5/9/2008
0PX00002*AD	May 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.17	5/10/2008
0PX00002*AD	May 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.26	5/14/2008
0PX00002*AD	May 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.4	5/15/2008
0PX00002*AD	May 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.36	5/16/2008
0PX00002*AD	May 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.25	5/17/2008
0PX00002*AD	May 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.15	5/18/2008
0PX00002*AD	May 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.16	5/19/2008
0PX00002*AD	May 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.17	5/20/2008
0PX00002*AD	May 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.13	5/21/2008
0PX00002*AD	May 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.53	5/22/2008
0PX00002*AD	May 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.47	5/23/2008
0PX00002*AD	May 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.38	5/24/2008
0PX00002*AD	May 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.24	5/25/2008
0PX00002*AD	May 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.27	5/26/2008
0PX00002*AD	May 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.55	5/27/2008
0PX00002*AD	May 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.44	5/29/2008
0PX00002*AD	May 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.26	5/30/2008
0PX00002*AD	May 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.46	5/31/2008
0PX00002*AD	June 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.5	6/1/2008
0PX00002*AD	June 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.42	6/2/2008
0PX00002*AD	June 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.58	6/3/2008
0PX00002*AD	June 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.85	6/4/2008
0PX00002*AD	June 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.76	6/5/2008
0PX00002*AD	June 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.51	6/6/2008
0PX00002*AD	June 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.28	6/7/2008
0PX00002*AD	June 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.35	6/8/2008
0PX00002*AD	June 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.71	6/9/2008
0PX00002*AD	June 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.7	6/10/2008
0PX00002*AD	June 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.32	6/11/2008
0PX00002*AD	June 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.34	6/12/2008
0PX00002*AD	June 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.3	6/13/2008
0PX00002*AD	June 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.33	6/14/2008
0PX00002*AD	June 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.14	6/15/2008
0PX00002*AD	June 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.12	6/16/2008
0PX00002*AD	June 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.49	6/17/2008

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
0PX00002*AD	June 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.27	6/18/2008
0PX00002*AD	June 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.44	6/19/2008
0PX00002*AD	June 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.36	6/20/2008
0PX00002*AD	June 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.3	6/21/2008
0PX00002*AD	June 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.39	6/22/2008
0PX00002*AD	June 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.4	6/23/2008
0PX00002*AD	June 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.25	6/24/2008
0PX00002*AD	June 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.1	6/25/2008
0PX00002*AD	June 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.48	6/26/2008
0PX00002*AD	June 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.8	6/27/2008
0PX00002*AD	June 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.62	6/28/2008
0PX00002*AD	June 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.73	6/29/2008
0PX00002*AD	June 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.36	6/30/2008
0PX00002*AD	July 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.56	7/1/2008
0PX00002*AD	July 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.32	7/2/2008
0PX00002*AD	July 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.83	7/3/2008
0PX00002*AD	July 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.94	7/4/2008
0PX00002*AD	July 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.56	7/5/2008
0PX00002*AD	July 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.16	7/6/2008
0PX00002*AD	July 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.26	7/7/2008
0PX00002*AD	July 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.6	7/8/2008
0PX00002*AD	July 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.48	7/9/2008
0PX00002*AD	July 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.31	7/10/2008
0PX00002*AD	July 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.62	7/11/2008
0PX00002*AD	July 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	1.14	7/12/2008
0PX00002*AD	July 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	7/13/2008
0PX00002*AD	July 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.08	7/14/2008
0PX00002*AD	July 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.21	7/15/2008
0PX00002*AD	July 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.86	7/16/2008
0PX00002*AD	July 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.53	7/17/2008
0PX00002*AD	July 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.8	7/18/2008
0PX00002*AD	July 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	1.51	7/19/2008
0PX00002*AD	July 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.8	7/20/2008
0PX00002*AD	July 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.94	7/21/2008
0PX00002*AD	July 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.44	7/22/2008
0PX00002*AD	July 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.6	7/23/2008
0PX00002*AD	July 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.44	7/24/2008
0PX00002*AD	July 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.46	7/25/2008
0PX00002*AD	July 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.73	7/26/2008
0PX00002*AD	July 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.69	7/27/2008
0PX00002*AD	July 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.06	7/28/2008
0PX00002*AD	July 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.32	7/29/2008
0PX00002*AD	July 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.09	7/30/2008
0PX00002*AD	July 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.15	7/31/2008
0PX00002*AD	October 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.12	10/1/2008
0PX00002*AD	October 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.4	10/2/2008
0PX00002*AD	October 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.19	10/3/2008
0PX00002*AD	October 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.14	10/4/2008
0PX00002*AD	October 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.11	10/5/2008
0PX00002*AD	October 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.11	10/6/2008
0PX00002*AD	October 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.16	10/7/2008
0PX00002*AD	October 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.26	10/8/2008
0PX00002*AD	October 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.12	10/9/2008
0PX00002*AD	October 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.25	10/10/2008
0PX00002*AD	October 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.18	10/11/2008
0PX00002*AD	October 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.16	10/12/2008
0PX00002*AD	October 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.09	10/13/2008
0PX00002*AD	October 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.2	10/14/2008
0PX00002*AD	October 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.31	10/15/2008

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
0PX00002*AD	October 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.35	10/16/2008
0PX00002*AD	October 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.4	10/17/2008
0PX00002*AD	October 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.53	10/18/2008
0PX00002*AD	October 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.38	10/19/2008
0PX00002*AD	October 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.37	10/20/2008
0PX00002*AD	October 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.12	10/21/2008
0PX00002*AD	October 2008	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	10/22/2008
0PX00002*AD	May 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.08	5/6/2009
0PX00002*AD	May 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.45	5/12/2009
0PX00002*AD	May 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.06	5/16/2009
0PX00002*AD	May 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.08	5/22/2009
0PX00002*AD	May 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.1	5/23/2009
0PX00002*AD	May 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.09	5/24/2009
0PX00002*AD	May 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.08	5/25/2009
0PX00002*AD	May 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	5/26/2009
0PX00002*AD	May 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.1	5/27/2009
0PX00002*AD	May 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	5/28/2009
0PX00002*AD	June 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.06	6/2/2009
0PX00002*AD	June 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.09	6/4/2009
0PX00002*AD	June 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.06	6/5/2009
0PX00002*AD	June 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	6/6/2009
0PX00002*AD	June 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.09	6/8/2009
0PX00002*AD	June 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.06	6/9/2009
0PX00002*AD	June 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.12	6/10/2009
0PX00002*AD	June 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.08	6/11/2009
0PX00002*AD	June 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.06	6/13/2009
0PX00002*AD	June 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.06	6/14/2009
0PX00002*AD	June 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.15	6/15/2009
0PX00002*AD	June 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.07	6/16/2009
0PX00002*AD	June 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.07	6/17/2009
0PX00002*AD	June 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	6/18/2009
0PX00002*AD	June 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.1	6/19/2009
0PX00002*AD	June 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.09	6/20/2009
0PX00002*AD	June 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.08	6/21/2009
0PX00002*AD	June 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.09	6/22/2009
0PX00002*AD	June 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.09	6/23/2009
0PX00002*AD	June 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.11	6/24/2009
0PX00002*AD	June 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.11	6/25/2009
0PX00002*AD	June 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.06	6/27/2009
0PX00002*AD	June 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	6/29/2009
0PX00002*AD	June 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	6/30/2009
0PX00002*AD	July 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	7/3/2009
0PX00002*AD	July 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	7/4/2009
0PX00002*AD	July 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.06	7/5/2009
0PX00002*AD	July 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	7/6/2009
0PX00002*AD	July 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.1	7/10/2009
0PX00002*AD	July 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.1	7/11/2009
0PX00002*AD	July 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.15	7/12/2009
0PX00002*AD	July 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.09	7/13/2009
0PX00002*AD	July 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.07	7/15/2009
0PX00002*AD	July 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	7/17/2009
0PX00002*AD	August 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.11	8/4/2009
0PX00002*AD	August 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.07	8/5/2009
0PX00002*AD	August 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.14	8/6/2009
0PX00002*AD	August 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.06	8/8/2009
0PX00002*AD	August 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	8/9/2009
0PX00002*AD	August 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.06	8/13/2009
0PX00002*AD	August 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	8/14/2009
0PX00002*AD	August 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	8/20/2009

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
0PX00002*AD	August 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	8/21/2009
0PX00002*AD	August 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.06	8/22/2009
0PX00002*AD	August 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	8/24/2009
0PX00002*AD	September 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.08	9/2/2009
0PX00002*AD	September 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.06	9/3/2009
0PX00002*AD	September 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.09	9/17/2009
0PX00002*AD	September 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.06	9/19/2009
0PX00002*AD	September 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	9/22/2009
0PX00002*AD	September 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.09	9/23/2009
0PX00002*AD	September 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.06	9/25/2009
0PX00002*AD	September 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.08	9/26/2009
0PX00002*AD	September 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.22	9/29/2009
0PX00002*AD	October 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.08	10/3/2009
0PX00002*AD	October 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.11	10/4/2009
0PX00002*AD	October 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.16	10/5/2009
0PX00002*AD	October 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.33	10/6/2009
0PX00002*AD	October 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.37	10/7/2009
0PX00002*AD	October 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.56	10/8/2009
0PX00002*AD	October 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.18	10/9/2009
0PX00002*AD	October 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.27	10/10/2009
0PX00002*AD	October 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.21	10/12/2009
0PX00002*AD	October 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.11	10/14/2009
0PX00002*AD	October 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.09	10/26/2009
0PX00002*AD	October 2009	001	50060	Chlorine, Total Residu	1D Conc	0.011	.07	10/27/2009
0PX00002*AD	May 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.07	5/4/2010
0PX00002*AD	May 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.07	5/5/2010
0PX00002*AD	May 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.06	5/6/2010
0PX00002*AD	May 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	5/7/2010
0PX00002*AD	May 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.07	5/8/2010
0PX00002*AD	May 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.07	5/9/2010
0PX00002*AD	May 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.07	5/10/2010
0PX00002*AD	May 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.06	5/11/2010
0PX00002*AD	May 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.06	5/12/2010
0PX00002*AD	May 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	5/13/2010
0PX00002*AD	May 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.06	5/14/2010
0PX00002*AD	May 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	5/15/2010
0PX00002*AD	May 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	5/16/2010
0PX00002*AD	May 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.08	5/17/2010
0PX00002*AD	May 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.1	5/18/2010
0PX00002*AD	June 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	6/1/2010
0PX00002*AD	June 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.06	6/7/2010
0PX00002*AD	June 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	6/11/2010
0PX00002*AD	July 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.06	7/9/2010
0PX00002*AD	July 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.11	7/10/2010
0PX00002*AD	July 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.08	7/11/2010
0PX00002*AD	July 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.1	7/12/2010
0PX00002*AD	July 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.08	7/13/2010
0PX00002*AD	July 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.06	7/14/2010
0PX00002*AD	July 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.07	7/21/2010
0PX00002*AD	July 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.06	7/22/2010
0PX00002*AD	July 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	7/24/2010
0PX00002*AD	July 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	7/25/2010
0PX00002*AD	July 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.06	7/27/2010
0PX00002*AD	July 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.07	7/28/2010
0PX00002*AD	July 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.06	7/29/2010
0PX00002*AD	July 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.06	7/30/2010
0PX00002*AD	July 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	7/31/2010
0PX00002*AD	August 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.06	8/1/2010
0PX00002*AD	August 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.18	8/3/2010

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
0PX00002*AD	August 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.08	8/4/2010
0PX00002*AD	August 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.08	8/5/2010
0PX00002*AD	August 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.06	8/6/2010
0PX00002*AD	August 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.06	8/7/2010
0PX00002*AD	August 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	8/8/2010
0PX00002*AD	August 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.06	8/9/2010
0PX00002*AD	August 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.06	8/10/2010
0PX00002*AD	August 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	8/11/2010
0PX00002*AD	August 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	8/15/2010
0PX00002*AD	August 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	8/16/2010
0PX00002*AD	August 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	8/18/2010
0PX00002*AD	August 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	8/19/2010
0PX00002*AD	August 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.19	8/21/2010
0PX00002*AD	August 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.06	8/25/2010
0PX00002*AD	August 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.27	8/28/2010
0PX00002*AD	August 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.2	8/29/2010
0PX00002*AD	August 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.08	8/30/2010
0PX00002*AD	August 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.1	8/31/2010
0PX00002*AD	September 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	9/4/2010
0PX00002*AD	September 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	9/10/2010
0PX00002*AD	September 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	9/11/2010
0PX00002*AD	September 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.39	9/15/2010
0PX00002*AD	September 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.1	9/25/2010
0PX00002*AD	September 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.09	9/26/2010
0PX00002*AD	September 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.26	9/27/2010
0PX00002*AD	September 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.09	9/28/2010
0PX00002*AD	September 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.06	9/29/2010
0PX00002*AD	September 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.06	9/30/2010
0PX00002*AD	October 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.37	10/1/2010
0PX00002*AD	October 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.31	10/2/2010
0PX00002*AD	October 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.25	10/3/2010
0PX00002*AD	October 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.58	10/4/2010
0PX00002*AD	October 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.55	10/5/2010
0PX00002*AD	October 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.12	10/6/2010
0PX00002*AD	October 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.48	10/17/2010
0PX00002*AD	October 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.31	10/18/2010
0PX00002*AD	October 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.18	10/19/2010
0PX00002*AD	October 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.11	10/20/2010
0PX00002*AD	October 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.21	10/21/2010
0PX00002*AD	October 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.1	10/22/2010
0PX00002*AD	October 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.11	10/23/2010
0PX00002*AD	October 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.18	10/24/2010
0PX00002*AD	October 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.26	10/25/2010
0PX00002*AD	October 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.2	10/27/2010
0PX00002*AD	October 2010	001	50060	Chlorine, Total Residu	1D Conc	0.011	.14	10/28/2010
0PX00002*AD	May 2011	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	5/15/2011
0PX00002*AD	May 2011	001	50060	Chlorine, Total Residu	1D Conc	0.011	.09	5/16/2011
0PX00002*AD	May 2011	001	50060	Chlorine, Total Residu	1D Conc	0.011	.06	5/18/2011
0PX00002*AD	May 2011	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	5/20/2011
0PX00002*AD	May 2011	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	5/21/2011
0PX00002*AD	May 2011	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	5/23/2011
0PX00002*AD	May 2011	001	50060	Chlorine, Total Residu	1D Conc	0.011	.06	5/29/2011
0PX00002*AD	May 2011	001	50060	Chlorine, Total Residu	1D Conc	0.011	.08	5/30/2011
0PX00002*AD	June 2011	001	50060	Chlorine, Total Residu	1D Conc	0.011	.1	6/16/2011
0PX00002*AD	June 2011	001	50060	Chlorine, Total Residu	1D Conc	0.011	.08	6/17/2011
0PX00002*AD	July 2011	001	50060	Chlorine, Total Residu	1D Conc	0.011	.09	7/3/2011
0PX00002*AD	July 2011	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	7/7/2011
0PX00002*AD	July 2011	001	50060	Chlorine, Total Residu	1D Conc	0.011	.14	7/8/2011
0PX00002*AD	July 2011	001	50060	Chlorine, Total Residu	1D Conc	0.011	.09	7/9/2011

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
0PX00002*AD	July 2011	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	7/10/2011
0PX00002*AD	July 2011	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	7/12/2011
0PX00002*AD	July 2011	001	50060	Chlorine, Total Residu	1D Conc	0.011	.14	7/24/2011
0PX00002*AD	July 2011	001	50060	Chlorine, Total Residu	1D Conc	0.011	.12	7/26/2011
0PX00002*AD	July 2011	001	50060	Chlorine, Total Residu	1D Conc	0.011	.09	7/27/2011
0PX00002*AD	July 2011	001	50060	Chlorine, Total Residu	1D Conc	0.011	.06	7/28/2011
0PX00002*AD	August 2011	001	50060	Chlorine, Total Residu	1D Conc	0.011	.06	8/4/2011
0PX00002*AD	August 2011	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	8/5/2011
0PX00002*AD	August 2011	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	8/17/2011
0PX00002*AD	August 2011	001	50060	Chlorine, Total Residu	1D Conc	0.011	.06	8/18/2011
0PX00002*AD	August 2011	001	50060	Chlorine, Total Residu	1D Conc	0.011	.09	8/20/2011
0PX00002*AD	August 2011	001	50060	Chlorine, Total Residu	1D Conc	0.011	.12	8/30/2011
0PX00002*AD	September 2011	001	50060	Chlorine, Total Residu	1D Conc	0.011	.06	9/1/2011
0PX00002*AD	September 2011	001	50060	Chlorine, Total Residu	1D Conc	0.011	.06	9/4/2011
0PX00002*AD	September 2011	001	50060	Chlorine, Total Residu	1D Conc	0.011	.11	9/8/2011
0PX00002*AD	September 2011	001	50060	Chlorine, Total Residu	1D Conc	0.011	.08	9/9/2011
0PX00002*AD	September 2011	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	9/10/2011
0PX00002*AD	September 2011	001	50060	Chlorine, Total Residu	1D Conc	0.011	.07	9/11/2011
0PX00002*AD	September 2011	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	9/12/2011
0PX00002*AD	September 2011	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	9/13/2011
0PX00002*AD	September 2011	001	50060	Chlorine, Total Residu	1D Conc	0.011	.08	9/23/2011
0PX00002*AD	September 2011	001	50060	Chlorine, Total Residu	1D Conc	0.011	.07	9/24/2011
0PX00002*AD	September 2011	001	50060	Chlorine, Total Residu	1D Conc	0.011	.08	9/25/2011
0PX00002*AD	September 2011	001	50060	Chlorine, Total Residu	1D Conc	0.011	.17	9/26/2011
0PX00002*AD	September 2011	001	50060	Chlorine, Total Residu	1D Conc	0.011	.06	9/28/2011
0PX00002*AD	October 2011	001	50060	Chlorine, Total Residu	1D Conc	0.011	.12	10/4/2011
0PX00002*AD	October 2011	001	50060	Chlorine, Total Residu	1D Conc	0.011	.09	10/5/2011
0PX00002*AD	October 2011	001	50060	Chlorine, Total Residu	1D Conc	0.011	.1	10/6/2011
0PX00002*AD	October 2011	001	50060	Chlorine, Total Residu	1D Conc	0.011	.08	10/9/2011
0PX00002*AD	October 2011	001	50060	Chlorine, Total Residu	1D Conc	0.011	.06	10/10/2011
0PX00002*AD	October 2011	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	10/12/2011
0PX00002*AD	October 2011	001	50060	Chlorine, Total Residu	1D Conc	0.011	.06	10/13/2011
0PX00002*AD	October 2011	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	10/15/2011
0PX00002*AD	October 2011	001	50060	Chlorine, Total Residu	1D Conc	0.011	.06	10/16/2011
0PX00002*AD	October 2011	001	50060	Chlorine, Total Residu	1D Conc	0.011	.14	10/17/2011
0PX00002*AD	October 2011	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	10/18/2011
0PX00002*AD	October 2011	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	10/19/2011
0PX00002*AD	October 2011	001	50060	Chlorine, Total Residu	1D Conc	0.011	.11	10/26/2011
0PX00002*AD	October 2011	001	50060	Chlorine, Total Residu	1D Conc	0.011	.1	10/27/2011
0PX00002*AD	October 2011	001	50060	Chlorine, Total Residu	1D Conc	0.011	.09	10/28/2011
0PX00002*AD	October 2011	001	50060	Chlorine, Total Residu	1D Conc	0.011	.15	10/29/2011
0PX00002*AD	May 2012	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	5/3/2012
0PX00002*AD	May 2012	001	50060	Chlorine, Total Residu	1D Conc	0.011	.07	5/7/2012
0PX00002*AD	May 2012	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	5/8/2012
0PX00002*AD	May 2012	001	50060	Chlorine, Total Residu	1D Conc	0.011	.06	5/9/2012
0PX00002*AD	May 2012	001	50060	Chlorine, Total Residu	1D Conc	0.011	.08	5/11/2012
0PX00002*AD	May 2012	001	50060	Chlorine, Total Residu	1D Conc	0.011	.07	5/12/2012
0PX00002*AD	May 2012	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	5/13/2012
0PX00002*AD	May 2012	001	50060	Chlorine, Total Residu	1D Conc	0.011	1.	5/15/2012
0PX00002*AD	May 2012	001	50060	Chlorine, Total Residu	1D Conc	0.011	.06	5/16/2012
0PX00002*AD	May 2012	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	5/17/2012
0PX00002*AD	May 2012	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	5/28/2012
0PX00002*AD	June 2012	001	50060	Chlorine, Total Residu	1D Conc	0.011	.14	6/2/2012
0PX00002*AD	June 2012	001	50060	Chlorine, Total Residu	1D Conc	0.011	.08	6/3/2012
0PX00002*AD	June 2012	001	50060	Chlorine, Total Residu	1D Conc	0.011	.15	6/4/2012
0PX00002*AD	June 2012	001	50060	Chlorine, Total Residu	1D Conc	0.011	.07	6/6/2012
0PX00002*AD	June 2012	001	50060	Chlorine, Total Residu	1D Conc	0.011	.08	6/17/2012
0PX00002*AD	June 2012	001	50060	Chlorine, Total Residu	1D Conc	0.011	.07	6/22/2012
0PX00002*AD	June 2012	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	6/23/2012

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
0PX00002*AD	June 2012	001	50060	Chlorine, Total Residu	1D Conc	0.011	.08	6/24/2012
0PX00002*AD	June 2012	001	50060	Chlorine, Total Residu	1D Conc	0.011	.1	6/26/2012
0PX00002*AD	June 2012	001	50060	Chlorine, Total Residu	1D Conc	0.011	.05	6/27/2012
0PX00002*AD	July 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	5.9	7/3/2005
0PX00002*AD	July 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	5.5	7/4/2005
0PX00002*AD	July 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	5.7	7/5/2005
0PX00002*AD	July 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	5.3	7/6/2005
0PX00002*AD	July 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	5.4	7/7/2005
0PX00002*AD	July 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	5.6	7/8/2005
0PX00002*AD	July 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	5.6	7/9/2005
0PX00002*AD	July 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	5.7	7/10/2005
0PX00002*AD	July 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	5.4	7/12/2005
0PX00002*AD	July 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	5.6	7/13/2005
0PX00002*AD	July 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	5.2	7/14/2005
0PX00002*AD	July 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	5.3	7/15/2005
0PX00002*AD	July 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	5.3	7/16/2005
0PX00002*AD	July 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	5.8	7/18/2005
0PX00002*AD	July 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	5.8	7/19/2005
0PX00002*AD	July 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	5.7	7/21/2005
0PX00002*AD	August 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	5.7	8/4/2005
0PX00002*AD	August 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	5.9	8/9/2005
0PX00002*AD	August 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	5.8	8/11/2005
0PX00002*AD	August 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	5.6	8/12/2005
0PX00002*AD	August 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	5.8	8/13/2005
0PX00002*AD	August 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	5.7	8/14/2005
0PX00002*AD	August 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	5.7	8/15/2005
0PX00002*AD	August 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	5.8	8/17/2005
0PX00002*AD	August 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	5.8	8/18/2005
0PX00002*AD	August 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	5.8	8/19/2005
0PX00002*AD	August 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	5.	8/20/2005
0PX00002*AD	August 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	4.9	8/21/2005
0PX00002*AD	August 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	4.7	8/22/2005
0PX00002*AD	August 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	4.9	8/23/2005
0PX00002*AD	August 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	5.4	8/24/2005
0PX00002*AD	August 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	5.5	8/25/2005
0PX00002*AD	August 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	5.8	8/26/2005
0PX00002*AD	August 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	5.5	8/27/2005
0PX00002*AD	August 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	5.8	8/30/2005
0PX00002*AD	August 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	5.7	8/31/2005
0PX00002*AD	September 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	5.5	9/1/2005
0PX00002*AD	September 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	5.7	9/2/2005
0PX00002*AD	September 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	5.7	9/3/2005
0PX00002*AD	September 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	5.6	9/4/2005
0PX00002*AD	September 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	5.5	9/5/2005
0PX00002*AD	September 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	5.1	9/6/2005
0PX00002*AD	September 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	4.9	9/7/2005
0PX00002*AD	September 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	5.2	9/8/2005
0PX00002*AD	September 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	4.4	9/9/2005
0PX00002*AD	September 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	3.7	9/10/2005
0PX00002*AD	September 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	3.7	9/11/2005
0PX00002*AD	September 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	2.8	9/12/2005
0PX00002*AD	September 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	2.5	9/13/2005
0PX00002*AD	September 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	2.2	9/14/2005
0PX00002*AD	September 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	1.7	9/15/2005
0PX00002*AD	September 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	1.3	9/16/2005
0PX00002*AD	September 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	1.2	9/17/2005
0PX00002*AD	September 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	1.1	9/18/2005
0PX00002*AD	September 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	1.	9/19/2005
0PX00002*AD	September 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	1.1	9/20/2005

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
0PX00002*AD	September 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	1.1	9/21/2005
0PX00002*AD	September 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	1.	9/22/2005
0PX00002*AD	September 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	.9	9/23/2005
0PX00002*AD	September 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	1.	9/24/2005
0PX00002*AD	September 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	1.	9/25/2005
0PX00002*AD	September 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	.9	9/26/2005
0PX00002*AD	September 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	.9	9/27/2005
0PX00002*AD	May 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	5.2	5/7/2006
0PX00002*AD	May 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	5.8	5/28/2006
0PX00002*AD	May 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	5.6	5/29/2006
0PX00002*AD	May 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	4.8	5/30/2006
0PX00002*AD	May 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	4.	5/31/2006
0PX00002*AD	June 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	3.8	6/1/2006
0PX00002*AD	June 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	4.5	6/2/2006
0PX00002*AD	June 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	4.1	6/3/2006
0PX00002*AD	June 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	4.9	6/4/2006
0PX00002*AD	June 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	5.4	6/5/2006
0PX00002*AD	June 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	4.7	6/6/2006
0PX00002*AD	June 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	3.6	6/7/2006
0PX00002*AD	June 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	4.5	6/8/2006
0PX00002*AD	June 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	4.2	6/9/2006
0PX00002*AD	June 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	4.1	6/10/2006
0PX00002*AD	June 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	4.8	6/11/2006
0PX00002*AD	June 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	5.	6/12/2006
0PX00002*AD	June 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	4.4	6/13/2006
0PX00002*AD	June 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	4.6	6/14/2006
0PX00002*AD	June 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	4.	6/15/2006
0PX00002*AD	June 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	3.9	6/16/2006
0PX00002*AD	June 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	4.2	6/17/2006
0PX00002*AD	June 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	5.2	6/18/2006
0PX00002*AD	June 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	4.5	6/19/2006
0PX00002*AD	June 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	3.9	6/20/2006
0PX00002*AD	June 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	3.3	6/21/2006
0PX00002*AD	June 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	5.	6/22/2006
0PX00002*AD	June 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	4.8	6/23/2006
0PX00002*AD	June 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	4.5	6/24/2006
0PX00002*AD	June 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	4.5	6/25/2006
0PX00002*AD	June 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	4.2	6/26/2006
0PX00002*AD	June 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	3.2	6/27/2006
0PX00002*AD	June 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	3.9	6/28/2006
0PX00002*AD	June 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	3.8	6/29/2006
0PX00002*AD	June 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	3.	6/30/2006
0PX00002*AD	July 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	3.8	7/1/2006
0PX00002*AD	July 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	3.8	7/2/2006
0PX00002*AD	July 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	3.8	7/3/2006
0PX00002*AD	July 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	3.3	7/4/2006
0PX00002*AD	July 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	3.7	7/5/2006
0PX00002*AD	July 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	5.4	7/6/2006
0PX00002*AD	July 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	4.4	7/7/2006
0PX00002*AD	July 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	4.3	7/8/2006
0PX00002*AD	July 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	4.	7/9/2006
0PX00002*AD	July 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	4.6	7/10/2006
0PX00002*AD	July 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	3.8	7/11/2006
0PX00002*AD	July 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	4.7	7/12/2006
0PX00002*AD	July 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	4.9	7/13/2006
0PX00002*AD	July 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	4.2	7/14/2006
0PX00002*AD	July 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	4.2	7/15/2006
0PX00002*AD	July 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	4.5	7/16/2006
0PX00002*AD	July 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	4.2	7/17/2006

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
0PX00002*AD	July 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	2.9	7/18/2006
0PX00002*AD	July 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	3.7	7/19/2006
0PX00002*AD	July 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	3.6	7/20/2006
0PX00002*AD	July 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	3.2	7/21/2006
0PX00002*AD	July 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	2.7	7/22/2006
0PX00002*AD	July 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	3.5	7/23/2006
0PX00002*AD	July 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	4.1	7/24/2006
0PX00002*AD	July 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	3.7	7/25/2006
0PX00002*AD	July 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	2.4	7/26/2006
0PX00002*AD	July 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	3.4	7/27/2006
0PX00002*AD	July 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	4.	7/28/2006
0PX00002*AD	July 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	3.3	7/29/2006
0PX00002*AD	July 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	2.5	7/30/2006
0PX00002*AD	July 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	3.	7/31/2006
0PX00002*AD	August 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	2.8	8/1/2006
0PX00002*AD	August 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	1.7	8/2/2006
0PX00002*AD	August 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	1.4	8/3/2006
0PX00002*AD	August 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	3.1	8/4/2006
0PX00002*AD	August 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	2.	8/5/2006
0PX00002*AD	August 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	5.3	8/6/2006
0PX00002*AD	August 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	4.8	8/7/2006
0PX00002*AD	August 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	2.9	8/8/2006
0PX00002*AD	August 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	3.9	8/9/2006
0PX00002*AD	August 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	5.	8/10/2006
0PX00002*AD	August 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	5.3	8/11/2006
0PX00002*AD	August 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	5.6	8/12/2006
0PX00002*AD	August 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	5.7	8/14/2006
0PX00002*AD	August 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	5.2	8/15/2006
0PX00002*AD	August 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	4.8	8/16/2006
0PX00002*AD	August 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	3.2	8/18/2006
0PX00002*AD	August 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	4.6	8/19/2006
0PX00002*AD	August 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	5.5	8/20/2006
0PX00002*AD	August 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	5.6	8/21/2006
0PX00002*AD	August 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	5.4	8/22/2006
0PX00002*AD	August 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	5.5	8/24/2006
0PX00002*AD	August 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	5.5	8/25/2006
0PX00002*AD	August 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	2.4	8/26/2006
0PX00002*AD	August 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	5.6	8/28/2006
0PX00002*AD	August 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	5.6	8/29/2006
0PX00002*AD	August 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	5.8	8/30/2006
0PX00002*AD	August 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	5.9	8/31/2006
0PX00002*AD	September 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	5.9	9/7/2006
0PX00002*AD	September 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	5.3	9/12/2006
0PX00002*AD	September 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	3.4	9/13/2006
0PX00002*AD	September 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	5.8	9/15/2006
0PX00002*AD	September 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	3.6	9/22/2006
0PX00002*AD	September 2006	001	00300	Dissolved Oxygen	1D Conc	6.0	5.6	9/27/2006
0PX00002*AD	June 2007	001	00300	Dissolved Oxygen	1D Conc	6.0	5.7	6/17/2007
0PX00002*AD	July 2007	001	00300	Dissolved Oxygen	1D Conc	6.0	4.01	7/8/2007
0PX00002*AD	July 2007	001	00300	Dissolved Oxygen	1D Conc	6.0	5.65	7/9/2007
0PX00002*AD	July 2007	001	00300	Dissolved Oxygen	1D Conc	6.0	3.77	7/10/2007
0PX00002*AD	July 2007	001	00300	Dissolved Oxygen	1D Conc	6.0	5.65	7/11/2007
0PX00002*AD	July 2007	001	00300	Dissolved Oxygen	1D Conc	6.0	5.97	7/13/2007
0PX00002*AD	July 2007	001	00300	Dissolved Oxygen	1D Conc	6.0	4.86	7/15/2007
0PX00002*AD	July 2007	001	00300	Dissolved Oxygen	1D Conc	6.0	5.96	7/16/2007
0PX00002*AD	July 2007	001	00300	Dissolved Oxygen	1D Conc	6.0	4.86	7/17/2007
0PX00002*AD	July 2007	001	00300	Dissolved Oxygen	1D Conc	6.0	4.99	7/18/2007
0PX00002*AD	July 2007	001	00300	Dissolved Oxygen	1D Conc	6.0	5.17	7/29/2007
0PX00002*AD	July 2007	001	00300	Dissolved Oxygen	1D Conc	6.0	4.83	7/30/2007

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
0PX00002*AD	August 2007	001	00300	Dissolved Oxygen	1D Conc	6.0	4.73	8/1/2007
0PX00002*AD	August 2007	001	00300	Dissolved Oxygen	1D Conc	6.0	5.82	8/6/2007
0PX00002*AD	August 2007	001	00300	Dissolved Oxygen	1D Conc	6.0	5.07	8/7/2007
0PX00002*AD	August 2007	001	00300	Dissolved Oxygen	1D Conc	6.0	5.8	8/8/2007
0PX00002*AD	August 2007	001	00300	Dissolved Oxygen	1D Conc	6.0	5.82	8/9/2007
0PX00002*AD	August 2007	001	00300	Dissolved Oxygen	1D Conc	6.0	2.71	8/10/2007
0PX00002*AD	August 2007	001	00300	Dissolved Oxygen	1D Conc	6.0	5.47	8/11/2007
0PX00002*AD	August 2007	001	00300	Dissolved Oxygen	1D Conc	6.0	3.59	8/12/2007
0PX00002*AD	August 2007	001	00300	Dissolved Oxygen	1D Conc	6.0	5.49	8/13/2007
0PX00002*AD	August 2007	001	00300	Dissolved Oxygen	1D Conc	6.0	5.99	8/14/2007
0PX00002*AD	August 2007	001	00300	Dissolved Oxygen	1D Conc	6.0	5.84	8/16/2007
0PX00002*AD	August 2007	001	00300	Dissolved Oxygen	1D Conc	6.0	5.1	8/17/2007
0PX00002*AD	August 2007	001	00300	Dissolved Oxygen	1D Conc	6.0	4.5	8/18/2007
0PX00002*AD	August 2007	001	00300	Dissolved Oxygen	1D Conc	6.0	3.51	8/19/2007
0PX00002*AD	August 2007	001	00300	Dissolved Oxygen	1D Conc	6.0	3.44	8/20/2007
0PX00002*AD	August 2007	001	00300	Dissolved Oxygen	1D Conc	6.0	3.43	8/21/2007
0PX00002*AD	August 2007	001	00300	Dissolved Oxygen	1D Conc	6.0	5.87	8/25/2007
0PX00002*AD	August 2007	001	00300	Dissolved Oxygen	1D Conc	6.0	5.8	8/27/2007
0PX00002*AD	August 2007	001	00300	Dissolved Oxygen	1D Conc	6.0	5.	8/30/2007
0PX00002*AD	August 2007	001	00300	Dissolved Oxygen	1D Conc	6.0	5.73	8/31/2007
0PX00002*AD	September 2007	001	00300	Dissolved Oxygen	1D Conc	6.0	5.63	9/1/2007
0PX00002*AD	September 2007	001	00300	Dissolved Oxygen	1D Conc	6.0	5.4	9/7/2007
0PX00002*AD	September 2007	001	00300	Dissolved Oxygen	1D Conc	6.0	5.1	9/8/2007
0PX00002*AD	September 2007	001	00300	Dissolved Oxygen	1D Conc	6.0	5.26	9/9/2007
0PX00002*AD	September 2007	001	00300	Dissolved Oxygen	1D Conc	6.0	4.52	9/10/2007
0PX00002*AD	September 2007	001	00300	Dissolved Oxygen	1D Conc	6.0	2.5	9/15/2007
0PX00002*AD	September 2007	001	00300	Dissolved Oxygen	1D Conc	6.0	4.44	9/16/2007
0PX00002*AD	June 2008	001	00300	Dissolved Oxygen	1D Conc	6.0	5.9	6/7/2008
0PX00002*AD	June 2008	001	00300	Dissolved Oxygen	1D Conc	6.0	5.9	6/10/2008
0PX00002*AD	July 2008	001	00300	Dissolved Oxygen	1D Conc	6.0	4.98	7/7/2008
0PX00002*AD	July 2008	001	00300	Dissolved Oxygen	1D Conc	6.0	5.65	7/9/2008
0PX00002*AD	July 2008	001	00300	Dissolved Oxygen	1D Conc	6.0	5.35	7/10/2008
0PX00002*AD	July 2008	001	00300	Dissolved Oxygen	1D Conc	6.0	5.47	7/11/2008
0PX00002*AD	July 2008	001	00300	Dissolved Oxygen	1D Conc	6.0	5.93	7/12/2008
0PX00002*AD	July 2008	001	00300	Dissolved Oxygen	1D Conc	6.0	5.52	7/13/2008
0PX00002*AD	July 2009	001	00300	Dissolved Oxygen	1D Conc	6.0	5.37	7/14/2009
0PX00002*AD	July 2009	001	00300	Dissolved Oxygen	1D Conc	6.0	4.99	7/16/2009
0PX00002*AD	August 2009	001	00300	Dissolved Oxygen	1D Conc	6.0	5.82	8/2/2009
0PX00002*AD	August 2009	001	00300	Dissolved Oxygen	1D Conc	6.0	5.84	8/3/2009
0PX00002*AD	August 2009	001	00300	Dissolved Oxygen	1D Conc	6.0	5.42	8/4/2009
0PX00002*AD	August 2009	001	00300	Dissolved Oxygen	1D Conc	6.0	5.36	8/5/2009
0PX00002*AD	August 2009	001	00300	Dissolved Oxygen	1D Conc	6.0	5.72	8/6/2009
0PX00002*AD	August 2009	001	00300	Dissolved Oxygen	1D Conc	6.0	5.77	8/11/2009
0PX00002*AD	August 2009	001	00300	Dissolved Oxygen	1D Conc	6.0	5.82	8/14/2009
0PX00002*AD	August 2009	001	00300	Dissolved Oxygen	1D Conc	6.0	4.74	8/17/2009
0PX00002*AD	August 2009	001	00300	Dissolved Oxygen	1D Conc	6.0	4.98	8/18/2009
0PX00002*AD	August 2009	001	00300	Dissolved Oxygen	1D Conc	6.0	5.02	8/19/2009
0PX00002*AD	August 2009	001	00300	Dissolved Oxygen	1D Conc	6.0	4.88	8/20/2009
0PX00002*AD	August 2009	001	00300	Dissolved Oxygen	1D Conc	6.0	5.11	8/21/2009
0PX00002*AD	August 2009	001	00300	Dissolved Oxygen	1D Conc	6.0	5.39	8/22/2009
0PX00002*AD	August 2009	001	00300	Dissolved Oxygen	1D Conc	6.0	5.8	8/24/2009
0PX00002*AD	August 2009	001	00300	Dissolved Oxygen	1D Conc	6.0	5.42	8/25/2009
0PX00002*AD	August 2009	001	00300	Dissolved Oxygen	1D Conc	6.0	5.02	8/26/2009
0PX00002*AD	August 2009	001	00300	Dissolved Oxygen	1D Conc	6.0	4.88	8/27/2009
0PX00002*AD	August 2009	001	00300	Dissolved Oxygen	1D Conc	6.0	5.07	8/28/2009
0PX00002*AD	August 2009	001	00300	Dissolved Oxygen	1D Conc	6.0	5.16	8/29/2009
0PX00002*AD	August 2009	001	00300	Dissolved Oxygen	1D Conc	6.0	5.07	8/30/2009
0PX00002*AD	August 2009	001	00300	Dissolved Oxygen	1D Conc	6.0	5.09	8/31/2009
0PX00002*AD	September 2009	001	00300	Dissolved Oxygen	1D Conc	6.0	5.28	9/6/2009

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
0PX00002*AD	September 2009	001	00300	Dissolved Oxygen	1D Conc	6.0	5.87	9/9/2009
0PX00002*AD	September 2009	001	00300	Dissolved Oxygen	1D Conc	6.0	3.92	9/10/2009
0PX00002*AD	September 2009	001	00300	Dissolved Oxygen	1D Conc	6.0	5.11	9/11/2009
0PX00002*AD	September 2009	001	00300	Dissolved Oxygen	1D Conc	6.0	5.44	9/12/2009
0PX00002*AD	September 2009	001	00300	Dissolved Oxygen	1D Conc	6.0	5.71	9/14/2009
0PX00002*AD	September 2009	001	00300	Dissolved Oxygen	1D Conc	6.0	2.26	9/15/2009
0PX00002*AD	September 2009	001	00300	Dissolved Oxygen	1D Conc	6.0	2.35	9/16/2009
0PX00002*AD	September 2009	001	00300	Dissolved Oxygen	1D Conc	6.0	2.44	9/17/2009
0PX00002*AD	September 2009	001	00300	Dissolved Oxygen	1D Conc	6.0	4.56	9/18/2009
0PX00002*AD	September 2009	001	00300	Dissolved Oxygen	1D Conc	6.0	4.02	9/19/2009
0PX00002*AD	September 2009	001	00300	Dissolved Oxygen	1D Conc	6.0	2.36	9/20/2009
0PX00002*AD	September 2009	001	00300	Dissolved Oxygen	1D Conc	6.0	1.71	9/21/2009
0PX00002*AD	September 2009	001	00300	Dissolved Oxygen	1D Conc	6.0	1.3	9/22/2009
0PX00002*AD	August 2010	001	00300	Dissolved Oxygen	1D Conc	6.0	4.16	8/27/2010
0PX00002*AD	August 2010	001	00300	Dissolved Oxygen	1D Conc	6.0	3.8	8/28/2010
0PX00002*AD	August 2010	001	00300	Dissolved Oxygen	1D Conc	6.0	4.12	8/29/2010
0PX00002*AD	August 2010	001	00300	Dissolved Oxygen	1D Conc	6.0	5.97	8/31/2010
0PX00002*AD	February 2011	001	00300	Dissolved Oxygen	1D Conc	6.0	3.31	2/18/2011
0PX00002*AD	April 2011	001	00300	Dissolved Oxygen	1D Conc	6.0	5.56	4/5/2011
0PX00002*AD	May 2011	001	00300	Dissolved Oxygen	1D Conc	6.0	4.71	5/27/2011
0PX00002*AD	May 2011	001	00300	Dissolved Oxygen	1D Conc	6.0	3.98	5/28/2011
0PX00002*AD	May 2011	001	00300	Dissolved Oxygen	1D Conc	6.0	3.56	5/29/2011
0PX00002*AD	May 2011	001	00300	Dissolved Oxygen	1D Conc	6.0	2.1	5/30/2011
0PX00002*AD	June 2011	001	00300	Dissolved Oxygen	1D Conc	6.0	5.84	6/8/2011
0PX00002*AD	June 2011	001	00300	Dissolved Oxygen	1D Conc	6.0	4.47	6/9/2011
0PX00002*AD	June 2011	001	00300	Dissolved Oxygen	1D Conc	6.0	3.16	6/28/2011
0PX00002*AD	July 2011	001	00300	Dissolved Oxygen	1D Conc	6.0	3.66	7/8/2011
0PX00002*AD	July 2011	001	00300	Dissolved Oxygen	1D Conc	6.0	5.38	7/9/2011
0PX00002*AD	July 2011	001	00300	Dissolved Oxygen	1D Conc	6.0	5.92	7/10/2011
0PX00002*AD	July 2011	001	00300	Dissolved Oxygen	1D Conc	6.0	3.61	7/13/2011
0PX00002*AD	July 2011	001	00300	Dissolved Oxygen	1D Conc	6.0	3.41	7/14/2011
0PX00002*AD	July 2011	001	00300	Dissolved Oxygen	1D Conc	6.0	4.46	7/15/2011
0PX00002*AD	July 2011	001	00300	Dissolved Oxygen	1D Conc	6.0	5.27	7/16/2011
0PX00002*AD	July 2011	001	00300	Dissolved Oxygen	1D Conc	6.0	5.54	7/17/2011
0PX00002*AD	July 2011	001	00300	Dissolved Oxygen	1D Conc	6.0	5.6	7/18/2011
0PX00002*AD	July 2011	001	00300	Dissolved Oxygen	1D Conc	6.0	4.72	7/22/2011
0PX00002*AD	July 2011	001	00300	Dissolved Oxygen	1D Conc	6.0	5.01	7/27/2011
0PX00002*AD	August 2011	001	00300	Dissolved Oxygen	1D Conc	6.0	3.07	8/1/2011
0PX00002*AD	August 2011	001	00300	Dissolved Oxygen	1D Conc	6.0	5.35	8/4/2011
0PX00002*AD	August 2011	001	00300	Dissolved Oxygen	1D Conc	6.0	4.44	8/5/2011
0PX00002*AD	August 2011	001	00300	Dissolved Oxygen	1D Conc	6.0	5.46	8/6/2011
0PX00002*AD	August 2011	001	00300	Dissolved Oxygen	1D Conc	6.0	5.38	8/7/2011
0PX00002*AD	August 2011	001	00300	Dissolved Oxygen	1D Conc	6.0	5.63	8/8/2011
0PX00002*AD	August 2011	001	00300	Dissolved Oxygen	1D Conc	6.0	3.49	8/11/2011
0PX00002*AD	August 2011	001	00300	Dissolved Oxygen	1D Conc	6.0	4.2	8/12/2011
0PX00002*AD	August 2011	001	00300	Dissolved Oxygen	1D Conc	6.0	5.88	8/15/2011
0PX00002*AD	August 2011	001	00300	Dissolved Oxygen	1D Conc	6.0	5.8	8/19/2011
0PX00002*AD	August 2011	001	00300	Dissolved Oxygen	1D Conc	6.0	5.82	8/22/2011
0PX00002*AD	September 2011	001	00300	Dissolved Oxygen	1D Conc	6.0	.08	9/8/2011
0PX00002*AD	September 2011	001	00300	Dissolved Oxygen	1D Conc	6.0	2.73	9/9/2011
0PX00002*AD	September 2011	001	00300	Dissolved Oxygen	1D Conc	6.0	3.1	9/10/2011
0PX00002*AD	September 2011	001	00300	Dissolved Oxygen	1D Conc	6.0	3.34	9/11/2011
0PX00002*AD	September 2011	001	00300	Dissolved Oxygen	1D Conc	6.0	4.25	9/12/2011
0PX00002*AD	September 2011	001	00300	Dissolved Oxygen	1D Conc	6.0	5.13	9/13/2011
0PX00002*AD	June 2012	001	00300	Dissolved Oxygen	1D Conc	6.0	4.4	6/7/2012
0PX00002*AD	June 2012	001	00300	Dissolved Oxygen	1D Conc	6.0	5.77	6/10/2012
0PX00002*AD	June 2012	001	00300	Dissolved Oxygen	1D Conc	6.0	2.13	6/27/2012
0PX00002*AD	September 2005	001	31616	Fecal Coliform	7D Conc	400	7300.	9/1/2005
0PX00002*AD	October 2005	001	31616	Fecal Coliform	7D Conc	400	450.	10/8/2005

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
0PX00002*AD	July 2006	001	31616	Fecal Coliform	7D Conc	400	2200.	7/1/2006
0PX00002*AD	August 2006	001	31616	Fecal Coliform	30D Conc	200	358.866	8/1/2006
0PX00002*AD	August 2006	001	31616	Fecal Coliform	7D Conc	400	480.	8/8/2006
0PX00002*AD	August 2006	001	31616	Fecal Coliform	7D Conc	400	2074.99	8/22/2006
0PX00002*AD	September 2006	001	31616	Fecal Coliform	7D Conc	400	520.	9/8/2006
0PX00002*AD	September 2006	001	31616	Fecal Coliform	7D Conc	400	4300.	9/15/2006
0PX00002*AD	October 2006	001	31616	Fecal Coliform	30D Conc	200	352.278	10/1/2006
0PX00002*AD	October 2006	001	31616	Fecal Coliform	7D Conc	400	3100.	10/8/2006
0PX00002*AD	October 2006	001	31616	Fecal Coliform	7D Conc	400	10800.	10/15/2006
0PX00002*AD	October 2006	001	31616	Fecal Coliform	7D Conc	400	460.	10/22/2006
0PX00002*AD	May 2007	001	31616	Fecal Coliform	30D Conc	200	259.970	5/1/2007
0PX00002*AD	May 2007	001	31616	Fecal Coliform	7D Conc	400	8000.	5/1/2007
0PX00002*AD	July 2007	001	31616	Fecal Coliform	7D Conc	400	4900.	7/1/2007
0PX00002*AD	August 2007	001	31616	Fecal Coliform	30D Conc	200	272.702	8/1/2007
0PX00002*AD	August 2007	001	31616	Fecal Coliform	7D Conc	400	780.	8/15/2007
0PX00002*AD	May 2010	001	31616	Fecal Coliform	30D Conc	200	632.	5/1/2010
0PX00002*AD	May 2010	001	31616	Fecal Coliform	7D Conc	400	632.	5/1/2010
0PX00002*AD	June 2010	001	31616	Fecal Coliform	30D Conc	200	440.	6/1/2010
0PX00002*AD	June 2010	001	31616	Fecal Coliform	7D Conc	400	440.	6/1/2010
0PX00002*AD	July 2010	001	31616	Fecal Coliform	30D Conc	200	1368.	7/1/2010
0PX00002*AD	July 2010	001	31616	Fecal Coliform	7D Conc	400	1368.	7/1/2010
0PX00002*AD	September 2010	001	31616	Fecal Coliform	30D Conc	200	231.	9/1/2010
0PX00002*AD	June 2011	001	31616	Fecal Coliform	30D Conc	200	440.	6/1/2011
0PX00002*AD	June 2011	001	31616	Fecal Coliform	7D Conc	400	440.	6/1/2011
0PX00002*AD	August 2011	001	31616	Fecal Coliform	30D Conc	200	798.	8/1/2011
0PX00002*AD	August 2011	001	31616	Fecal Coliform	7D Conc	400	798.	8/1/2011
0PX00002*AD	July 2005	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.35	.42581	7/5/2005
0PX00002*AD	August 2005	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.35	.90686	8/1/2005
0PX00002*AD	August 2005	001	00610	Nitrogen, Ammonia (NH3	30D Qty	0.21	.56025	8/1/2005
0PX00002*AD	August 2005	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.35	.62448	8/8/2005
0PX00002*AD	August 2005	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.35	.73407	8/15/2005
0PX00002*AD	August 2005	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.35	.39901	8/29/2005
0PX00002*AD	May 2006	001	00610	Nitrogen, Ammonia (NH3	1D Conc	2.5	3.74	5/30/2006
0PX00002*AD	May 2006	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.35	.94845	5/30/2006
0PX00002*AD	June 2006	001	00610	Nitrogen, Ammonia (NH3	30D Conc	1.5	8.6725	6/1/2006
0PX00002*AD	June 2006	001	00610	Nitrogen, Ammonia (NH3	1D Conc	2.5	9.94	6/7/2006
0PX00002*AD	June 2006	001	00610	Nitrogen, Ammonia (NH3	1D Conc	2.5	11.6	6/19/2006
0PX00002*AD	June 2006	001	00610	Nitrogen, Ammonia (NH3	1D Conc	2.5	13.1	6/26/2006
0PX00002*AD	July 2006	001	00610	Nitrogen, Ammonia (NH3	30D Conc	1.5	25.925	7/1/2006
0PX00002*AD	July 2006	001	00610	Nitrogen, Ammonia (NH3	30D Qty	0.21	.35768	7/1/2006
0PX00002*AD	July 2006	001	00610	Nitrogen, Ammonia (NH3	1D Conc	2.5	17.	7/5/2006
0PX00002*AD	July 2006	001	00610	Nitrogen, Ammonia (NH3	1D Conc	2.5	29.2	7/10/2006
0PX00002*AD	July 2006	001	00610	Nitrogen, Ammonia (NH3	1D Conc	2.5	27.	7/17/2006
0PX00002*AD	July 2006	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.35	1.43073	7/17/2006
0PX00002*AD	July 2006	001	00610	Nitrogen, Ammonia (NH3	1D Conc	2.5	30.5	7/24/2006
0PX00002*AD	August 2006	001	00610	Nitrogen, Ammonia (NH3	30D Conc	1.5	6.5532	8/1/2006
0PX00002*AD	August 2006	001	00610	Nitrogen, Ammonia (NH3	1D Conc	2.5	23.3	8/2/2006
0PX00002*AD	August 2006	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.35	.44095	8/2/2006
0PX00002*AD	August 2006	001	00610	Nitrogen, Ammonia (NH3	1D Conc	2.5	7.18	8/16/2006
0PX00002*AD	September 2006	001	00610	Nitrogen, Ammonia (NH3	30D Conc	1.5	4.07	9/1/2006
0PX00002*AD	September 2006	001	00610	Nitrogen, Ammonia (NH3	1D Conc	2.5	3.08	9/6/2006
0PX00002*AD	September 2006	001	00610	Nitrogen, Ammonia (NH3	1D Conc	2.5	5.6	9/18/2006
0PX00002*AD	September 2006	001	00610	Nitrogen, Ammonia (NH3	1D Conc	2.5	5.7	9/25/2006
0PX00002*AD	October 2006	001	00610	Nitrogen, Ammonia (NH3	30D Conc	1.5	3.937	10/1/2006
0PX00002*AD	October 2006	001	00610	Nitrogen, Ammonia (NH3	1D Conc	2.5	3.09	10/9/2006
0PX00002*AD	October 2006	001	00610	Nitrogen, Ammonia (NH3	1D Conc	2.5	4.2	10/16/2006
0PX00002*AD	October 2006	001	00610	Nitrogen, Ammonia (NH3	1D Conc	2.5	8.35	10/23/2006
0PX00002*AD	November 2006	001	00610	Nitrogen, Ammonia (NH3	1D Conc	6.0	6.37	11/6/2006
0PX00002*AD	May 2007	001	00610	Nitrogen, Ammonia (NH3	30D Conc	1.5	2.04875	5/1/2007

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
0PX00002*AD	May 2007	001	00610	Nitrogen, Ammonia (NH3	1D Conc	2.5	5.	5/29/2007
0PX00002*AD	May 2007	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.35	.3785	5/29/2007
0PX00002*AD	June 2007	001	00610	Nitrogen, Ammonia (NH3	30D Conc	1.5	6.9245	6/1/2007
0PX00002*AD	June 2007	001	00610	Nitrogen, Ammonia (NH3	30D Qty	0.21	.23185	6/1/2007
0PX00002*AD	June 2007	001	00610	Nitrogen, Ammonia (NH3	1D Conc	2.5	9.98	6/11/2007
0PX00002*AD	June 2007	001	00610	Nitrogen, Ammonia (NH3	1D Conc	2.5	7.2	6/18/2007
0PX00002*AD	June 2007	001	00610	Nitrogen, Ammonia (NH3	1D Conc	2.5	10.4	6/25/2007
0PX00002*AD	July 2007	001	00610	Nitrogen, Ammonia (NH3	30D Conc	1.5	25.24	7/1/2007
0PX00002*AD	July 2007	001	00610	Nitrogen, Ammonia (NH3	30D Qty	0.21	1.54352	7/1/2007
0PX00002*AD	July 2007	001	00610	Nitrogen, Ammonia (NH3	1D Conc	2.5	10.8	7/2/2007
0PX00002*AD	July 2007	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.35	.94019	7/2/2007
0PX00002*AD	July 2007	001	00610	Nitrogen, Ammonia (NH3	1D Conc	2.5	19.3	7/9/2007
0PX00002*AD	July 2007	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.35	1.46101	7/9/2007
0PX00002*AD	July 2007	001	00610	Nitrogen, Ammonia (NH3	1D Conc	2.5	23.	7/16/2007
0PX00002*AD	July 2007	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.35	1.21877	7/16/2007
0PX00002*AD	July 2007	001	00610	Nitrogen, Ammonia (NH3	1D Conc	2.5	29.	7/23/2007
0PX00002*AD	July 2007	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.35	1.42695	7/23/2007
0PX00002*AD	July 2007	001	00610	Nitrogen, Ammonia (NH3	1D Conc	2.5	44.1	7/30/2007
0PX00002*AD	July 2007	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.35	2.6707	7/30/2007
0PX00002*AD	August 2007	001	00610	Nitrogen, Ammonia (NH3	30D Conc	1.5	17.1923	8/1/2007
0PX00002*AD	August 2007	001	00610	Nitrogen, Ammonia (NH3	30D Qty	0.21	1.08183	8/1/2007
0PX00002*AD	August 2007	001	00610	Nitrogen, Ammonia (NH3	1D Conc	2.5	36.5	8/6/2007
0PX00002*AD	August 2007	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.35	2.6249	8/6/2007
0PX00002*AD	August 2007	001	00610	Nitrogen, Ammonia (NH3	1D Conc	2.5	14.7	8/13/2007
0PX00002*AD	August 2007	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.35	.61203	8/13/2007
0PX00002*AD	June 2008	001	00610	Nitrogen, Ammonia (NH3	1D Conc	2.5	3.59	6/3/2008
0PX00002*AD	June 2008	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.35	.36688	6/3/2008
0PX00002*AD	July 2008	001	00610	Nitrogen, Ammonia (NH3	30D Conc	1.5	14.325	7/1/2008
0PX00002*AD	July 2008	001	00610	Nitrogen, Ammonia (NH3	30D Qty	0.21	.45051	7/1/2008
0PX00002*AD	July 2008	001	00610	Nitrogen, Ammonia (NH3	1D Conc	2.5	17.7	7/7/2008
0PX00002*AD	July 2008	001	00610	Nitrogen, Ammonia (NH3	1D Conc	2.5	18.9	7/14/2008
0PX00002*AD	July 2008	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.35	.7869	7/14/2008
0PX00002*AD	July 2008	001	00610	Nitrogen, Ammonia (NH3	1D Conc	2.5	12.1	7/21/2008
0PX00002*AD	July 2008	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.35	.45799	7/21/2008
0PX00002*AD	July 2008	001	00610	Nitrogen, Ammonia (NH3	1D Conc	2.5	8.6	7/28/2008
0PX00002*AD	July 2008	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.35	.42316	7/28/2008
0PX00002*AD	December 2008	001	00610	Nitrogen, Ammonia (NH3	30D Conc	4.0	4.51	12/1/2008
0PX00002*AD	December 2008	001	00610	Nitrogen, Ammonia (NH3	1D Conc	6.0	7.5	12/29/2008
0PX00002*AD	January 2009	001	00610	Nitrogen, Ammonia (NH3	30D Conc	4.0	8.22333	1/1/2009
0PX00002*AD	January 2009	001	00610	Nitrogen, Ammonia (NH3	1D Conc	6.0	8.61	1/5/2009
0PX00002*AD	January 2009	001	00610	Nitrogen, Ammonia (NH3	1D Conc	6.0	10.1	1/13/2009
0PX00002*AD	July 2009	001	00610	Nitrogen, Ammonia (NH3	30D Conc	1.5	15.555	7/1/2009
0PX00002*AD	July 2009	001	00610	Nitrogen, Ammonia (NH3	30D Qty	0.21	.65967	7/1/2009
0PX00002*AD	July 2009	001	00610	Nitrogen, Ammonia (NH3	1D Conc	2.5	9.31	7/6/2009
0PX00002*AD	July 2009	001	00610	Nitrogen, Ammonia (NH3	1D Conc	2.5	21.8	7/21/2009
0PX00002*AD	July 2009	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.35	1.07267	7/21/2009
0PX00002*AD	August 2009	001	00610	Nitrogen, Ammonia (NH3	30D Conc	1.5	27.2	8/1/2009
0PX00002*AD	August 2009	001	00610	Nitrogen, Ammonia (NH3	30D Qty	0.21	1.82588	8/1/2009
0PX00002*AD	August 2009	001	00610	Nitrogen, Ammonia (NH3	1D Conc	2.5	32.6	8/3/2009
0PX00002*AD	August 2009	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.35	2.7146	8/3/2009
0PX00002*AD	August 2009	001	00610	Nitrogen, Ammonia (NH3	1D Conc	2.5	28.4	8/18/2009
0PX00002*AD	August 2009	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.35	1.8274	8/18/2009
0PX00002*AD	August 2009	001	00610	Nitrogen, Ammonia (NH3	1D Conc	2.5	20.6	8/24/2009
0PX00002*AD	August 2009	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.35	.93565	8/24/2009
0PX00002*AD	September 2009	001	00610	Nitrogen, Ammonia (NH3	1D Conc	2.5	8.59	9/1/2009
0PX00002*AD	September 2009	001	00610	Nitrogen, Ammonia (NH3	30D Conc	1.5	4.32	9/1/2009
0PX00002*AD	October 2009	001	00610	Nitrogen, Ammonia (NH3	30D Conc	1.5	4.9	10/1/2009
0PX00002*AD	October 2009	001	00610	Nitrogen, Ammonia (NH3	1D Conc	2.5	9.7	10/19/2009
0PX00002*AD	February 2010	001	00610	Nitrogen, Ammonia (NH3	30D Conc	4.0	4.64	2/1/2010

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
0PX00002*AD	March 2010	001	00610	Nitrogen, Ammonia (NH3	1D Conc	6.0	6.45	3/1/2010
0PX00002*AD	June 2010	001	00610	Nitrogen, Ammonia (NH3	30D Conc	1.5	2.71	6/1/2010
0PX00002*AD	June 2010	001	00610	Nitrogen, Ammonia (NH3	1D Conc	2.5	4.18	6/15/2010
0PX00002*AD	July 2010	001	00610	Nitrogen, Ammonia (NH3	30D Conc	1.5	13.25	7/1/2010
0PX00002*AD	July 2010	001	00610	Nitrogen, Ammonia (NH3	30D Qty	0.21	.97445	7/1/2010
0PX00002*AD	July 2010	001	00610	Nitrogen, Ammonia (NH3	1D Conc	2.5	11.4	7/7/2010
0PX00002*AD	July 2010	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.35	.86298	7/7/2010
0PX00002*AD	July 2010	001	00610	Nitrogen, Ammonia (NH3	1D Conc	2.5	15.1	7/19/2010
0PX00002*AD	July 2010	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.35	1.08592	7/19/2010
0PX00002*AD	December 2010	001	00610	Nitrogen, Ammonia (NH3	30D Conc	4.0	7.59	12/1/2010
0PX00002*AD	December 2010	001	00610	Nitrogen, Ammonia (NH3	1D Conc	6.0	8.58	12/6/2010
0PX00002*AD	December 2010	001	00610	Nitrogen, Ammonia (NH3	1D Conc	6.0	6.6	12/20/2010
0PX00002*AD	January 2011	001	00610	Nitrogen, Ammonia (NH3	30D Conc	4.0	5.205	1/1/2011
0PX00002*AD	June 2011	001	00610	Nitrogen, Ammonia (NH3	30D Conc	1.5	2.925	6/1/2011
0PX00002*AD	June 2011	001	00610	Nitrogen, Ammonia (NH3	30D Qty	0.21	.22106	6/1/2011
0PX00002*AD	June 2011	001	00610	Nitrogen, Ammonia (NH3	1D Conc	2.5	4.61	6/15/2011
0PX00002*AD	July 2011	001	00610	Nitrogen, Ammonia (NH3	30D Conc	1.5	12.75	7/1/2011
0PX00002*AD	July 2011	001	00610	Nitrogen, Ammonia (NH3	30D Qty	0.21	1.07362	7/1/2011
0PX00002*AD	July 2011	001	00610	Nitrogen, Ammonia (NH3	1D Conc	2.5	13.1	7/5/2011
0PX00002*AD	July 2011	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.35	1.53709	7/5/2011
0PX00002*AD	July 2011	001	00610	Nitrogen, Ammonia (NH3	1D Conc	2.5	12.4	7/18/2011
0PX00002*AD	July 2011	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.35	.61014	7/18/2011
0PX00002*AD	August 2011	001	00610	Nitrogen, Ammonia (NH3	30D Conc	1.5	2.005	8/1/2011
0PX00002*AD	August 2011	001	00610	Nitrogen, Ammonia (NH3	1D Conc	2.5	3.96	8/15/2011
0PX00002*AD	June 2012	001	00610	Nitrogen, Ammonia (NH3	30D Conc	1.5	2.095	6/1/2012
0PX00002*AD	June 2012	001	00610	Nitrogen, Ammonia (NH3	1D Conc	2.5	3.33	6/4/2012
0PX00002*AD	February 2007	001	00400	pH	1D Conc	6.5	6.35	2/5/2007
0PX00002*AD	September 2007	001	00400	pH	1D Conc	6.5	3.62	9/17/2007
0PX00002*AD	November 2007	001	00400	pH	1D Conc	6.5	3.74	11/19/2007
0PX00002*AD	November 2007	001	00400	pH	1D Conc	6.5	3.19	11/26/2007
0PX00002*AD	December 2007	001	00400	pH	1D Conc	6.5	5.9	12/27/2007
0PX00002*AD	November 2008	001	00400	pH	1D Conc	6.5	5.66	11/4/2008
0PX00002*AD	November 2008	001	00400	pH	1D Conc	6.5	3.38	11/10/2008
0PX00002*AD	September 2009	001	00400	pH	1D Conc	6.5	5.88	9/1/2009
0PX00002*AD	September 2009	001	00400	pH	1D Conc	6.5	6.49	9/15/2009
0PX00002*AD	November 2009	001	00400	pH	1D Conc	6.5	3.14	11/9/2009
0PX00002*AD	November 2009	001	00400	pH	1D Conc	6.5	2.84	11/27/2009
0PX00002*AD	December 2009	001	00400	pH	1D Conc	6.5	3.38	12/8/2009
0PX00002*AD	December 2009	001	00400	pH	1D Conc	6.5	6.03	12/22/2009
0PX00002*AD	January 2010	001	00400	pH	1D Conc	6.5	5.72	1/4/2010
0PX00002*AD	April 2010	001	00400	pH	1D Conc	6.5	4.64	4/12/2010
0PX00002*AD	October 2010	001	00400	pH	1D Conc	6.5	3.57	10/5/2010
0PX00002*AD	January 2011	001	00400	pH	1D Conc	6.5	4.05	1/10/2011
0PX00002*AD	January 2011	001	00400	pH	1D Conc	6.5	2.88	1/18/2011
0PX00002*AD	January 2011	001	00400	pH	1D Conc	6.5	6.31	1/24/2011
0PX00002*AD	February 2011	001	00400	pH	1D Conc	6.5	6.15	2/15/2011
0PX00002*AD	June 2012	001	00400	pH	1D Conc	6.5	3.45	6/26/2012
0PX00002*AD	April 2005	001	00665	Phosphorus, Total (P)	30D Conc	1.0	1.15025	4/1/2005
0PX00002*AD	April 2005	001	00665	Phosphorus, Total (P)	30D Qty	0.14	.33523	4/1/2005
0PX00002*AD	April 2005	001	00665	Phosphorus, Total (P)	1D Qty	0.21	.32933	4/12/2005
0PX00002*AD	April 2005	001	00665	Phosphorus, Total (P)	1D Qty	0.21	.43134	4/18/2005
0PX00002*AD	April 2005	001	00665	Phosphorus, Total (P)	1D Qty	0.21	.43134	4/25/2005
0PX00002*AD	May 2005	001	00665	Phosphorus, Total (P)	30D Qty	0.14	.21299	5/1/2005
0PX00002*AD	May 2005	001	00665	Phosphorus, Total (P)	1D Qty	0.21	.3168	5/2/2005
0PX00002*AD	May 2005	001	00665	Phosphorus, Total (P)	1D Qty	0.21	.22004	5/9/2005
0PX00002*AD	May 2005	001	00665	Phosphorus, Total (P)	1D Qty	0.21	.30893	5/23/2005
0PX00002*AD	June 2005	001	00665	Phosphorus, Total (P)	1D Conc	1.5	2.37	6/1/2005
0PX00002*AD	June 2005	001	00665	Phosphorus, Total (P)	30D Conc	1.0	1.988	6/1/2005
0PX00002*AD	June 2005	001	00665	Phosphorus, Total (P)	1D Qty	0.21	.62793	6/1/2005

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
0PX00002*AD	June 2005	001	00665	Phosphorus, Total (P)	30D Qty	0.14	.42604	6/1/2005
0PX00002*AD	June 2005	001	00665	Phosphorus, Total (P)	1D Conc	1.5	2.59	6/6/2005
0PX00002*AD	June 2005	001	00665	Phosphorus, Total (P)	1D Qty	0.21	.29409	6/6/2005
0PX00002*AD	June 2005	001	00665	Phosphorus, Total (P)	1D Qty	0.21	.24224	6/13/2005
0PX00002*AD	June 2005	001	00665	Phosphorus, Total (P)	1D Qty	0.21	.25738	6/20/2005
0PX00002*AD	June 2005	001	00665	Phosphorus, Total (P)	1D Conc	1.5	2.34	6/27/2005
0PX00002*AD	June 2005	001	00665	Phosphorus, Total (P)	1D Qty	0.21	.70855	6/27/2005
0PX00002*AD	July 2005	001	00665	Phosphorus, Total (P)	30D Conc	1.0	4.2025	7/1/2005
0PX00002*AD	July 2005	001	00665	Phosphorus, Total (P)	30D Qty	0.14	.86828	7/1/2005
0PX00002*AD	July 2005	001	00665	Phosphorus, Total (P)	1D Conc	1.5	3.52	7/5/2005
0PX00002*AD	July 2005	001	00665	Phosphorus, Total (P)	1D Qty	0.21	.66616	7/5/2005
0PX00002*AD	July 2005	001	00665	Phosphorus, Total (P)	1D Conc	1.5	4.6	7/13/2005
0PX00002*AD	July 2005	001	00665	Phosphorus, Total (P)	1D Qty	0.21	.87055	7/13/2005
0PX00002*AD	July 2005	001	00665	Phosphorus, Total (P)	1D Conc	1.5	4.59	7/18/2005
0PX00002*AD	July 2005	001	00665	Phosphorus, Total (P)	1D Qty	0.21	.69493	7/18/2005
0PX00002*AD	July 2005	001	00665	Phosphorus, Total (P)	1D Conc	1.5	4.1	7/25/2005
0PX00002*AD	July 2005	001	00665	Phosphorus, Total (P)	1D Qty	0.21	1.24148	7/25/2005
0PX00002*AD	August 2005	001	00665	Phosphorus, Total (P)	1D Conc	1.5	4.96	8/1/2005
0PX00002*AD	August 2005	001	00665	Phosphorus, Total (P)	30D Conc	1.0	5.346	8/1/2005
0PX00002*AD	August 2005	001	00665	Phosphorus, Total (P)	1D Qty	0.21	10.0626	8/1/2005
0PX00002*AD	August 2005	001	00665	Phosphorus, Total (P)	30D Qty	0.14	13.2256	8/1/2005
0PX00002*AD	August 2005	001	00665	Phosphorus, Total (P)	1D Conc	1.5	5.03	8/8/2005
0PX00002*AD	August 2005	001	00665	Phosphorus, Total (P)	1D Qty	0.21	11.0994	8/8/2005
0PX00002*AD	August 2005	001	00665	Phosphorus, Total (P)	1D Conc	1.5	5.37	8/15/2005
0PX00002*AD	August 2005	001	00665	Phosphorus, Total (P)	1D Qty	0.21	13.2725	8/15/2005
0PX00002*AD	August 2005	001	00665	Phosphorus, Total (P)	1D Conc	1.5	6.27	8/23/2005
0PX00002*AD	August 2005	001	00665	Phosphorus, Total (P)	1D Qty	0.21	17.1582	8/23/2005
0PX00002*AD	August 2005	001	00665	Phosphorus, Total (P)	1D Conc	1.5	5.1	8/29/2005
0PX00002*AD	August 2005	001	00665	Phosphorus, Total (P)	1D Qty	0.21	14.5355	8/29/2005
0PX00002*AD	September 2005	001	00665	Phosphorus, Total (P)	30D Conc	1.0	6.5075	9/1/2005
0PX00002*AD	September 2005	001	00665	Phosphorus, Total (P)	1D Conc	1.5	5.36	9/6/2005
0PX00002*AD	September 2005	001	00665	Phosphorus, Total (P)	1D Conc	1.5	5.92	9/13/2005
0PX00002*AD	September 2005	001	00665	Phosphorus, Total (P)	1D Conc	1.5	6.82	9/19/2005
0PX00002*AD	September 2005	001	00665	Phosphorus, Total (P)	1D Conc	1.5	7.93	9/26/2005
0PX00002*AD	September 2005	001	00665	Phosphorus, Total (P)	1D Qty	0.21	.21011	9/26/2005
0PX00002*AD	October 2005	001	00665	Phosphorus, Total (P)	30D Conc	1.0	6.2475	10/1/2005
0PX00002*AD	October 2005	001	00665	Phosphorus, Total (P)	30D Qty	0.14	.16661	10/1/2005
0PX00002*AD	October 2005	001	00665	Phosphorus, Total (P)	1D Conc	1.5	6.08	10/3/2005
0PX00002*AD	October 2005	001	00665	Phosphorus, Total (P)	1D Conc	1.5	5.84	10/10/2005
0PX00002*AD	October 2005	001	00665	Phosphorus, Total (P)	1D Conc	1.5	6.9	10/17/2005
0PX00002*AD	October 2005	001	00665	Phosphorus, Total (P)	1D Conc	1.5	6.17	10/24/2005
0PX00002*AD	October 2005	001	00665	Phosphorus, Total (P)	1D Qty	0.21	.21018	10/24/2005
0PX00002*AD	November 2005	001	00665	Phosphorus, Total (P)	1D Conc	1.5	5.6	11/1/2005
0PX00002*AD	November 2005	001	00665	Phosphorus, Total (P)	30D Conc	1.0	4.376	11/1/2005
0PX00002*AD	November 2005	001	00665	Phosphorus, Total (P)	1D Conc	1.5	5.33	11/14/2005
0PX00002*AD	November 2005	001	00665	Phosphorus, Total (P)	1D Conc	1.5	3.96	11/21/2005
0PX00002*AD	November 2005	001	00665	Phosphorus, Total (P)	1D Conc	1.5	6.03	11/28/2005
0PX00002*AD	December 2005	001	00665	Phosphorus, Total (P)	30D Conc	1.0	5.3	12/1/2005
0PX00002*AD	December 2005	001	00665	Phosphorus, Total (P)	1D Conc	1.5	5.8	12/5/2005
0PX00002*AD	December 2005	001	00665	Phosphorus, Total (P)	1D Conc	1.5	4.73	12/12/2005
0PX00002*AD	December 2005	001	00665	Phosphorus, Total (P)	1D Conc	1.5	5.54	12/19/2005
0PX00002*AD	December 2005	001	00665	Phosphorus, Total (P)	1D Conc	1.5	5.13	12/22/2005
0PX00002*AD	January 2006	001	00665	Phosphorus, Total (P)	30D Conc	1.0	3.418	1/1/2006
0PX00002*AD	January 2006	001	00665	Phosphorus, Total (P)	1D Conc	1.5	4.14	1/3/2006
0PX00002*AD	January 2006	001	00665	Phosphorus, Total (P)	1D Conc	1.5	3.66	1/9/2006
0PX00002*AD	January 2006	001	00665	Phosphorus, Total (P)	1D Conc	1.5	3.47	1/17/2006
0PX00002*AD	January 2006	001	00665	Phosphorus, Total (P)	1D Conc	1.5	2.96	1/23/2006
0PX00002*AD	January 2006	001	00665	Phosphorus, Total (P)	1D Conc	1.5	2.86	1/30/2006
0PX00002*AD	February 2006	001	00665	Phosphorus, Total (P)	30D Conc	1.0	2.815	2/1/2006

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
0PX00002*AD	February 2006	001	00665	Phosphorus, Total (P)	1D Conc	1.5	2.63	2/6/2006
0PX00002*AD	February 2006	001	00665	Phosphorus, Total (P)	1D Conc	1.5	3.82	2/13/2006
0PX00002*AD	February 2006	001	00665	Phosphorus, Total (P)	1D Conc	1.5	2.2	2/21/2006
0PX00002*AD	February 2006	001	00665	Phosphorus, Total (P)	1D Conc	1.5	2.61	2/27/2006
0PX00002*AD	March 2006	001	00665	Phosphorus, Total (P)	30D Conc	1.0	2.055	3/1/2006
0PX00002*AD	March 2006	001	00665	Phosphorus, Total (P)	1D Conc	1.5	2.57	3/6/2006
0PX00002*AD	March 2006	001	00665	Phosphorus, Total (P)	1D Conc	1.5	1.69	3/13/2006
0PX00002*AD	March 2006	001	00665	Phosphorus, Total (P)	1D Conc	1.5	1.73	3/20/2006
0PX00002*AD	March 2006	001	00665	Phosphorus, Total (P)	1D Conc	1.5	2.23	3/28/2006
0PX00002*AD	April 2006	001	00665	Phosphorus, Total (P)	30D Conc	1.0	3.32	4/1/2006
0PX00002*AD	April 2006	001	00665	Phosphorus, Total (P)	1D Conc	1.5	2.43	4/3/2006
0PX00002*AD	April 2006	001	00665	Phosphorus, Total (P)	1D Conc	1.5	3.12	4/10/2006
0PX00002*AD	April 2006	001	00665	Phosphorus, Total (P)	1D Conc	1.5	3.7	4/17/2006
0PX00002*AD	April 2006	001	00665	Phosphorus, Total (P)	1D Conc	1.5	4.03	4/24/2006
0PX00002*AD	May 2006	001	00665	Phosphorus, Total (P)	1D Conc	1.5	4.66	5/1/2006
0PX00002*AD	May 2006	001	00665	Phosphorus, Total (P)	30D Conc	1.0	4.356	5/1/2006
0PX00002*AD	May 2006	001	00665	Phosphorus, Total (P)	30D Qty	0.14	.31967	5/1/2006
0PX00002*AD	May 2006	001	00665	Phosphorus, Total (P)	1D Conc	1.5	4.21	5/8/2006
0PX00002*AD	May 2006	001	00665	Phosphorus, Total (P)	1D Conc	1.5	3.71	5/15/2006
0PX00002*AD	May 2006	001	00665	Phosphorus, Total (P)	1D Conc	1.5	4.16	5/22/2006
0PX00002*AD	May 2006	001	00665	Phosphorus, Total (P)	1D Conc	1.5	5.04	5/30/2006
0PX00002*AD	May 2006	001	00665	Phosphorus, Total (P)	1D Qty	0.21	1.27812	5/30/2006
0PX00002*AD	June 2006	001	00665	Phosphorus, Total (P)	30D Conc	1.0	5.71	6/1/2006
0PX00002*AD	June 2006	001	00665	Phosphorus, Total (P)	1D Conc	1.5	5.37	6/7/2006
0PX00002*AD	June 2006	001	00665	Phosphorus, Total (P)	1D Conc	1.5	6.5	6/12/2006
0PX00002*AD	June 2006	001	00665	Phosphorus, Total (P)	1D Conc	1.5	6.01	6/19/2006
0PX00002*AD	June 2006	001	00665	Phosphorus, Total (P)	1D Conc	1.5	4.96	6/26/2006
0PX00002*AD	July 2006	001	00665	Phosphorus, Total (P)	30D Conc	1.0	8.335	7/1/2006
0PX00002*AD	July 2006	001	00665	Phosphorus, Total (P)	1D Conc	1.5	6.62	7/5/2006
0PX00002*AD	July 2006	001	00665	Phosphorus, Total (P)	1D Conc	1.5	7.65	7/10/2006
0PX00002*AD	July 2006	001	00665	Phosphorus, Total (P)	1D Conc	1.5	8.66	7/17/2006
0PX00002*AD	July 2006	001	00665	Phosphorus, Total (P)	1D Qty	0.21	.45889	7/17/2006
0PX00002*AD	July 2006	001	00665	Phosphorus, Total (P)	1D Conc	1.5	10.41	7/24/2006
0PX00002*AD	August 2006	001	00665	Phosphorus, Total (P)	30D Conc	1.0	8.078	8/1/2006
0PX00002*AD	August 2006	001	00665	Phosphorus, Total (P)	1D Conc	1.5	11.62	8/2/2006
0PX00002*AD	August 2006	001	00665	Phosphorus, Total (P)	1D Qty	0.21	.21991	8/2/2006
0PX00002*AD	August 2006	001	00665	Phosphorus, Total (P)	1D Conc	1.5	9.68	8/8/2006
0PX00002*AD	August 2006	001	00665	Phosphorus, Total (P)	1D Conc	1.5	5.61	8/16/2006
0PX00002*AD	August 2006	001	00665	Phosphorus, Total (P)	1D Conc	1.5	6.72	8/23/2006
0PX00002*AD	August 2006	001	00665	Phosphorus, Total (P)	1D Conc	1.5	6.76	8/28/2006
0PX00002*AD	September 2006	001	00665	Phosphorus, Total (P)	30D Conc	1.0	5.155	9/1/2006
0PX00002*AD	September 2006	001	00665	Phosphorus, Total (P)	1D Conc	1.5	7.64	9/6/2006
0PX00002*AD	September 2006	001	00665	Phosphorus, Total (P)	1D Conc	1.5	6.42	9/11/2006
0PX00002*AD	September 2006	001	00665	Phosphorus, Total (P)	1D Conc	1.5	5.09	9/25/2006
0PX00002*AD	October 2006	001	00665	Phosphorus, Total (P)	30D Conc	1.0	4.0225	10/1/2006
0PX00002*AD	October 2006	001	00665	Phosphorus, Total (P)	1D Conc	1.5	5.67	10/2/2006
0PX00002*AD	October 2006	001	00665	Phosphorus, Total (P)	1D Conc	1.5	2.24	10/9/2006
0PX00002*AD	October 2006	001	00665	Phosphorus, Total (P)	1D Conc	1.5	4.52	10/16/2006
0PX00002*AD	October 2006	001	00665	Phosphorus, Total (P)	1D Conc	1.5	3.66	10/23/2006
0PX00002*AD	November 2006	001	00665	Phosphorus, Total (P)	30D Conc	1.0	2.3625	11/1/2006
0PX00002*AD	November 2006	001	00665	Phosphorus, Total (P)	1D Conc	1.5	2.58	11/6/2006
0PX00002*AD	November 2006	001	00665	Phosphorus, Total (P)	1D Conc	1.5	2.49	11/13/2006
0PX00002*AD	November 2006	001	00665	Phosphorus, Total (P)	1D Conc	1.5	2.24	11/20/2006
0PX00002*AD	November 2006	001	00665	Phosphorus, Total (P)	1D Conc	1.5	2.14	11/27/2006
0PX00002*AD	December 2006	001	00665	Phosphorus, Total (P)	30D Conc	1.0	1.8	12/1/2006
0PX00002*AD	December 2006	001	00665	Phosphorus, Total (P)	1D Conc	1.5	1.93	12/4/2006
0PX00002*AD	December 2006	001	00665	Phosphorus, Total (P)	1D Conc	1.5	1.96	12/11/2006
0PX00002*AD	December 2006	001	00665	Phosphorus, Total (P)	1D Conc	1.5	2.13	12/18/2006
0PX00002*AD	January 2007	001	00665	Phosphorus, Total (P)	1D Conc	1.5	1.54	1/8/2007

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
0PX00002*AD	February 2007	001	00665	Phosphorus, Total (P)	30D Conc	1.0	1.23225	2/1/2007
0PX00002*AD	February 2007	001	00665	Phosphorus, Total (P)	1D Conc	1.5	1.99	2/13/2007
0PX00002*AD	April 2007	001	00665	Phosphorus, Total (P)	30D Conc	1.0	1.324	4/1/2007
0PX00002*AD	April 2007	001	00665	Phosphorus, Total (P)	1D Conc	1.5	1.82	4/30/2007
0PX00002*AD	May 2007	001	00665	Phosphorus, Total (P)	30D Conc	1.0	3.1675	5/1/2007
0PX00002*AD	May 2007	001	00665	Phosphorus, Total (P)	1D Conc	1.5	2.86	5/7/2007
0PX00002*AD	May 2007	001	00665	Phosphorus, Total (P)	1D Conc	1.5	3.13	5/16/2007
0PX00002*AD	May 2007	001	00665	Phosphorus, Total (P)	1D Conc	1.5	3.62	5/21/2007
0PX00002*AD	May 2007	001	00665	Phosphorus, Total (P)	1D Conc	1.5	3.06	5/29/2007
0PX00002*AD	May 2007	001	00665	Phosphorus, Total (P)	1D Qty	0.21	.23164	5/29/2007
0PX00002*AD	June 2007	001	00665	Phosphorus, Total (P)	30D Conc	1.0	2.825	6/1/2007
0PX00002*AD	June 2007	001	00665	Phosphorus, Total (P)	1D Conc	1.5	4.5	6/11/2007
0PX00002*AD	June 2007	001	00665	Phosphorus, Total (P)	1D Conc	1.5	4.45	6/18/2007
0PX00002*AD	July 2007	001	00665	Phosphorus, Total (P)	30D Conc	1.0	8.06	7/1/2007
0PX00002*AD	July 2007	001	00665	Phosphorus, Total (P)	30D Qty	0.14	.51822	7/1/2007
0PX00002*AD	July 2007	001	00665	Phosphorus, Total (P)	1D Conc	1.5	7.56	7/2/2007
0PX00002*AD	July 2007	001	00665	Phosphorus, Total (P)	1D Qty	0.21	.65814	7/2/2007
0PX00002*AD	July 2007	001	00665	Phosphorus, Total (P)	1D Conc	1.5	6.73	7/9/2007
0PX00002*AD	July 2007	001	00665	Phosphorus, Total (P)	1D Qty	0.21	.50946	7/9/2007
0PX00002*AD	July 2007	001	00665	Phosphorus, Total (P)	1D Conc	1.5	7.96	7/16/2007
0PX00002*AD	July 2007	001	00665	Phosphorus, Total (P)	1D Qty	0.21	.4218	7/16/2007
0PX00002*AD	July 2007	001	00665	Phosphorus, Total (P)	1D Conc	1.5	8.05	7/23/2007
0PX00002*AD	July 2007	001	00665	Phosphorus, Total (P)	1D Qty	0.21	.3961	7/23/2007
0PX00002*AD	July 2007	001	00665	Phosphorus, Total (P)	1D Conc	1.5	10.	7/30/2007
0PX00002*AD	July 2007	001	00665	Phosphorus, Total (P)	1D Qty	0.21	.6056	7/30/2007
0PX00002*AD	August 2007	001	00665	Phosphorus, Total (P)	30D Conc	1.0	9.63	8/1/2007
0PX00002*AD	August 2007	001	00665	Phosphorus, Total (P)	30D Qty	0.14	.40095	8/1/2007
0PX00002*AD	August 2007	001	00665	Phosphorus, Total (P)	1D Conc	1.5	9.63	8/13/2007
0PX00002*AD	August 2007	001	00665	Phosphorus, Total (P)	1D Qty	0.21	.40095	8/13/2007
0PX00002*AD	November 2007	001	00665	Phosphorus, Total (P)	30D Conc	1.0	3.1425	11/1/2007
0PX00002*AD	November 2007	001	00665	Phosphorus, Total (P)	30D Qty	0.14	.4287	11/1/2007
0PX00002*AD	November 2007	001	00665	Phosphorus, Total (P)	1D Conc	1.5	6.92	11/6/2007
0PX00002*AD	November 2007	001	00665	Phosphorus, Total (P)	1D Qty	0.21	1.6763	11/6/2007
0PX00002*AD	November 2007	001	00665	Phosphorus, Total (P)	1D Conc	1.5	4.52	11/15/2007
0PX00002*AD	December 2007	001	00665	Phosphorus, Total (P)	30D Conc	1.0	2.136	12/1/2007
0PX00002*AD	December 2007	001	00665	Phosphorus, Total (P)	1D Conc	1.5	2.36	12/3/2007
0PX00002*AD	December 2007	001	00665	Phosphorus, Total (P)	1D Conc	1.5	2.79	12/10/2007
0PX00002*AD	December 2007	001	00665	Phosphorus, Total (P)	1D Conc	1.5	2.71	12/17/2007
0PX00002*AD	April 2008	001	00665	Phosphorus, Total (P)	30D Conc	1.0	2.298	4/1/2008
0PX00002*AD	April 2008	001	00665	Phosphorus, Total (P)	30D Qty	0.14	.29661	4/1/2008
0PX00002*AD	April 2008	001	00665	Phosphorus, Total (P)	1D Conc	1.5	1.54	4/15/2008
0PX00002*AD	April 2008	001	00665	Phosphorus, Total (P)	1D Conc	1.5	2.9	4/21/2008
0PX00002*AD	April 2008	001	00665	Phosphorus, Total (P)	1D Qty	0.21	.57078	4/21/2008
0PX00002*AD	April 2008	001	00665	Phosphorus, Total (P)	1D Conc	1.5	4.13	4/28/2008
0PX00002*AD	April 2008	001	00665	Phosphorus, Total (P)	1D Qty	0.21	.42207	4/28/2008
0PX00002*AD	May 2008	001	00665	Phosphorus, Total (P)	30D Conc	1.0	3.54	5/1/2008
0PX00002*AD	May 2008	001	00665	Phosphorus, Total (P)	30D Qty	0.14	.37477	5/1/2008
0PX00002*AD	May 2008	001	00665	Phosphorus, Total (P)	1D Conc	1.5	3.54	5/7/2008
0PX00002*AD	May 2008	001	00665	Phosphorus, Total (P)	1D Qty	0.21	.52256	5/7/2008
0PX00002*AD	May 2008	001	00665	Phosphorus, Total (P)	1D Conc	1.5	5.02	5/12/2008
0PX00002*AD	May 2008	001	00665	Phosphorus, Total (P)	1D Qty	0.21	.39901	5/12/2008
0PX00002*AD	May 2008	001	00665	Phosphorus, Total (P)	1D Conc	1.5	2.06	5/19/2008
0PX00002*AD	June 2008	001	00665	Phosphorus, Total (P)	30D Conc	1.0	7.025	6/1/2008
0PX00002*AD	June 2008	001	00665	Phosphorus, Total (P)	30D Qty	0.14	.23058	6/1/2008
0PX00002*AD	June 2008	001	00665	Phosphorus, Total (P)	1D Conc	1.5	5.29	6/3/2008
0PX00002*AD	June 2008	001	00665	Phosphorus, Total (P)	1D Qty	0.21	.54061	6/3/2008
0PX00002*AD	June 2008	001	00665	Phosphorus, Total (P)	1D Conc	1.5	8.	6/11/2008
0PX00002*AD	June 2008	001	00665	Phosphorus, Total (P)	1D Conc	1.5	8.94	6/16/2008
0PX00002*AD	June 2008	001	00665	Phosphorus, Total (P)	1D Conc	1.5	5.87	6/23/2008

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
0PX00002*AD	July 2008	001	00665	Phosphorus, Total (P)	30D Conc	1.0	6.3075	7/1/2008
0PX00002*AD	July 2008	001	00665	Phosphorus, Total (P)	30D Qty	0.14	.24642	7/1/2008
0PX00002*AD	July 2008	001	00665	Phosphorus, Total (P)	1D Conc	1.5	2.7	7/7/2008
0PX00002*AD	July 2008	001	00665	Phosphorus, Total (P)	1D Conc	1.5	4.91	7/14/2008
0PX00002*AD	July 2008	001	00665	Phosphorus, Total (P)	1D Conc	1.5	9.35	7/21/2008
0PX00002*AD	July 2008	001	00665	Phosphorus, Total (P)	1D Qty	0.21	.3539	7/21/2008
0PX00002*AD	July 2008	001	00665	Phosphorus, Total (P)	1D Conc	1.5	8.27	7/28/2008
0PX00002*AD	July 2008	001	00665	Phosphorus, Total (P)	1D Qty	0.21	.40693	7/28/2008
0PX00002*AD	October 2008	001	00665	Phosphorus, Total (P)	30D Conc	1.0	1.69325	10/1/2008
0PX00002*AD	October 2008	001	00665	Phosphorus, Total (P)	1D Conc	1.5	2.11	10/13/2008
0PX00002*AD	October 2008	001	00665	Phosphorus, Total (P)	1D Conc	1.5	2.37	10/28/2008
0PX00002*AD	November 2008	001	00665	Phosphorus, Total (P)	1D Conc	1.5	1.54	11/17/2008
0PX00002*AD	December 2008	001	00665	Phosphorus, Total (P)	1D Conc	1.5	5.01	12/1/2008
0PX00002*AD	December 2008	001	00665	Phosphorus, Total (P)	30D Conc	1.0	5.01	12/1/2008
0PX00002*AD	January 2009	001	00665	Phosphorus, Total (P)	30D Conc	1.0	2.7	1/1/2009
0PX00002*AD	January 2009	001	00665	Phosphorus, Total (P)	1D Conc	1.5	2.7	1/5/2009
0PX00002*AD	March 2009	001	00665	Phosphorus, Total (P)	30D Conc	1.0	1.75	3/1/2009
0PX00002*AD	March 2009	001	00665	Phosphorus, Total (P)	1D Conc	1.5	1.75	3/2/2009
0PX00002*AD	April 2009	001	00665	Phosphorus, Total (P)	30D Conc	1.0	2.24	4/1/2009
0PX00002*AD	April 2009	001	00665	Phosphorus, Total (P)	30D Qty	0.14	.14413	4/1/2009
0PX00002*AD	April 2009	001	00665	Phosphorus, Total (P)	1D Conc	1.5	2.24	4/6/2009
0PX00002*AD	May 2009	001	00665	Phosphorus, Total (P)	30D Conc	1.0	4.38	5/1/2009
0PX00002*AD	May 2009	001	00665	Phosphorus, Total (P)	30D Qty	0.14	.46419	5/1/2009
0PX00002*AD	May 2009	001	00665	Phosphorus, Total (P)	1D Conc	1.5	4.38	5/4/2009
0PX00002*AD	May 2009	001	00665	Phosphorus, Total (P)	1D Qty	0.21	.46419	5/4/2009
0PX00002*AD	June 2009	001	00665	Phosphorus, Total (P)	30D Conc	1.0	3.45	6/1/2009
0PX00002*AD	June 2009	001	00665	Phosphorus, Total (P)	1D Conc	1.5	3.45	6/2/2009
0PX00002*AD	July 2009	001	00665	Phosphorus, Total (P)	30D Conc	1.0	1.17	7/1/2009
0PX00002*AD	August 2009	001	00665	Phosphorus, Total (P)	30D Conc	1.0	5.15	8/1/2009
0PX00002*AD	August 2009	001	00665	Phosphorus, Total (P)	30D Qty	0.14	.42884	8/1/2009
0PX00002*AD	August 2009	001	00665	Phosphorus, Total (P)	1D Conc	1.5	5.15	8/3/2009
0PX00002*AD	August 2009	001	00665	Phosphorus, Total (P)	1D Qty	0.21	.42884	8/3/2009
0PX00002*AD	October 2009	001	00665	Phosphorus, Total (P)	30D Conc	1.0	7.07	10/1/2009
0PX00002*AD	October 2009	001	00665	Phosphorus, Total (P)	30D Qty	0.14	.24084	10/1/2009
0PX00002*AD	October 2009	001	00665	Phosphorus, Total (P)	1D Conc	1.5	7.07	10/12/2009
0PX00002*AD	October 2009	001	00665	Phosphorus, Total (P)	1D Qty	0.21	.24084	10/12/2009
0PX00002*AD	November 2009	001	00665	Phosphorus, Total (P)	30D Conc	1.0	1.81	11/1/2009
0PX00002*AD	November 2009	001	00665	Phosphorus, Total (P)	1D Conc	1.5	1.81	11/2/2009
0PX00002*AD	December 2009	001	00665	Phosphorus, Total (P)	1D Conc	1.5	2.26	12/1/2009
0PX00002*AD	December 2009	001	00665	Phosphorus, Total (P)	30D Conc	1.0	2.26	12/1/2009
0PX00002*AD	February 2010	001	00665	Phosphorus, Total (P)	1D Conc	1.5	4.65	2/1/2010
0PX00002*AD	February 2010	001	00665	Phosphorus, Total (P)	30D Conc	1.0	4.65	2/1/2010
0PX00002*AD	March 2010	001	00665	Phosphorus, Total (P)	30D Conc	1.0	1.18	3/1/2010
0PX00002*AD	May 2010	001	00665	Phosphorus, Total (P)	30D Conc	1.0	3.36	5/1/2010
0PX00002*AD	May 2010	001	00665	Phosphorus, Total (P)	30D Qty	0.14	.26707	5/1/2010
0PX00002*AD	May 2010	001	00665	Phosphorus, Total (P)	1D Conc	1.5	3.36	5/3/2010
0PX00002*AD	May 2010	001	00665	Phosphorus, Total (P)	1D Qty	0.21	.26707	5/3/2010
0PX00002*AD	June 2010	001	00665	Phosphorus, Total (P)	1D Conc	1.5	2.39	6/1/2010
0PX00002*AD	June 2010	001	00665	Phosphorus, Total (P)	30D Conc	1.0	2.39	6/1/2010
0PX00002*AD	June 2010	001	00665	Phosphorus, Total (P)	30D Qty	0.14	.17188	6/1/2010
0PX00002*AD	November 2010	001	00665	Phosphorus, Total (P)	1D Conc	1.5	2.48	11/1/2010
0PX00002*AD	November 2010	001	00665	Phosphorus, Total (P)	30D Conc	1.0	3.835	11/1/2010
0PX00002*AD	November 2010	001	00665	Phosphorus, Total (P)	1D Conc	1.5	5.19	11/15/2010
0PX00002*AD	December 2010	001	00665	Phosphorus, Total (P)	30D Conc	1.0	3.23	12/1/2010
0PX00002*AD	December 2010	001	00665	Phosphorus, Total (P)	1D Conc	1.5	3.23	12/6/2010
0PX00002*AD	February 2011	001	00665	Phosphorus, Total (P)	30D Conc	1.0	1.75	2/1/2011
0PX00002*AD	February 2011	001	00665	Phosphorus, Total (P)	1D Conc	1.5	1.75	2/2/2011
0PX00002*AD	March 2011	001	00665	Phosphorus, Total (P)	1D Conc	1.5	3.04	3/1/2011
0PX00002*AD	March 2011	001	00665	Phosphorus, Total (P)	30D Conc	1.0	3.04	3/1/2011

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
0PX00002*AD	March 2011	001	00665	Phosphorus, Total (P)	1D Qty	0.21	.32218	3/1/2011
0PX00002*AD	March 2011	001	00665	Phosphorus, Total (P)	30D Qty	0.14	.32218	3/1/2011
0PX00002*AD	May 2011	001	00665	Phosphorus, Total (P)	30D Conc	1.0	2.08	5/1/2011
0PX00002*AD	May 2011	001	00665	Phosphorus, Total (P)	30D Qty	0.14	.22831	5/1/2011
0PX00002*AD	May 2011	001	00665	Phosphorus, Total (P)	1D Conc	1.5	2.08	5/2/2011
0PX00002*AD	May 2011	001	00665	Phosphorus, Total (P)	1D Qty	0.21	.22831	5/2/2011
0PX00002*AD	June 2011	001	00665	Phosphorus, Total (P)	1D Conc	1.5	2.39	6/1/2011
0PX00002*AD	June 2011	001	00665	Phosphorus, Total (P)	30D Conc	1.0	2.39	6/1/2011
0PX00002*AD	June 2011	001	00665	Phosphorus, Total (P)	1D Qty	0.21	.28043	6/1/2011
0PX00002*AD	June 2011	001	00665	Phosphorus, Total (P)	30D Qty	0.14	.28043	6/1/2011
0PX00002*AD	July 2011	001	00665	Phosphorus, Total (P)	30D Conc	1.0	5.52	7/1/2011
0PX00002*AD	July 2011	001	00665	Phosphorus, Total (P)	30D Qty	0.14	.64769	7/1/2011
0PX00002*AD	July 2011	001	00665	Phosphorus, Total (P)	1D Conc	1.5	5.52	7/5/2011
0PX00002*AD	July 2011	001	00665	Phosphorus, Total (P)	1D Qty	0.21	.64769	7/5/2011
0PX00002*AD	August 2011	001	00665	Phosphorus, Total (P)	30D Conc	1.0	6.79	8/1/2011
0PX00002*AD	August 2011	001	00665	Phosphorus, Total (P)	30D Qty	0.14	.3084	8/1/2011
0PX00002*AD	August 2011	001	00665	Phosphorus, Total (P)	1D Conc	1.5	6.79	8/2/2011
0PX00002*AD	August 2011	001	00665	Phosphorus, Total (P)	1D Qty	0.21	.3084	8/2/2011
0PX00002*AD	September 2011	001	00665	Phosphorus, Total (P)	1D Conc	1.5	5.51	9/1/2011
0PX00002*AD	September 2011	001	00665	Phosphorus, Total (P)	30D Conc	1.0	5.51	9/1/2011
0PX00002*AD	October 2011	001	00665	Phosphorus, Total (P)	30D Conc	1.0	1.5	10/1/2011
0PX00002*AD	November 2011	001	00665	Phosphorus, Total (P)	30D Conc	1.0	4.02	11/1/2011
0PX00002*AD	November 2011	001	00665	Phosphorus, Total (P)	30D Qty	0.14	.15216	11/1/2011
0PX00002*AD	November 2011	001	00665	Phosphorus, Total (P)	1D Conc	1.5	4.02	11/2/2011
0PX00002*AD	December 2011	001	00665	Phosphorus, Total (P)	1D Conc	1.5	1.52	12/1/2011
0PX00002*AD	December 2011	001	00665	Phosphorus, Total (P)	30D Conc	1.0	1.52	12/1/2011
0PX00002*AD	December 2011	001	00665	Phosphorus, Total (P)	30D Qty	0.14	.14958	12/1/2011
0PX00002*AD	January 2012	001	00665	Phosphorus, Total (P)	30D Conc	1.0	1.04	1/1/2012
0PX00002*AD	February 2012	001	00665	Phosphorus, Total (P)	30D Conc	1.0	1.02	2/1/2012
0PX00002*AD	March 2012	001	00665	Phosphorus, Total (P)	30D Conc	1.0	1.18	3/1/2012
0PX00002*AD	April 2012	001	00665	Phosphorus, Total (P)	30D Conc	1.0	2.16	4/1/2012
0PX00002*AD	April 2012	001	00665	Phosphorus, Total (P)	1D Conc	1.5	2.16	4/2/2012
0PX00002*AD	May 2012	001	00665	Phosphorus, Total (P)	1D Conc	1.5	3.08	5/1/2012
0PX00002*AD	May 2012	001	00665	Phosphorus, Total (P)	30D Conc	1.0	3.08	5/1/2012
0PX00002*AD	August 2005	001	00530	Total Suspended Solids	30D Qty	1.68	21.5078	8/1/2005
0PX00002*AD	August 2005	001	00530	Total Suspended Solids	1D Qty	2.52	13.2399	8/8/2005
0PX00002*AD	August 2005	001	00530	Total Suspended Solids	1D Conc	18	24.	8/15/2005
0PX00002*AD	August 2005	001	00530	Total Suspended Solids	1D Qty	2.52	59.3185	8/15/2005
0PX00002*AD	August 2005	001	00530	Total Suspended Solids	1D Qty	2.52	30.1021	8/23/2005
0PX00002*AD	August 2005	001	00530	Total Suspended Solids	1D Qty	2.52	2.85011	8/29/2005
0PX00002*AD	April 2006	001	00530	Total Suspended Solids	30D Conc	12	14.	4/1/2006
0PX00002*AD	April 2006	001	00530	Total Suspended Solids	1D Conc	18	25.	4/17/2006
0PX00002*AD	May 2006	001	00530	Total Suspended Solids	1D Conc	18	28.	5/22/2006
0PX00002*AD	June 2006	001	00530	Total Suspended Solids	1D Conc	18	20.	6/12/2006
0PX00002*AD	July 2006	001	00530	Total Suspended Solids	30D Conc	12	22.5	7/1/2006
0PX00002*AD	July 2006	001	00530	Total Suspended Solids	1D Conc	18	24.	7/5/2006
0PX00002*AD	July 2006	001	00530	Total Suspended Solids	1D Conc	18	23.	7/10/2006
0PX00002*AD	July 2006	001	00530	Total Suspended Solids	1D Conc	18	25.	7/17/2006
0PX00002*AD	August 2006	001	00530	Total Suspended Solids	30D Conc	12	15.2	8/1/2006
0PX00002*AD	August 2006	001	00530	Total Suspended Solids	1D Conc	18	24.	8/8/2006
0PX00002*AD	September 2006	001	00530	Total Suspended Solids	30D Conc	12	16.75	9/1/2006
0PX00002*AD	September 2006	001	00530	Total Suspended Solids	1D Conc	18	28.	9/6/2006
0PX00002*AD	September 2006	001	00530	Total Suspended Solids	1D Conc	18	30.	9/18/2006
0PX00002*AD	December 2006	001	00530	Total Suspended Solids	1D Conc	18	27.	12/26/2006
0PX00002*AD	January 2007	001	00530	Total Suspended Solids	30D Conc	12	14.	1/1/2007
0PX00002*AD	January 2007	001	00530	Total Suspended Solids	1D Conc	18	21.	1/8/2007
0PX00002*AD	February 2007	001	00530	Total Suspended Solids	1D Conc	18	21.	2/5/2007
0PX00002*AD	April 2007	001	00530	Total Suspended Solids	30D Conc	12	13.4	4/1/2007
0PX00002*AD	April 2007	001	00530	Total Suspended Solids	1D Conc	18	21.	4/16/2007

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
0PX00002*AD	May 2007	001	00530	Total Suspended Solids	1D Conc	18	34.	5/30/2007
0PX00002*AD	July 2007	001	00530	Total Suspended Solids	30D Conc	12	25.	7/1/2007
0PX00002*AD	July 2007	001	00530	Total Suspended Solids	1D Conc	18	31.	7/9/2007
0PX00002*AD	July 2007	001	00530	Total Suspended Solids	1D Conc	18	24.	7/16/2007
0PX00002*AD	July 2007	001	00530	Total Suspended Solids	1D Conc	18	34.	7/23/2007
0PX00002*AD	August 2007	001	00530	Total Suspended Solids	30D Conc	12	45.6666	8/1/2007
0PX00002*AD	August 2007	001	00530	Total Suspended Solids	30D Qty	1.68	2.05021	8/1/2007
0PX00002*AD	August 2007	001	00530	Total Suspended Solids	1D Conc	18	36.	8/6/2007
0PX00002*AD	August 2007	001	00530	Total Suspended Solids	1D Qty	2.52	2.58894	8/6/2007
0PX00002*AD	August 2007	001	00530	Total Suspended Solids	1D Conc	18	67.	8/13/2007
0PX00002*AD	August 2007	001	00530	Total Suspended Solids	1D Qty	2.52	2.78955	8/13/2007
0PX00002*AD	August 2007	001	00530	Total Suspended Solids	1D Conc	18	34.	8/28/2007
0PX00002*AD	September 2007	001	00530	Total Suspended Solids	30D Conc	12	51.5	9/1/2007
0PX00002*AD	September 2007	001	00530	Total Suspended Solids	1D Conc	18	53.	9/4/2007
0PX00002*AD	September 2007	001	00530	Total Suspended Solids	1D Conc	18	31.	9/10/2007
0PX00002*AD	September 2007	001	00530	Total Suspended Solids	1D Conc	18	70.	9/17/2007
0PX00002*AD	September 2007	001	00530	Total Suspended Solids	1D Conc	18	52.	9/24/2007
0PX00002*AD	October 2007	001	00530	Total Suspended Solids	30D Conc	12	19.5	10/1/2007
0PX00002*AD	October 2007	001	00530	Total Suspended Solids	1D Conc	18	23.	10/15/2007
0PX00002*AD	October 2007	001	00530	Total Suspended Solids	1D Conc	18	20.	10/23/2007
0PX00002*AD	November 2007	001	00530	Total Suspended Solids	30D Conc	12	19.75	11/1/2007
0PX00002*AD	November 2007	001	00530	Total Suspended Solids	1D Conc	18	22.	11/19/2007
0PX00002*AD	November 2007	001	00530	Total Suspended Solids	1D Conc	18	46.	11/26/2007
0PX00002*AD	December 2007	001	00530	Total Suspended Solids	30D Conc	12	29.5	12/1/2007
0PX00002*AD	December 2007	001	00530	Total Suspended Solids	1D Conc	18	44.	12/3/2007
0PX00002*AD	December 2007	001	00530	Total Suspended Solids	1D Conc	18	40.	12/10/2007
0PX00002*AD	December 2007	001	00530	Total Suspended Solids	1D Conc	18	28.	12/27/2007
0PX00002*AD	April 2008	001	00530	Total Suspended Solids	30D Conc	12	13.	4/1/2008
0PX00002*AD	April 2008	001	00530	Total Suspended Solids	1D Qty	2.52	3.74715	4/8/2008
0PX00002*AD	April 2008	001	00530	Total Suspended Solids	1D Conc	18	24.	4/15/2008
0PX00002*AD	October 2008	001	00530	Total Suspended Solids	30D Conc	12	19.25	10/1/2008
0PX00002*AD	October 2008	001	00530	Total Suspended Solids	1D Conc	18	20.	10/13/2008
0PX00002*AD	October 2008	001	00530	Total Suspended Solids	1D Conc	18	26.	10/28/2008
0PX00002*AD	November 2008	001	00530	Total Suspended Solids	30D Conc	12	24.25	11/1/2008
0PX00002*AD	November 2008	001	00530	Total Suspended Solids	1D Conc	18	23.	11/4/2008
0PX00002*AD	November 2008	001	00530	Total Suspended Solids	1D Conc	18	42.	11/17/2008
0PX00002*AD	November 2008	001	00530	Total Suspended Solids	1D Conc	18	26.	11/25/2008
0PX00002*AD	January 2009	001	00530	Total Suspended Solids	1D Conc	18	20.	1/5/2009
0PX00002*AD	February 2009	001	00530	Total Suspended Solids	30D Conc	12	14.25	2/1/2009
0PX00002*AD	February 2009	001	00530	Total Suspended Solids	1D Conc	18	20.	2/23/2009
0PX00002*AD	March 2009	001	00530	Total Suspended Solids	30D Conc	12	67.8	3/1/2009
0PX00002*AD	March 2009	001	00530	Total Suspended Solids	1D Conc	18	30.	3/2/2009
0PX00002*AD	March 2009	001	00530	Total Suspended Solids	1D Conc	18	247.	3/10/2009
0PX00002*AD	March 2009	001	00530	Total Suspended Solids	1D Qty	2.52	5.60937	3/10/2009
0PX00002*AD	March 2009	001	00530	Total Suspended Solids	1D Conc	18	28.	3/17/2009
0PX00002*AD	March 2009	001	00530	Total Suspended Solids	1D Conc	18	21.	3/26/2009
0PX00002*AD	May 2009	001	00530	Total Suspended Solids	30D Conc	12	15.25	5/1/2009
0PX00002*AD	May 2009	001	00530	Total Suspended Solids	1D Conc	18	31.	5/11/2009
0PX00002*AD	July 2009	001	00530	Total Suspended Solids	30D Conc	12	15.6666	7/1/2009
0PX00002*AD	July 2009	001	00530	Total Suspended Solids	1D Conc	18	20.	7/6/2009
0PX00002*AD	July 2009	001	00530	Total Suspended Solids	1D Conc	18	21.	7/13/2009
0PX00002*AD	August 2009	001	00530	Total Suspended Solids	30D Conc	12	13.5	8/1/2009
0PX00002*AD	August 2009	001	00530	Total Suspended Solids	1D Conc	18	19.	8/10/2009
0PX00002*AD	September 2009	001	00530	Total Suspended Solids	30D Conc	12	45.25	9/1/2009
0PX00002*AD	September 2009	001	00530	Total Suspended Solids	1D Conc	18	30.	9/10/2009
0PX00002*AD	September 2009	001	00530	Total Suspended Solids	1D Conc	18	50.	9/15/2009
0PX00002*AD	September 2009	001	00530	Total Suspended Solids	1D Conc	18	93.	9/23/2009
0PX00002*AD	October 2009	001	00530	Total Suspended Solids	30D Conc	12	26.25	10/1/2009
0PX00002*AD	October 2009	001	00530	Total Suspended Solids	1D Conc	18	20.	10/19/2009

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
0PX00002*AD	October 2009	001	00530	Total Suspended Solids	1D Conc	18	58.	10/26/2009
0PX00002*AD	October 2009	001	00530	Total Suspended Solids	1D Qty	2.52	3.95154	10/26/2009
0PX00002*AD	November 2009	001	00530	Total Suspended Solids	30D Conc	12	38.	11/1/2009
0PX00002*AD	November 2009	001	00530	Total Suspended Solids	1D Conc	18	60.	11/2/2009
0PX00002*AD	November 2009	001	00530	Total Suspended Solids	1D Qty	2.52	2.7252	11/2/2009
0PX00002*AD	November 2009	001	00530	Total Suspended Solids	1D Conc	18	29.	11/9/2009
0PX00002*AD	November 2009	001	00530	Total Suspended Solids	1D Conc	18	25.	11/16/2009
0PX00002*AD	November 2009	001	00530	Total Suspended Solids	1D Conc	18	38.	11/27/2009
0PX00002*AD	December 2009	001	00530	Total Suspended Solids	30D Conc	12	26.5	12/1/2009
0PX00002*AD	December 2009	001	00530	Total Suspended Solids	1D Conc	18	34.	12/8/2009
0PX00002*AD	December 2009	001	00530	Total Suspended Solids	1D Conc	18	40.	12/22/2009
0PX00002*AD	January 2010	001	00530	Total Suspended Solids	30D Conc	12	30.75	1/1/2010
0PX00002*AD	January 2010	001	00530	Total Suspended Solids	1D Conc	18	46.	1/4/2010
0PX00002*AD	January 2010	001	00530	Total Suspended Solids	1D Conc	18	38.	1/11/2010
0PX00002*AD	January 2010	001	00530	Total Suspended Solids	1D Conc	18	32.	1/20/2010
0PX00002*AD	January 2010	001	00530	Total Suspended Solids	1D Qty	2.52	2.90688	1/20/2010
0PX00002*AD	March 2010	001	00530	Total Suspended Solids	30D Conc	12	14.5	3/1/2010
0PX00002*AD	March 2010	001	00530	Total Suspended Solids	1D Conc	18	26.	3/1/2010
0PX00002*AD	April 2010	001	00530	Total Suspended Solids	30D Conc	12	13.25	4/1/2010
0PX00002*AD	April 2010	001	00530	Total Suspended Solids	1D Conc	18	29.	4/12/2010
0PX00002*AD	June 2010	001	00530	Total Suspended Solids	1D Conc	18	24.	6/1/2010
0PX00002*AD	June 2010	001	00530	Total Suspended Solids	30D Conc	12	24.	6/1/2010
0PX00002*AD	June 2010	001	00530	Total Suspended Solids	1D Conc	18	25.	6/8/2010
0PX00002*AD	June 2010	001	00530	Total Suspended Solids	1D Qty	2.52	2.55488	6/8/2010
0PX00002*AD	June 2010	001	00530	Total Suspended Solids	1D Conc	18	30.	6/15/2010
0PX00002*AD	July 2010	001	00530	Total Suspended Solids	30D Conc	12	28.	7/1/2010
0PX00002*AD	July 2010	001	00530	Total Suspended Solids	30D Qty	1.68	2.01267	7/1/2010
0PX00002*AD	July 2010	001	00530	Total Suspended Solids	1D Conc	18	21.	7/7/2010
0PX00002*AD	July 2010	001	00530	Total Suspended Solids	1D Conc	18	24.	7/12/2010
0PX00002*AD	July 2010	001	00530	Total Suspended Solids	1D Qty	2.52	2.54352	7/12/2010
0PX00002*AD	July 2010	001	00530	Total Suspended Solids	1D Conc	18	33.	7/19/2010
0PX00002*AD	July 2010	001	00530	Total Suspended Solids	1D Conc	18	34.	7/26/2010
0PX00002*AD	August 2010	001	00530	Total Suspended Solids	30D Conc	12	25.	8/1/2010
0PX00002*AD	August 2010	001	00530	Total Suspended Solids	1D Conc	18	20.	8/2/2010
0PX00002*AD	August 2010	001	00530	Total Suspended Solids	1D Conc	18	30.	8/9/2010
0PX00002*AD	August 2010	001	00530	Total Suspended Solids	1D Conc	18	32.	8/23/2010
0PX00002*AD	September 2010	001	00530	Total Suspended Solids	30D Conc	12	18.	9/1/2010
0PX00002*AD	September 2010	001	00530	Total Suspended Solids	1D Conc	18	26.	9/7/2010
0PX00002*AD	September 2010	001	00530	Total Suspended Solids	1D Conc	18	27.	9/27/2010
0PX00002*AD	November 2010	001	00530	Total Suspended Solids	1D Conc	18	31.	11/1/2010
0PX00002*AD	November 2010	001	00530	Total Suspended Solids	30D Conc	12	15.	11/1/2010
0PX00002*AD	December 2010	001	00530	Total Suspended Solids	30D Conc	12	36.	12/1/2010
0PX00002*AD	December 2010	001	00530	Total Suspended Solids	1D Conc	18	28.	12/6/2010
0PX00002*AD	December 2010	001	00530	Total Suspended Solids	1D Conc	18	54.	12/13/2010
0PX00002*AD	December 2010	001	00530	Total Suspended Solids	1D Conc	18	26.	12/20/2010
0PX00002*AD	January 2011	001	00530	Total Suspended Solids	30D Conc	12	32.75	1/1/2011
0PX00002*AD	January 2011	001	00530	Total Suspended Solids	1D Conc	18	32.	1/3/2011
0PX00002*AD	January 2011	001	00530	Total Suspended Solids	1D Conc	18	20.	1/10/2011
0PX00002*AD	January 2011	001	00530	Total Suspended Solids	1D Conc	18	78.	1/18/2011
0PX00002*AD	February 2011	001	00530	Total Suspended Solids	30D Conc	12	18.75	2/1/2011
0PX00002*AD	February 2011	001	00530	Total Suspended Solids	1D Conc	18	32.	2/15/2011
0PX00002*AD	February 2011	001	00530	Total Suspended Solids	1D Conc	18	20.	2/22/2011
0PX00002*AD	March 2011	001	00530	Total Suspended Solids	1D Conc	18	32.	3/1/2011
0PX00002*AD	March 2011	001	00530	Total Suspended Solids	30D Conc	12	26.	3/1/2011
0PX00002*AD	March 2011	001	00530	Total Suspended Solids	1D Qty	2.52	3.39136	3/1/2011
0PX00002*AD	March 2011	001	00530	Total Suspended Solids	30D Qty	1.68	2.04201	3/1/2011
0PX00002*AD	March 2011	001	00530	Total Suspended Solids	1D Conc	18	34.	3/8/2011
0PX00002*AD	March 2011	001	00530	Total Suspended Solids	1D Qty	2.52	3.34594	3/8/2011
0PX00002*AD	March 2011	001	00530	Total Suspended Solids	1D Conc	18	34.	3/22/2011

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
0PX00002*AD	April 2011	001	00530	Total Suspended Solids	30D Conc	12	15.	4/1/2011
0PX00002*AD	April 2011	001	00530	Total Suspended Solids	1D Conc	18	20.	4/11/2011
0PX00002*AD	May 2011	001	00530	Total Suspended Solids	30D Conc	12	25.75	5/1/2011
0PX00002*AD	May 2011	001	00530	Total Suspended Solids	30D Qty	1.68	1.79031	5/1/2011
0PX00002*AD	May 2011	001	00530	Total Suspended Solids	1D Conc	18	20.	5/2/2011
0PX00002*AD	May 2011	001	00530	Total Suspended Solids	1D Conc	18	34.	5/16/2011
0PX00002*AD	May 2011	001	00530	Total Suspended Solids	1D Conc	18	33.	5/23/2011
0PX00002*AD	June 2011	001	00530	Total Suspended Solids	1D Conc	18	24.	6/1/2011
0PX00002*AD	June 2011	001	00530	Total Suspended Solids	30D Conc	12	15.25	6/1/2011
0PX00002*AD	June 2011	001	00530	Total Suspended Solids	1D Qty	2.52	2.81604	6/1/2011
0PX00002*AD	July 2011	001	00530	Total Suspended Solids	30D Conc	12	14.25	7/1/2011

SENDER: *COMPLETE THIS SECTION*

- Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.

1. Article Addressed to:

Boris Slogar
Muskingum Watershed Cons. District
1319 3rd Street NW
P.O. Box 349
New Philadelphia, OH 44663

COMPLETE THIS SECTION ON DELIVERY

A. Signature
X Jason Collins
☐ Agent
☐ Addressee

B. Received by (Printed Name)
Jason Collins

C. Date of Delivery

D. Is delivery address different from item 1? ☐ Yes
If YES, enter delivery address below: ☐ No

NEW PHILADELPHIA, OH 44663-9998
AUG 3 2012

3. Service Type
☒ Certified Mail ☐ Express Mail
☐ Registered ☐ Return Receipt for Merchandise
☐ Insured Mail ☐ C.O.D.

4. Restricted Delivery? *(Extra Fee)* ☐ Yes

2. Article Number
(Transfer from service lat
7010 1060 0001 7896 4604

PS Form 3811, February 2004 Domestic Return Receipt 102595-02-M-1540

U.S. Postal Service™
CERTIFIED MAIL™ RECEIPT
(Domestic Mail Only; No Insurance Coverage Provided)

For delivery information visit our website at www.usps.com®

OFFICIAL USE

7010 1060 0001 7896 4604

Postage $ 1.70

Certified Fee: $ 2.95
(En **Return Receipt Fee:** 2.35

Restricted Delivery Fee (Endorsement Required)

Total Postage & Fees $ 7.00

LOUISVILLE OHIO
AUG 09 2012
Postmark Here
43138

Sent To
Boris Slogar, Muskingum Watershed Cons. Dist.
Street, Apt. No.; or PO Box No. 1319 3rd. St., NW, P.O. Box 349
City, State, ZIP+4 New Philadelphia, OH 44663

PS Form 3800, August 2006 See Reverse for Instructions