



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

August 13, 2012

RE: CUYAHOGA COUNTY  
CITY OF BEACHWOOD  
BEACHWOOD REHABILITATION HOSPITAL  
CONSTRUCTION STORM WATER  
PERMIT NO: 3GC05751

Mr. Brad Beyer  
Cogdell Spencer Erdman  
One Erdman Place  
Madison, WI 53717

Dear Mr. Beyer:

On August 9, 2012, I performed a compliance inspection for storm water best management practices (BMPs) at the above referenced site. I was accompanied by Steve Handler, Inspector with the GPD Group for the City of Beachwood. While on site, I met with Pat Dolan, Senior Project Superintendent with Erdman. Our records indicate that Cogdell Spencer Erdman has obtained coverage under the Ohio EPA General Storm Water National Pollutant Discharge Elimination System (NPDES) Permit for Construction Activities #3GC05751\*AG.

After review of the site and Storm Water Pollution Prevention Plan (SWP3), I noted that temporary stabilization had taken place around the sediment basin and that a skimmer device had been designed and will be installed soon. I also noted that there were two small piles of dried concrete on the ground. Please disposed of these in the solid waste dumpster.

If you have further questions, please contact Dan Bogoevski, District Engineer of the Division of Surface Water, at (330) 963-1145 or by e-mail at [dan.bogoevski@epa.state.oh.us](mailto:dan.bogoevski@epa.state.oh.us).

Sincerely,

Katie Bowman  
Assistant to the District Engineer  
Division of Surface Water

KB/cs

cc: Matt Adkins, Project Engineer, GPD Group  
Steve Handler, Inspector, GPD Group,  
Pat Dolan, Project Superintendent, Erdman  
Todd Houser, Cuyahoga SWCD  
Merle S. Gorden, Mayor, City of Beachwood

Attachments: Photo

**INSPECTION PHOTOS**

**Beachwood Rehabilitation Hospital**



**Figure 1:** Small dry concrete piles

City of Beachwood, Cuyahoga County  
Photos taken on August 9, 2012  
Photos taken by Katie Bowman, DSW