



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

August 14, 2012

RE: CUYAHOGA COUNTY
MAYFIELD VILLAGE
CUYAHOGA CO PUBLIC LIBRARY
MAYFIELD BRANCH
CONSTRUCTION STORM WATER
PERMIT NO: 3GC05882

Mr. William Rubin
Cuyahoga County Public Library
2111 Snow Road
Parma, OH 44134

Dear Mr. Rubin:

On August 13, 2012, I performed a compliance inspection for storm water best management practices (BMPs) at the above referenced site. I was accompanied by Tom Cappello, Engineer with Stephen Hovancsek & Associates. While on site, we met with Justin Thenn, Project Engineer for Infinity Construction. Our records indicate that the Cuyahoga County Public Library has obtained coverage under the Ohio EPA General Storm Water National Pollutant Discharge Elimination System (NPDES) Permit for Construction Activities #3GC05882*AG.

After review of the site and the Storm Water Pollution Prevention Plan (SWP3), I noted that no runoff is going off site since the site sits lower than the surrounding area. I was informed that the sediment basin has not been installed because the outlet is not able to connect to the storm sewer system. Once the connection from the outlet to the storm sewer is made and storm water is able to go offsite, please install the sediment basin with the skimmer device. If any area is undisturbed for 21 or more days, please seed and mulch within seven days.

If you have any questions, please contact Dan Bogoevski, District Engineer for Ohio EPA's Division of Surface Water at (330) 963-1145 or by e-mail at Dan.Bogoevski@epa.state.oh.us

Sincerely,

Katie Bowman
Assistant to the District Engineer
Division of Surface Water

KB/cs

cc: Tom Cappello, Engineer, Stephen Hovancsek &
Todd Houser, Cuyahoga SWCD
Bruce G. Rinker, Mayor, Mayfield Village