



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

August 3, 2012

Mr. Robert Leventry
Butler County Environmental Services
130 High Street
Hamilton, Ohio 45069

RE: Butler County, Upper Mill Creek WWTP, NPDES Permit Violations

Dear Mr. Leventry:

We have received your Discharge Monitoring Reports covering the month of June 2012 for the referenced facility. Our review indicates violations of the conditions of your NPDES Permit (NPDES Permit # OH0072087; OEPA Permit # 1PK00016*LD). The specific instances of noncompliance were as follows:

Effluent Limit Violations for June 2012					
Reporting Period	Parameter	Limit Type	Units	Permit Limit	Reported Value
June 2012	TSS	Weekly	mg/l	18	20
June 2012	Phosphorus	Monthly	mg/l	1.0	1.2
June 2012	Phosphorus	Weekly	mg/l	1.5	1.7

Please be advised that failure to comply with the effluent limitations of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have reviewed your report addressing the reasons for the above violations and the actions being taken to prevent further occurrences. No additional information is requested at this time. Future violations must continue to be reported as required by the NPDES permit as detailed in Part III.12 titled "Noncompliance Notification."

If you have any questions regarding the above, please contact me at (937) 285-6096.

Sincerely,

Ned Sarle
Environmental Specialist
Division of Surface Water
Permit Section

ec: Brian Custer, Butler County Water and Sewer Department

NS/ca